

Table 3 - Water Testing - UTSC Results - August 31, 2021

Level	GU/mL
1	<10
2	10-100
3	>100

Level	CFU/mL
1	<10
2	10-100
3	>100

Test Date	Building	Room Tested	Room Description	Room Status q-PCR results	Room Status - culture (validation) results
Thursday, March 11, 2021	Science Research		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Joan Foley Hall		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Arts and Administration		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Students Centre		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	N'sheemaehn Child Care Centre		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Instructional Centre		Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	K-05		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	L-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	E-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	I-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	H-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	J-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	A-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	B-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	G-08		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	H-02		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Arts and Administration		1st Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Arts and Administration		2nd Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Instructional Centre - IC40	IC40	Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Instructional Centre		Mechanical room - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Students Centre - SL241	SL241	Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Students Centre		Basement - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Social Sciences		1st Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Social Sciences		3rd Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Joan Foley Hall		1st Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Joan Foley Hall		Boiler Room - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Arts and Administration		1st Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Arts and Administration		2nd Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Instructional Centre - IC40	IC40	Instructional Centre	ND - Open - No action required	N/A
Monday, March 29, 2021	Instructional Centre		Mechanical room	ND - Open - No action required	N/A
Monday, March 29, 2021	Students Centre - SL241	SL241	Students Centre	ND - Open - No action required	N/A
Monday, March 29, 2021	Students Centre		Basement	ND - Open - No action required	N/A
Monday, March 29, 2021	Social Sciences		1st Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Social Sciences		3rd Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Joan Foley Hall		1st Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Joan Foley Hall		Boiler Room	ND - Open - No action required	N/A
Monday, March 29, 2021	Arts and Administration		Mechanical Rm.	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Highland Hall		Mechanical Rm.	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Environmental Sciences and Chemistry Building		Rm. 4th floor washroom close to EV431	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Environmental Sciences and Chemistry Building		Rm. 1st floor washroom close to EV121	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Bladen Wing		4th floor washroom close to BV450	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Bladen Wing 2 nd floor washroom close to BV222		4th floor washroom close to BV450	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Academic Resource Centre	AC226		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Humanties Wing	HW218		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Science Wing	SW306		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Science Wing	SW522		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Science Research Building	SY141	Initial analysis showed PCR inhibition but re-analysis using a 1.6 GU/ml detection limit showed not detected	ND - Open - No action required	N/A
Friday, June 4, 2021	Miller Lash House	Kitchen	Sink	ND - Open - No action required	N/A
Friday, June 4, 2021	Environmental Sciences and Chemistry Building	Chiller room		ND - Open - No action required	N/A
Friday, June 4, 2021	Science Wing	6th Floor Mechanical room		ND - Open - No action required	N/A
Thursday, June 10, 2021	G-01		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	M-08		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	B-08		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	E-09		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	Residences	Laundry room	Near K-01	ND - Open - No action required	N/A
Thursday, June 10, 2021	K-01		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	A-11		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	I-04		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	F-09		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	H-06		Kitchen sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Joan Foley Hall	Laundry room 100L	Sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Social Sciences Buidling	1st floor Women washroom	Near MW120	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Environmental Sciences and Chemistry Building	1st floor Women washroom	Near EV121	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Science Research Building	1st floor Women washroom	Near SY141	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Arts and Administration	1st floor Women washroom	Near AA122	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Academic Resource Centre	AC226	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Science Wing	SW306	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Humanties Wing	HW218	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Highland Hall	1st floor Women washroom	Near HL170	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Bladen Wing	BV203	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Instructional Centre	1st floor Women washroom	Near IC118	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Student Centre	1st floor Women washroom	Near SL151	ND - Open - No action required	N/A