

| Table 4 - Water Testing - UTM Results - Sept 8, 2021 | | | | Level | GU/mL | Level | CFU/mL |
|--|-------------------------------|---------------------------------------|------------------------------|--------------------------------|--------|---|--------|
| | | | | 1 | <10 | 1 | <10 |
| | | | | 2 | 10-100 | 2 | 10-100 |
| | | | | 3 | >100 | 3 | >100 |
| | | | | ND - None detected | | ND - None detected | |
| Test Date | Building | Room Tested | Room Description | Room Status q-PCR results | | Room Status - culture (validation) results | |
| 21-Apr-21 | Erindale Hall | Suite 207 | | n/a | | ND - Open - No action required | |
| 21-Apr-21 | HMALC Building | Rm253 | Caretaker closet on level 2 | n/a | | ND - Open - No action required | |
| 21-Apr-21 | Oscar Peterson Hall | Rm 600C | 6th Floor- Caretaking Closet | n/a | | ND - Open - No action required | |
| 21-Apr-21 | Roy Ivor Hall, BLOCK A | Rm 606 | | n/a | | ND - Open - No action required | |
| 21-Apr-21 | Roy Ivor Hall, BLOCK B | Rm 621 | | n/a | | ND - Open - No action required | |
| 21-Apr-21 | Roy Ivor Hall, BLOCK C | | Main Floor Caretakers closet | n/a | | ND - Open - No action required | |
| 21-Apr-21 | Roy Ivor Hall, BLOCK D | Rm 645 | | n/a | | ND - Open - No action required | |
| 21-Apr-21 | WG Davis Building | DC5036 | Greenhouse | n/a | | ND - Open - No action required | |
| 21-Apr-21 | WG Davis Building, ABCD Block | DV5004 | 5th floor washroom | n/a | | 90 - Open - Normal operations with preventive maintenance | |
| 30-Apr-21 | WG Davis Building, ABCD Block | DV5004 | 5th floor washroom | ND - Open - No action required | | n/a | |
| 7-Jun-21 | Margarth Valley 154 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | Leacock Lane 132 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | Putnam Place 107 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | McLuhan Ct 56 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | Leacock Lane 148 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | McLuhan Ct. 88 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | McGrath Valley 225 | | Townhouse | n/a | | ND - Open - No action required | |
| 7-Jun-21 | Putnam Place 95 | | Townhouse | n/a | | ND - Open - No action required | |
| 20-Jul-21 | MN building | | Hot Water Tank (HWT) 1 | n/a | | 3 - Open - No action required | |
| 20-Jul-21 | MN building | | Hot Water Tank (HWT) 2 | n/a | | ND - Open - No action required | |
| 20-Jul-21 | MN building | | Hot Water faucet (HW) | n/a | | ND - Open - No action required | |
| 20-Jul-21 | Deerfield Hall | | Hot Water Tank (HWT) 3 | n/a | | 1 - Open - No action required | |
| 20-Jul-21 | Deerfield Hall | | Hot Water Tank (HWT) 2 | n/a | | ND - Open - No action required | |
| 20-Jul-21 | Deerfield Hall | | Hot Water Tank (HWT) 1 | n/a | | ND - Open - No action required | |
| 20-Jul-21 | Deerfield Hall | | Hot Water faucet (HW) | n/a | | 4 - Open - No action required | |
| 10-Aug-21 | RAWC | Men's locker rm 115 | Hot Water faucet (HW) | n/a | | ND - Open - No action required | |
| 10-Aug-21 | RAWC | | Hot Water Tank (HWT) 1 | n/a | | ND - Open - No action required | |
| 10-Aug-21 | RAW | | Hot Water Tank (HWT) 2 | n/a | | ND - Open - No action required | |
| 10-Aug-21 | HSC | Penhouse Mech Room | Hot Water faucet (HW) | n/a | | ND - Open - No action required | |
| 10-Aug-21 | DV JKL | Caretaking closet Rm 1111 | Hot Water faucet (HW) | n/a | | ND - Open - No action required | |
| 24-Aug-21 | CCT | | Hot Water Tank (HWT) 1 | n/a | | ND - Open - No action required | |
| 24-Aug-21 | CCT | | Hot Water Tank (HWT) 2 | n/a | | ND - Open - No action required | |
| 24-Aug-21 | CCT | 4199 - sink in caretaking closet | Hot Water (HW) faucet | n/a | | ND - Open - No action required | |
| 24-Aug-21 | IB | 29 - sink in basement mechanical room | Hot Water (HW) faucet | n/a | | ND - Open - No action required | |
| 24-Aug-21 | IB | | Hot Water Tank (HWT) 1 | n/a | | ND - Open - No action required | |