

Table 5 - Water Testing - UTM E. Coli and Total Coliform Results - Sept. 8, 2021

E.COLI LIMITS
Potable Cold-Water = 0 CFU/100-ml
Potable Cold-Water ≥ 1 CFU/100-ml
TOTAL COLIFORMS LIMITS
Potable Cold-Water = 0 CFU/100-ml
Potable Cold-Water ≥ 1 CFU/100-ml

Test Date	Building	Room Tested	Room Description	Room Status
21-Apr-21	WG Davis Building, ABCD Block	DV5004	5th floor washroom	0 - Open - No action required
21-Apr-21	HMALC Building	Rm 253	Caretaker Closet on Level 2	0 - Open - No action required
21-Apr-21	Erindale Hall	Suite 207		0 - Open - No action required
21-Apr-21	Oscar Peterson Hall	Rm 600C	6th floor - Caretaker Closet	0 - Open - No action required
21-Apr-21	Roy Ivor Hall, BLOCK A	Rm 606		0 - Open - No action required
21-Apr-21	Roy Ivor Hall, BLOCK B	Rm 621		0 - Open - No action required
21-Apr-21	Roy Ivor Hall, BLOCK C		Main floor caretaker closet	0 - Open - No action required
21-Apr-21	Roy Ivor Hall, BLOCK D	Rm 645		0 - Open - No action required
10-Aug-21	RAWC	Men's locker rm 115	Cold Water faucet	0 - Open - No action required
10-Aug-21	DV JKL	Caretaking closet sink rm 1111	Cold Water faucet	0 - Open - No action required
10-Aug-21	HSC	Penthouse Mech Rm	Cold Water faucet	0 - Open - No action required
24-Aug-21	CCT	4199 – sink in caretaking closet	Cold Water faucet	0 - Open - No action required
24-Aug-21	IB	465 – sink in mechanical penthouse	Cold Water faucet	0 - Open - No action required