

Table 2 - Water Testing - St. George - Historical Results (qPCR) - November 26, 2021

Level	GU/mL
1	<10
2	10-100
3	>100

GU = Genomic Units

Test Date	Building	Room Tested	Room Description	Room Status
Wednesday, February 24, 2021	107 St. George Garage		P1 Room 128	ND - Open - No action required
Wednesday, February 24, 2021	107 St. George Garage	101	P1 Washroom Room 101	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	132	JP - 1st Floor Washroom Room 132	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	333	JP - 3rd Floor Practice Room Sink Room 333	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	432	JP - 4th Floor Men's Washroom Room 432	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music		JP - Basement Water Fountain Beside Room 17	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building	AP130	AP - 1st Floor Lab Sink	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building	AP102	AP - 1st Floor Student Lounge Kitchen	9.3 - Open - No action required
Tuesday, June 22, 2021	Anthropology Building	AP102	AP - 1st Floor Student Lounge Kitchen	ND - Open - No action required
Monday, October 18, 2021	Anthropology Building		AP - 2nd Floor Water Fountain Near Department of Anthropology Administrative Offices	5 - Open - No action required
Tuesday, August 24, 2021	Anthropology Building		AP - 3rd Floor Water Fountain Near AP300	ND - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP411	AP - 4th Floor All Gender Accessible Washroom Shower	77 - Open - Normal operations with preventive maintenance
Tuesday, September 7, 2021	Anthropology Building	AP411	AP - 4th Floor All Gender Accessible Washroom Shower	260 - Closed - Isolation point of use, remediation required
Thursday, September 23, 2021	Anthropology Building	AP411	AP - 4th Floor All Gender Accessible Washroom Shower	ND - Open - No action required
Monday, October 4, 2021	Anthropology Building	AP411	AP - 4th Floor All Gender Accessible Washroom Shower	27 - Open - Normal operations with preventive maintenance
Monday, October 18, 2021	Anthropology Building	AP411	AP - 4th Floor All Gender Accessible Washroom Shower	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building		AP - 5th Floor Water Fountain Beside AP 500	ND - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP535	AP - 5th Floor Water Fountain Beside AP 500	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building	AP69	AP - Basement All-Gender Washroom	ND - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP59	AP - Basement All-Gender Washroom	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building		AB - 1st Floor Left All-Gender Washroom	29 - Open - Normal operations with preventive maintenance
Thursday, August 26, 2021	Astronomy & Astrophysics Building	AB201	AB - 2nd Floor Lounge Kitchenette	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building	AB55	AB - Basement Lab Sink (Left)	ND - Open - No action required
Tuesday, September 29, 2020	Astronomy & Astrophysics Building		AB - Basement Men's Washroom	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building		AB - Basement Water Fountain Near AB52	32 - Open - Normal operations with preventive maintenance
Tuesday, September 29, 2020	Astronomy & Astrophysics Building	AB102	AB - Kitchen	ND - Open - No action required
Tuesday, September 29, 2020	Astronomy & Astrophysics Building	AB73A	AB - Lab	ND - Open - No action required
Tuesday, September 29, 2020	Astronomy & Astrophysics Building	AB215K	AB - Women's Washroom	ND - Open - No action required
Thursday, October 22, 2020	Bahen Centre for Information Technology		BA - 3rd Floor Water Fountain	ND - Open - No action required
Tuesday, September 21, 2021	Bahen Centre for Information Technology	BA4286	BA - 4th Floor All-Gender Washroom	ND - Open - No action required
Tuesday, September 21, 2021	Bahen Centre for Information Technology	BA5284	BA - 5th Floor Men's Washroom	ND - Open - No action required
Thursday, October 22, 2020	Bahen Centre for Information Technology		BA - 5th Floor Women's Washroom	ND - Open - No action required
Tuesday, September 21, 2021	Bahen Centre for Information Technology	BA8202	BA - 8th Floor Lab Sink	ND - Open - No action required
Thursday, October 22, 2020	Bahen Centre for Information Technology	BA8224	BA - Lab	ND - Open - No action required
Monday, November 2, 2020	Bancroft Building	RM213	BF - 2nd Floor Kitchen	ND - Open - No action required
Thursday, August 26, 2021	Bancroft Building		BF - 3rd Floor Water Fountain Near BF322	ND - Open - No action required
Monday, November 2, 2020	Bancroft Building		BF - 3rd Men's Washroom	ND - Open - No action required
Monday, November 2, 2020	Bancroft Building		BF - 4th Floor Water Fountain	ND - Open - No action required
Thursday, August 26, 2021	Bancroft Building		BF - 4th Floor Women's Washroom	ND - Open - No action required
Thursday, August 26, 2021	Bancroft Building		BF - Basement Women's Washroom	ND - Open - No action required
Wednesday, November 25, 2020	Banting Institute		BI - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, November 25, 2020	Banting Institute		BI - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 25, 2020	Banting Institute		BI - Water Fountain Near BI 104	5.3 - Open - No action required
Tuesday, January 19, 2021	Bloor street West-371	FE135	FE - 1st Floor Kitchen Room 135	ND - Open - No action required
Monday, March 15, 2021	Bloor street West-371	FE135	FE - 1st Floor Kitchen Room 135	ND - Open - No action required
Tuesday, January 19, 2021	Bloor street West-371	FE226	FE - 2nd Floor Accessible Washroom Room 226	ND - Open - No action required
Tuesday, January 19, 2021	Bloor street West-371	FE322	FE - 3rd Floor Lab Sink Room 322	20 - Open - Normal operations with preventive maintenance
Monday, March 15, 2021	Bloor street West-371	FE322	FE - 3rd Floor Lab Sink Room 322	ND - Open - No action required
Tuesday, January 19, 2021	Bloor street West-371	FE21A	FE - Basement Men's Washroom Room 21A	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library		LW - 1st Floor "stacks" Washroom Sink	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP247	LW - 2nd Floor All-Gender Washroom Sink	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP249	LW - 2nd Floor All-Gender Washroom Sink	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP231	LW - 2nd Floor Kitchen Sink	ND - Open - No action required
Tuesday, September 22, 2020	Borden Building North	NB104A	NB - 1st Floor Accessible Washroom	ND - Open - No action required
Thursday, September 30, 2021	Borden Building North	NB104A	NB - 1st Floor Accessible Washroom	ND - Open - No action required
Thursday, September 30, 2021	Borden Building North	NB216A	NB - 2nd Floor Accessible Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Borden Building North		NB - 2nd Floor Kitchen	ND - Open - No action required
Thursday, September 30, 2021	Borden Building North	NB210	NB - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Borden Building North		NB - 3rd Floor Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South		SB - 1st Floor Kitchen Room 101	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB209	SB - 2nd Floor Office Kitchenette	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South		SB - 2nd Floor Women's Washroom Room 201B	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB201	SB - 2nd Floor Women's Washroom Shower	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South		SB - 3rd Floor All-Gender Washroom Room 313	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB313	SB - 3rd Floor All-Gender Washroom Room 313	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South		SB - 3rd Floor Men's Washroom Room 308A	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB308A	SB - 3rd Floor Men's Washroom Room 308A	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	44 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	47 - Open - Normal operations with preventive maintenance
Thursday, September 17, 2020	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	95 - Open - Normal operations with preventive maintenance
Monday, September 21, 2020	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	9.1 - Open - No action required
Friday, September 25, 2020	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	ND - Open - No action required
Friday, October 2, 2020	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	ND - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL116	NL - 1st Floor Accessible Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	2.6 - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	7.5 - Open - No action required
Thursday, September 9, 2021	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	4 - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Eyewash	ND - Open - No action required
Friday, September 11, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	410 - Closed - Isolation point of use, remediation required
Tuesday, September 15, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	32 - Open - Normal operations with preventive maintenance
Friday, September 18, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	8.5 - Open - No action required
Thursday, October 15, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	15 - Open - Normal operations with preventive maintenance
Thursday, May 6, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	ND - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	1.8 - Open - No action required
Thursday, September 9, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	ND - Open - No action required
Friday, September 18, 2020	C. David Naylor Building	NL221	NL - 2nd Floor Research Kitchen Lab	5.4 - Open - No action required
Thursday, September 9, 2021	C. David Naylor Building	NL221	NL - 2nd Floor Research Kitchen Lab	ND - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL324	NL - 3rd Floor Accessible Washroom	34 - Open - Normal operations with preventive maintenance
Monday, September 21, 2020	C. David Naylor Building	NL324	NL - 3rd Floor Accessible Washroom	11 - Open - Normal operations with preventive maintenance
Thursday, May 6, 2021	C. David Naylor Building	NL324	NL - 3rd Floor Accessible Washroom	ND - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building		NL - 3rd Floor Kitchen	3.3 - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL326A	NL - 3rd Floor Men's Washroom	ND - Open - No action required
Friday, September 11, 2020	C. David Naylor Building		NL - Basement Accessible Washroom	20 - Open - Normal operations with preventive maintenance
Sunday, September 13, 2020	C. David Naylor Building		NL - Basement Accessible Washroom	37 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building		NL - Basement Accessible Washroom	6 - Open - No action required
Friday, October 2, 2020	C. David Naylor Building		NL - Basement Accessible Washroom	4.7 - Open - No action required
Thursday, May 6, 2021	C. David Naylor Building		NL - Basement Accessible Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL11	NL - Basement Kitchen	5.8 - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL11	NL - Basement Kitchen	3.6 - Open - No action required
Thursday, May 6, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	ND - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	36 - Open - Normal operations with preventive maintenance
Thursday, September 9, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	52 - Open - Normal operations with preventive maintenance
Thursday, September 23, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL5V	NL - Basement Women's Washroom	12 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building	NL5V	NL - Basement Women's Washroom	6.3 - Open - No action required
Thursday, October 15, 2020	C. David Naylor Building	NL5V	NL - Basement Women's Washroom	4.3 - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL5V	NL - Basement Women's Washroom	ND - Open - No action required
Friday, September 11, 2020	C. David Naylor Building	NL109	NL - Kitchen	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL5A	NL - Men's Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building		NL - Water Fountain in the Basement	ND - Open - No action required
Wednesday, October 28, 2020	Canadiana GALLERY		CG - 1st Floor Washroom	4 - Open - No action required
Wednesday, December 9, 2020	Canadiana GALLERY		CG - 1st Floor Washroom	26 - Open - Normal operations with preventive maintenance
Thursday, January 28, 2021	Canadiana GALLERY		CG - 1st Floor Washroom	ND - Open - No action required
Wednesday, February 17, 2021	Canadiana GALLERY		CG - 1st Floor Washroom	ND - Open - No action required
Thursday, January 28, 2021	Canadiana GALLERY		CG - Basement Kitchen	7.6 - Open - No action required
Wednesday, February 17, 2021	Canadiana GALLERY		CG - Basement Kitchen	ND - Open - No action required
Wednesday, February 17, 2021	Canadiana GALLERY		CG - Basement Men's Washroom	ND - Open - No action required
Thursday, January 28, 2021	Canadiana GALLERY		CG - Basement Water Fountain	ND - Open - No action required
Wednesday, October 28, 2020	Canadiana GALLERY		CG - Basement Women's Washroom	35 - Open - Normal operations with preventive maintenance
Wednesday, December 9, 2020	Canadiana GALLERY		CG - Basement Women's Washroom	19 - Open - Normal operations with preventive maintenance
Thursday, January 28, 2021	Canadiana GALLERY		CG - Basement Women's Washroom	22 - Open - Normal operations with preventive maintenance
Wednesday, February 17, 2021	Canadiana GALLERY		CG - Basement Women's Washroom	6.4 - Open - No action required
Wednesday, October 28, 2020	Canadiana GALLERY	CG200	CG - Kitchen (2nd Floor)	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - 2nd Floor Shower	160 - Closed - Isolation point of use, remediation required
Tuesday, July 27, 2021	Central Steam Plant		ST - 2nd Floor Shower	ND - Open - No action required
Wednesday, September 15, 2021	Central Steam Plant		ST - 2nd Floor Shower	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - 2nd Floor Washroom	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - Chemical room	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - Lunchroom sink	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)		RW - 1st Floor Men's Washroom	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)		RW - 1st Floor Women's Washroom	ND - Open - No action required



Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)		RW - 2nd Floor Accessible Washroom (Right of Water Fountain)	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)	RW278	RW - 2nd Floor Kitchen Sink	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-30	1424	C1 - 14th Floor Kitchen	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-30	1424	C1 - 14th Floor Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-30	2018	C1 - 20th Floor Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-30	425	C1 - 4th Floor Washroom	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-35	1114	C2 - 11th Floor Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-35	1507	C2 - 15th Floor Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-35	706	C2 - 7th Floor Kitchen	ND - Open - No action required
Thursday, March 11, 2021	Charles st. West-35	706	C2 - 7th Floor Washroom	ND - Open - No action required
Friday, May 28, 2021	Chestnut Residence and Conference Centre	CN1025	CN - 10th Floor Washroom Sink	ND - Open - No action required
Friday, May 28, 2021	Chestnut Residence and Conference Centre	CN1643	CN - 16th Floor Washroom Sink	ND - Open - No action required
Friday, May 28, 2021	Chestnut Residence and Conference Centre	CN2428	CN - 24th Floor Washroom Shower Spout (Tap)	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building		BN - 1st Floor Pool All-Gender Washroom Near BN107D	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building		BN - 1st Floor Pool Shower Near BN107D	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building	BN107B	BN - 1st Floor Staff Shower	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN107B	BN - 1st Floor Staff Shower	8 - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN224	BN - 2nd Floor All-Gender Washroom	16 - Open - Normal operations with preventive maintenance
Friday, October 8, 2021	Clara Benson Building	BN224	BN - 2nd Floor All-Gender Washroom	23 - Open - Normal operations with preventive maintenance
Monday, January 18, 2021	Clara Benson Building		BN - 2nd Floor Women's Washroom	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN316	BN - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building		BN137 - All-Gender Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Claude T. Bissell Building	109	BL - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Claude T. Bissell Building	226	BL - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, September 16, 2021	Claude T. Bissell Building	BL321	BL - 3rd Floor Kitchen	ND - Open - No action required
Thursday, September 16, 2021	Claude T. Bissell Building	BL407A	BL - 4th Floor Staff Washroom	ND - Open - No action required
Thursday, September 16, 2021	Claude T. Bissell Building	BL684	BL - 6th Floor Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Claude T. Bissell Building	729	BL - 7th Floor Kitchen	ND - Open - No action required
Wednesday, January 20, 2021	College street-229		CZ - 1st Floor Men's Washroom	ND - Open - No action required
Thursday, December 17, 2020	College street-229		CZ - 2nd Floor Kitchen	ND - Open - No action required
Thursday, December 17, 2020	College street-229		CZ - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, December 17, 2020	College street-229		CZ - 2nd Floor Women's Washroom	5.6 - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, January 20, 2021	College street-229		CZ - 3rd Floor Kitchen	ND - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 5th Floor Kitchen	ND - Open - No action required
Wednesday, January 20, 2021	College street-229		CZ - 5th Floor Staff Men's Washroom	ND - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 5th Floor Staff Women's Washroom	ND - Open - No action required
Thursday, November 26, 2020	College street-88		ZC - 1st Floor Kitchen	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC110	ZC - 1st Floor Men's Washroom	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC106	ZC - 1st Floor Office Kitchennette	ND - Open - No action required
Thursday, November 26, 2020	College street-88	ZC105	ZC - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, November 26, 2020	College street-88	ZC203	ZC - 2nd Floor Kitchen	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC203	ZC - 2nd Floor Kitchen	ND - Open - No action required
Thursday, November 26, 2020	College street-88	ZC210A	ZC - 2nd Floor Men's Washroom	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC211A	ZC - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX125A	CX - 1st Floor Kitchen	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX226	CX - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX203	CX - 2nd Floor Janitors Closet	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX224A	CX - 2nd Floor Kitchen	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX6	CX - Basement Kitchen	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX13	CX - Basement Men's Washroom	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX15	CX - Basement Women's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX15	CX - Basement Women's Washroom	ND - Open - No action required
Wednesday, August 25, 2021	Convocation Hall		CH - 1st Floor Kitchen Near Presidential Board Rooms	ND - Open - No action required
Wednesday, August 25, 2021	Convocation Hall		CH - 1st Floor Men's Washroom	ND - Open - No action required
Friday, October 2, 2020	Convocation Hall		CH - 1st Floor Women's Washroom	ND - Open - No action required
Friday, October 2, 2020	Convocation Hall		CH - 2nd Floor Kitchen Near president's Office	ND - Open - No action required
Wednesday, August 25, 2021	Convocation Hall		CH - 2nd Floor Staff Kitchen near CH250	ND - Open - No action required
Friday, October 2, 2020	Convocation Hall		CH - All-Gender Washroom	ND - Open - No action required
Tuesday, October 13, 2020	Cumberland House	CU107A	CU - 1st Floor Accessible Washroom	11 - Open - Normal operations with preventive maintenance
Monday, June 7, 2021	Cumberland House	CU107A	CU - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, October 25, 2021	Cumberland House	CU107A	CU - 1st Floor Accessible Washroom	ND - Open - No action required
Tuesday, October 13, 2020	Cumberland House	CU105	CU - 1st Floor Women's Washroom	8.3 - Open - No action required
Monday, June 7, 2021	Cumberland House	CU105	CU - 1st Floor Women's Washroom	ND - Open - No action required
Monday, October 25, 2021	Cumberland House	CU105	CU - 1st Floor Women's Washroom	ND - Open - No action required
Monday, October 25, 2021	Cumberland House	CU251	CU - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, October 13, 2020	Cumberland House		CU - Basement Men's Washroom	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT179	PT - 1st Floor Office Kitchen	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building		PT - 2nd Floor Water Fountain Near PT263	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT379	PT - 3rd Floor Accessible Washroom	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT392	PT - 3rd Floor Electrical Engineering Graduate Office Kitchennette	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT474	PT - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT474	PT - 4th Floor Women's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT67	PT - Basement Lab Sink	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT77	PT - Basement Research Lab	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building	DA113	DA - 1st Floor Men's Washroom	ND - Open - No action required
Monday, December 7, 2020	Daniels Building	DA198	DA - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building		DA - 2nd Floor Kitchennette Near DA200	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building		DA - 2nd Floor Kitchennette Near DA250	ND - Open - No action required
Monday, December 7, 2020	Daniels Building		DA - 2nd Floor Student Lounge Kitchen	ND - Open - No action required
Monday, December 7, 2020	Daniels Building	DA332A	DA - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building	DN180V	DN - 1st Floor Men's Washroom	69 - Open - Normal operations with preventive maintenance
Monday, September 28, 2020	Dentistry Building	DN180V	DN - 1st Floor Men's Washroom	39 - Open - Normal operations with preventive maintenance
Friday, October 2, 2020	Dentistry Building	DN180V	DN - 1st Floor Men's Washroom	10 - Open - Normal operations with preventive maintenance
Tuesday, November 24, 2020	Dentistry Building	DN180V	DN - 1st Floor Men's Washroom	23 - Open - Normal operations with preventive maintenance
Wednesday, January 6, 2021	Dentistry Building	DN180V	DN - 1st Floor Men's Washroom	ND - Open - No action required
Friday, March 19, 2021	Dentistry Building	DN180V	DN - 1st Floor Men's Washroom	5.9 - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	71 - Open - Normal operations with preventive maintenance
Wednesday, January 6, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	25 - Open - Normal operations with preventive maintenance
Tuesday, January 12, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	12 - Open - Normal operations with preventive maintenance
Tuesday, January 26, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	16 - Open - Normal operations with preventive maintenance
Friday, March 19, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	7.1 - Open - No action required
Monday, March 29, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	7.6 - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN263V	DN - 2nd Floor Men's Washroom	170 - Closed - Isolation point of use, remediation required
Wednesday, January 6, 2021	Dentistry Building	DN263V	DN - 2nd Floor Men's Washroom	ND - Open - No action required
Monday, January 11, 2021	Dentistry Building	DN263V	DN - 2nd Floor Men's Washroom	9 - Open - No action required
Tuesday, January 26, 2021	Dentistry Building	DN263V	DN - 2nd Floor Men's Washroom	36 - Open - Normal operations with preventive maintenance
Friday, March 19, 2021	Dentistry Building	DN263V	DN - 2nd Floor Men's Washroom	30 - Open - Normal operations with preventive maintenance
Monday, March 29, 2021	Dentistry Building	DN263V	DN - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN254V	DN - 2nd Floor Women's Washroom	3.8 - Open - No action required
Wednesday, January 6, 2021	Dentistry Building	DN254V	DN - 2nd Floor Women's Washroom	ND - Open - No action required
Monday, January 11, 2021	Dentistry Building	DN254V	DN - 2nd Floor Women's Washroom	ND - Open - No action required
Monday, September 28, 2020	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	18 - Open - Normal operations with preventive maintenance
Friday, October 2, 2020	Dentistry Building	DN357	DN - 3rd Floor men's Washroom	10 - Open - Normal operations with preventive maintenance
Tuesday, November 24, 2020	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	3.4 - Open - No action required
Monday, January 11, 2021	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	63 - Open - Normal operations with preventive maintenance
Tuesday, January 26, 2021	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	6.8 - Open - No action required
Friday, March 19, 2021	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, January 26, 2021	Dentistry Building		DN - 4th Floor All-Gender Accessible Across Kitchen	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building		DN - 4th Floor Kitchen	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building		DN - 4TH Floor Lab Sink	ND - Open - No action required
Monday, September 28, 2020	Dentistry Building		DN - 5th Floor Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building	DN410	DN - Lap Tap	ND - Open - No action required
Monday, September 28, 2020	Dentistry Building		DN - Shower Inside Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building	DN228	DN - Water Fountain in DN228	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN344	DN - Women's Washroom	1 - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child study	WR237	WR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, April 21, 2021	Dr. Eric Jackman Institute of Child study	WR237	WR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child study	WR330	WR - 3rd Floor All-Gender Washroom	30 - Open - Normal operations with preventive maintenance
Thursday, April 15, 2021	Dr. Eric Jackman Institute of Child study	WR330	WR - 3rd Floor All-Gender Washroom	49 - Open - Normal operations with preventive maintenance
Wednesday, April 21, 2021	Dr. Eric Jackman Institute of Child study	WR330	WR - 3rd Floor All-Gender Washroom	1.5 - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child study	WR124	WR - All-Gender Washroom	ND - Open - No action required
Thursday, April 15, 2021	Dr. Eric Jackman Institute of Child study	WR124	WR - All-Gender Washroom	ND - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child study	WR76	WR - Basement Kitchen	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		EC - 1st Floor Accessible Washroom (Adult)	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		EC - 1st Floor Kitchen (Food Prep)	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		EC - 2nd Floor Kitchen	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		EC - 3rd Floor Washroom	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	South (ES1067)	ES - 1st Floor Lab Sink	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	North (ES1024)	ES - 1st Floor Lab Sink (right)	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	South	ES - 1st Floor Water Fountain	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	North (RM1033)	ES - 1st Women's Washroom	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	North (ES2056)	ES - 2nd Floor Lab Sink (Left)	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	North (RM2054)	ES - 2nd Floor Student Lounge Kitchen	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	South	ES - 2nd Floor Water Fountain Near ES2117	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	North (ES3042)	ES - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	South (RM3119)	ES - 3RD Floor Student Lounge Kitchen	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	North	ES - 3RD Floor Water Fountain Beside Room 3062	ND - Open - No action required



Tuesday, November 3, 2020	Earth Sciences Centre	North (RM4076)	ES - 4TH Floor Lab Sink	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	South (E54107)	ES - 4th Floor Lounge Kitchenette	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	South (RM4105)	ES - 4TH Floor Men's Washroom	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	South (ESB172)	ES - Basement Accessible Washroom	5.6 - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	North (ESB111)	ES - Basement Senescence Room Sink	ND - Open - No action required
Thursday, November 26, 2020	Edward Johnson Building	EJ106	EJ - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, November 26, 2020	Edward Johnson Building		EJ - 2nd Floor Fountain Near EJ230	ND - Open - No action required
Tuesday, October 5, 2021	Edward Johnson Building	EJ229	EJ - 2nd Floor Men's Staff Washroom	ND - Open - No action required
Thursday, November 26, 2020	Edward Johnson Building		EJ - Basement Men's Washroom	ND - Open - No action required
Tuesday, October 5, 2021	Edward Johnson Building	EJ88	EJ - Basement Sink Inside Instrument Room	ND - Open - No action required
Tuesday, October 5, 2021	Edward Johnson Building		EJ - Subbasement Water Fountain Near EJ73A	ND - Open - No action required
Wednesday, November 4, 2020	Electrometallurgy Lab		EL - Washroom	ND - Open - No action required
Monday, October 25, 2021	Electrometallurgy Lab		EL - Washroom	ND - Open - No action required
Thursday, February 18, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	18 - Open - Normal operations with preventive maintenance
Monday, April 19, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	16 - Open - Normal operations with preventive maintenance
Tuesday, May 4, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, May 18, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, July 29, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, October 29, 2020	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	190 - Closed - Isolation point of use, remediation required
Thursday, February 18, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	340 - Closed - Isolation point of use, remediation required
Monday, April 19, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	38 - Open - Normal operations with preventive maintenance
Tuesday, May 4, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	63 - Open - Normal operations with preventive maintenance
Tuesday, May 18, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, July 7, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	82 - Open - Normal operations with preventive maintenance
Thursday, July 29, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	20 - Open - Normal operations with preventive maintenance
Monday, August 9, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	7.2 - Open - No action required
Thursday, October 29, 2020	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	26 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	22 - Open - Normal operations with preventive maintenance
Monday, April 19, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	97 - Open - Normal operations with preventive maintenance
Tuesday, May 4, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	180 - Closed - Isolation point of use, remediation required
Tuesday, May 18, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	260 - Closed - Isolation point of use, remediation required
Wednesday, July 7, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	770 - Closed - Isolation point of use, remediation required
Thursday, July 29, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	220 - Closed - Isolation point of use, remediation required
Monday, August 9, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	24 - Open - Normal operations with preventive maintenance
Thursday, October 29, 2020	Engineering Annex	EA107	EA - Kitchen Inside EA107	11 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	Engineering Annex	EA107	EA - Kitchen Inside EA107	ND - Open - No action required
Tuesday, May 18, 2021	Engineering Annex	EA107	EA - Kitchen Inside EA107	ND - Open - No action required
Thursday, October 29, 2020	Engineering Annex		EA - Water Fountain Near EA205	ND - Open - No action required
Tuesday, January 12, 2021	Enrolment Services		AD - 1st Floor Kitchen	ND - Open - No action required
Tuesday, January 12, 2021	Enrolment Services		AD - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Enrolment Services	AD217	AD - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Enrolment Services	AD319	AD - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, January 12, 2021	Enrolment Services		AD - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Enrolment Services	AD419K	AD - 4th Floor Kitchen	ND - Open - No action required
Thursday, November 5, 2020	Exam Centre		EX - 1st Floor All-Gender Washroom	ND - Open - No action required
Friday, October 22, 2021	Exam Centre	EX234	EX - 2nd Floor Men's Accessible Washroom	ND - Open - No action required
Friday, October 22, 2021	Exam Centre	EX388	EX - 3rd Floor Kitchen	ND - Open - No action required
Thursday, November 5, 2020	Exam Centre		EX - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, November 5, 2020	Exam Centre		EX - 4th Floor Kitchen	ND - Open - No action required
Friday, October 22, 2021	Exam Centre	EX451	EX - 4th Floor Men's Accessible Washroom	19 - Open - Normal operations with preventive maintenance
Wednesday, October 27, 2021	Exam Centre	EX451	EX - 4th Floor Men's Accessible Washroom	22 - Open - Normal operations with preventive maintenance
Wednesday, October 27, 2021	Exam Centre	EX451	EX - 4th Floor Men's Accessible Washroom Sink inside Accessible Stall	14 - Open - Normal operations with preventive maintenance
Wednesday, October 27, 2021	Exam Centre	EX453	EX - 4th Floor Women's Accessible Washroom	8.3 - Open - No action required
Thursday, December 3, 2020	Factor-Inwentash Faculty of Social Work		SK - 1st Floor Water Fountain	ND - Open - No action required
Thursday, October 14, 2021	Factor-Inwentash Faculty of Social Work	SK237	SK - 2nd Floor Men's Washroom	3.1 - Open - No action required
Thursday, December 3, 2020	Factor-Inwentash Faculty of Social Work		SK - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, October 14, 2021	Factor-Inwentash Faculty of Social Work	SK320A	SK - 3rd Floor Kitchenette inside Lounge	ND - Open - No action required
Thursday, October 14, 2021	Factor-Inwentash Faculty of Social Work	SK537K	SK - 5th Floor Water Fountain Near SK506	ND - Open - No action required
Thursday, December 3, 2020	Factor-Inwentash Faculty of Social Work		SK - 7th Floor Women's Washroom	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club		FC - 1st Floor Accessible Washroom	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC103	FC - 1st Floor Bar Sink by Accessible Washroom	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC107	FC - 1st Floor Dining Hall Bar Sink	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club		FC - 1st Floor Kitchen	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club		FC - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC14	FC - Basement Men's Changing Room	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club		FC - Basement Pub Tap	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club		FC - Basement Women's Washroom	ND - Open - No action required
Tuesday, April 20, 2021	Faculty of Law	J222	LW - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, April 20, 2021	Faculty of Law	J317	LW - 2nd Floor Kitchenette	ND - Open - No action required
Tuesday, April 20, 2021	Faculty of Law	J433	LW - 3rd Floor All-Gender Accessible Washroom	ND - Open - No action required
Monday, December 14, 2020	Faculty of Law	J102	LW - Basement Men's Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall	FA107A	FH - 1st Floor Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall		FH - 2nd Floor Washroom	5.6 - Open - No action required
Friday, June 25, 2021	Falconer Hall		FH - 2nd Floor Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall		FH - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall	FA10	FH - Basement Female Washroom	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building		LG - 1st Floor Washroom	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG207	LG - 2nd Floor Shower	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building		LG - 2nd Floor Washroom - Family Law Division Office	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG318	LG - 3rd Floor Shower	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG314	LG - 3rd Floor Sink	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building	LG317	LG - 3rd Floor Washroom - Criminal Law Office	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building		LG - Basement Kitchen	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG18	LG - Basement Kitchen	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	FI106	FI - 1st Floor Kitchen	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	FI157	FI - 1st Floor Women's Washroom	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	FI204	FI - 2nd Floor Kitchen Sink	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science		FI - 2nd Floor Water Fountain Near 206	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	FI305	FI - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	FI347	FI - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	FI447	FI - 4th Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	FI447	FI - 4th Floor All-Gender Washroom	ND - Open - No action required
Monday, December 14, 2020	Flavelle House	FL222	FL - 2nd Floor Kitchen Sink	ND - Open - No action required
Wednesday, June 2, 2021	Flavelle House	FL222	FL - 2nd Floor Kitchen Sink	6.4 - Open - No action required
Thursday, July 22, 2021	Flavelle House	FL222	FL - 2nd Floor Kitchen Sink	ND - Open - No action required
Monday, December 14, 2020	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	80 - Open - Normal operations with preventive maintenance
Monday, March 15, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	40 - Open - Normal operations with preventive maintenance
Tuesday, April 20, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	26 - Open - Normal operations with preventive maintenance
Wednesday, June 2, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	170 - Closed - Isolation point of use, remediation required
Monday, June 28, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	290 - Closed - Isolation point of use, remediation required
Thursday, July 22, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, March 15, 2021	Flavelle House	FL134	LW - 1st Floor Kitchen	ND - Open - No action required
Thursday, November 12, 2020	Gage Building	GA101	GA - 1st Floor Accessible Washroom	30 - Open - Normal operations with preventive maintenance
Monday, January 25, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	8900 - Closed - Isolation point of use, remediation required
Tuesday, March 2, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	48 - Open - Normal operations with preventive maintenance
Monday, March 8, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	74 - Open - Normal operations with preventive maintenance
Monday, March 22, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	13 - Open - Normal operations with preventive maintenance
Monday, March 29, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Wednesday, April 7, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, April 19, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, April 26, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, May 17, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	5.6 - Open - No action required
Tuesday, May 25, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, May 31, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	7.8 - Open - No action required
Tuesday, June 8, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	24 - Open - Normal operations with preventive maintenance
Monday, June 14, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, June 21, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Tuesday, June 29, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	8.6 - Open - No action required
Tuesday, July 6, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Tuesday, July 13, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	2.1 - Open - No action required
Tuesday, July 20, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, July 26, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Friday, August 6, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Wednesday, October 14, 2020	Gage Building	GA104	GA - 1st Floor Kitchen	63 - Open - Normal operations with preventive maintenance
Thursday, November 12, 2020	Gage Building	GA104	GA - 1st Floor Kitchen	24 - Open - Normal operations with preventive maintenance
Monday, January 25, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	6.1 - Open - No action required
Monday, March 8, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	23 - Open - Normal operations with preventive maintenance
Monday, March 22, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	49 - Open - Normal operations with preventive maintenance
Monday, March 29, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	3.6 - Open - No action required
Wednesday, April 7, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	7.1 - Open - No action required
Monday, April 19, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	1 - Open - No action required
Monday, April 26, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	5.6 - Open - No action required
Monday, May 3, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	1.5 - Open - No action required
Tuesday, May 11, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	17 - Open - Normal operations with preventive maintenance
Monday, May 17, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	8.7 - Open - No action required
Tuesday, May 25, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	32 - Open - Normal operations with preventive maintenance
Monday, May 31, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	3 - Open - No action required
Tuesday, June 8, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	10 - Open - Normal operations with preventive maintenance
Monday, June 14, 2021	Gage Building	GA104	GA - 1st Floor Kitchen	5.9 - Open - No action required







Tuesday, July 13, 2021	Gage Building	GAB12	GA - Basement Lab Sink	ND - Open - No action required
Monday, September 14, 2020	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	57 - Open - Normal operations with preventive maintenance
Friday, September 18, 2020	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	18 - Open - Normal operations with preventive maintenance
Monday, September 21, 2020	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	11 - Open - Normal operations with preventive maintenance
Tuesday, October 13, 2020	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	17 - Open - Normal operations with preventive maintenance
Monday, October 19, 2020	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	7.6 - Open - No action required
Tuesday, April 27, 2021	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	ND - Open - No action required
Friday, June 11, 2021	Galbraith Building	GB111A	GB - 1st Floor Men's Washroom	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB114	GB - 1st Floor Women's Washroom	65 - Open - Normal operations with preventive maintenance
Monday, September 21, 2020	Galbraith Building	GB114	GB - 1st Floor Women's Washroom	2.5 - Open - No action required
Tuesday, October 13, 2020	Galbraith Building	GB114	GB - 1st Floor Women's Washroom	ND - Open - No action required
Friday, June 11, 2021	Galbraith Building	GB114	GB - 1st Floor Women's Washroom	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB417B	GB - 4th Floor Lab Tap on the Right	2.2 - Open - No action required
Friday, June 11, 2021	Galbraith Building	GB417B	GB - 4th Floor Lab Tap on the Right	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB10	GB - Basement Lab Sink	430 - Closed - Isolation point of use, remediation required
Monday, September 21, 2020	Galbraith Building	GB10	GB - Basement Lab Sink	340 - Closed - Isolation point of use, remediation required
Tuesday, October 13, 2020	Galbraith Building	GB10	GB - Basement Lab Sink	260 - Closed - Isolation point of use, remediation required
Monday, October 19, 2020	Galbraith Building	GB10	GB - Basement Lab Sink	170 - Closed - Isolation point of use, remediation required
Tuesday, April 27, 2021	Galbraith Building	GB10	GB - Basement Lab Sink	350 - Closed - Isolation point of use, remediation required
Monday, May 31, 2021	Galbraith Building	GB10	GB - Basement Lab Sink	ND - Open - No action required
Friday, June 11, 2021	Galbraith Building	GB10	GB - Basement Lab Sink	4.5 - Open - No action required
Tuesday, June 15, 2021	Galbraith Building	GB10	GB - Basement Lab Sink	ND - Open - No action required
Tuesday, June 15, 2021	Galbraith Building	GB10	GB - Basement Lab Sink (Cold Water)	ND - Open - No action required
Monday, September 14, 2020	Galbraith Building	GB18	GB - Men's Washroom	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB410A	GB - Men's Washroom	3.1 - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB111	GB - Men's Washroom	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB18	GB - Men's Washroom	ND - Open - No action required
Tuesday, October 13, 2020	Galbraith Building	GB410A	GB - Men's Washroom	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB252/253	GB - Sink between GB252 and GB253	ND - Open - No action required
Monday, September 14, 2020	Galbraith Building	GB208	GB - Water Fountain Near GB208	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB210	GB - Women's Washroom	ND - Open - No action required
Monday, October 19, 2020	Galbraith Building	GB210	GB - Women's Washroom	ND - Open - No action required
Monday, September 14, 2020	Galbraith Building	GB308A	GB308A - Lab Tap	ND - Open - No action required
Friday, September 18, 2020	Galbraith Building	GB316A	GB316A - Lab Tap	1.6 - Open - No action required
Monday, October 19, 2020	Galbraith Building	GB316A	GB316A - Lab Tap	ND - Open - No action required
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM1373	SM - 1st Floor Kitchen Room 1373	ND - Open - No action required
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM152	SM - 1st Men's Washroom	4 - Open - No action required
Thursday, October 8, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM2335	SM - 2nd Floor Staff Kitchen	19 - Open - Normal operations with preventive maintenance
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM2335	SM - 2nd Floor Staff Kitchen	7.6 - Open - No action required
Monday, December 7, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM2335	SM - 2nd Floor Staff Kitchen	ND - Open - No action required
Tuesday, June 15, 2021	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM2335	SM - 2nd Floor Staff Kitchen	12 - Open - Normal operations with preventive maintenance
Friday, June 25, 2021	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM2335	SM - 2nd Floor Staff Kitchen	5 - Open - No action required
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM2363	SM - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SMB103	SM - Basement Men's Washroom	ND - Open - No action required
Thursday, October 8, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM13V	SM - Basement Women's Washroom	23 - Open - Normal operations with preventive maintenance
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SMB160	SM - Basement Women's Washroom	10 - Open - Normal operations with preventive maintenance
Tuesday, October 20, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM13V	SM - Basement Women's Washroom	ND - Open - No action required
Monday, December 7, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SMB160	SM - Basement Women's Washroom	ND - Open - No action required
Tuesday, June 15, 2021	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM13V	SM - Basement Women's Washroom	33 - Open - Normal operations with preventive maintenance
Tuesday, June 15, 2021	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SMB160	SM - Basement Women's Washroom	ND - Open - No action required
Friday, June 25, 2021	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg	SM13V	SM - Basement Women's Washroom	4.4 - Open - No action required
Thursday, October 8, 2020	Gerstein Science Information Centre in the Sigmund Samuel Library Bldg		SM - Water Fountain Beside Room 152	ND - Open - No action required
Friday, August 13, 2021	Goldring Centre for High Performance Sport	GOB210A	GO - 2nd Basement Men's Washroom Shower	ND - Open - No action required
Monday, September 7, 2020	Goldring Centre for High Performance Sport		GO - 2nd Floor Men's Change Room	ND - Open - No action required
Monday, September 7, 2020	Goldring Centre for High Performance Sport		GO - 2nd Floor Women's Change Room	ND - Open - No action required
Friday, August 13, 2021	Goldring Centre for High Performance Sport	GO462	GO - 4th Floor Consult Room	ND - Open - No action required
Friday, June 4, 2021	Grad Room		GD - Basement Kitchen Sink	ND - Open - No action required
Friday, June 4, 2021	Grad Room		GD - Basement Men's Washroom Sink	ND - Open - No action required
Friday, June 4, 2021	Grad Room		GD - Basement Women's Washroom Sink	ND - Open - No action required
Friday, June 4, 2021	Grad Room		GD - First Floor All-Gender Washroom Sink	ND - Open - No action required
Thursday, April 22, 2021	Graduate House	140	GD - 1st Floor Washroom	ND - Open - No action required
Thursday, April 22, 2021	Graduate House	318	GD - 3rd Floor Kitchen	ND - Open - No action required
Thursday, April 22, 2021	Graduate House	514	GD - 5th Floor Shower	ND - Open - No action required
Thursday, April 22, 2021	Graduate House	24	GD - Basement Shower	ND - Open - No action required
Monday, November 9, 2020	Graduate Students' Union	GU102A	GU - 1st Floor Pub Bar Sink	ND - Open - No action required
Monday, September 20, 2021	Graduate Students' Union	GU102A	GU - 1st Floor Pub Bar Sink	ND - Open - No action required
Monday, September 20, 2021	Graduate Students' Union	GU203	GU - 2nd Floor Kitchen	ND - Open - No action required
Monday, November 9, 2020	Graduate Students' Union	GU201	GU - 2nd Floor Washroom	ND - Open - No action required
Monday, November 9, 2020	Graduate Students' Union	GU6	GU - Basement Men's Washroom	ND - Open - No action required
Monday, September 20, 2021	Graduate Students' Union	GU7	GU - Basement Women's Washroom Shower	ND - Open - No action required
Monday, July 5, 2021	Hart House	HH107	HH - 1st Floor Hair Salon Hair Washer	ND - Open - No action required
Friday, July 16, 2021	Hart House	HH2017B	HH - 2nd Floor IT Offices Shower	ND - Open - No action required
Thursday, June 10, 2021	Hart House	HH2009	HH - 2nd Floor Kitchen Potwasher	10 - Open - Normal operations with preventive maintenance
Monday, July 5, 2021	Hart House	HH2009	HH - 2nd Floor Kitchen Potwasher	29 - Open - Normal operations with preventive maintenance
Friday, July 16, 2021	Hart House	HH2009	HH - 2nd Floor Kitchen Potwasher	1300 - Closed - Isolation point of use, remediation required
Friday, September 10, 2021	Hart House	HH2009	HH - 2nd Floor Kitchen Potwasher	150 - Closed - Isolation point of use, remediation required
Thursday, June 10, 2021	Hart House	HH2020	HH - 2nd Floor Kitchen Sink (Left)	460 - Closed - Isolation point of use, remediation required
Monday, July 5, 2021	Hart House	HH2020	HH - 2nd Floor Kitchen Sink (Left)	22 - Open - Normal operations with preventive maintenance
Friday, July 16, 2021	Hart House	HH2020	HH - 2nd Floor Kitchen Sink (Left)	49 - Open - Normal operations with preventive maintenance
Friday, September 10, 2021	Hart House	HH2020	HH - 2nd Floor Kitchen Sink (Left)	110 - Closed - Isolation point of use, remediation required
Thursday, June 10, 2021	Hart House	HH3016A	HH - 3rd Floor All-Gender Washroom	120 - Closed - Isolation point of use, remediation required
Monday, July 5, 2021	Hart House	HH3016A	HH - 3rd Floor All-Gender Washroom	33 - Open - Normal operations with preventive maintenance
Friday, July 16, 2021	Hart House	HH3016A	HH - 3rd Floor All-Gender Washroom	1.8 - Open - No action required
Friday, September 10, 2021	Hart House	HH3016A	HH - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, June 10, 2021	Hart House	HH134	HH - Basement Women's Shower	ND - Open - No action required
Thursday, June 10, 2021	Hart House	HH159	HH - Basement Women's Washroom Sink	ND - Open - No action required
Thursday, June 10, 2021	Hart House	HH17D	HH - Sub Basement Men's Dressing Room Shower (Left)	2.8 - Open - No action required
Monday, July 5, 2021	Hart House	HH17D	HH - Sub Basement Men's Dressing Room Shower (Left)	ND - Open - No action required
Friday, July 16, 2021	Hart House	HH17D	HH - Sub Basement Men's Dressing Room Shower (Left)	ND - Open - No action required
Friday, September 10, 2021	Hart House	HH17D	HH - Sub Basement Men's Dressing Room Shower (Left)	ND - Open - No action required
Thursday, June 10, 2021	Hart House	HH6A	HH - Sub Basement Theater Water Fountain	ND - Open - No action required
Tuesday, September 22, 2020	Haultain Building		HA - Water Fountain Near HA312	ND - Open - No action required
Wednesday, August 25, 2021	Haultain Building	HA102	HA - 1st Floor Workshop Sink	7.1 - Open - No action required
Tuesday, September 22, 2020	Haultain Building		HA - 2nd Floor Kitchen Inside HA203	5.3 - Open - No action required
Wednesday, June 23, 2021	Haultain Building		HA - 2nd Floor Kitchen Inside HA203	ND - Open - No action required
Wednesday, August 25, 2021	Haultain Building	HA205	HA - 2nd Floor Office Kitchenette	ND - Open - No action required
Wednesday, August 25, 2021	Haultain Building	HA311	HA - 3rd Floor Office Kitchenette	36 - Open - Normal operations with preventive maintenance
Tuesday, September 22, 2020	Haultain Building		HA - 3rd Floor Women's Washroom	8.5 - Open - No action required
Wednesday, June 23, 2021	Haultain Building		HA - 3rd Floor Women's Washroom	ND - Open - No action required
Wednesday, August 25, 2021	Haultain Building	HA53	HA - Basement Lab Sink	19 - Open - Normal operations with preventive maintenance
Tuesday, September 22, 2020	Haultain Building	HA102	HA - Workshop	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS172	HS - 1st Floor Simulation Lab Sink	ND - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS172	HS - 1st Floor Simulation Lab Sink	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS391V	HS - 3rd Floor Water Fountain Inside Women's Washroom	ND - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS391V	HS - 3rd Floor Water Fountain Inside Women's Washroom	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	12 - Open - Normal operations with preventive maintenance
Tuesday, December 8, 2020	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	8.5 - Open - No action required
Tuesday, April 27, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	4.4 - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	4.9 - Open - No action required
Friday, August 6, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	18 - Open - Normal operations with preventive maintenance
Wednesday, August 25, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	3.8 - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS12	HS - Basement All Gender Washroom (previously Men's Washroom)	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS12	HS - Basement Men's Washroom	ND - Open - No action required
Tuesday, December 8, 2020	Health Sciences Building	HS12	HS - Basement Men's Washroom	3.4 - Open - No action required
Tuesday, April 27, 2021	Health Sciences Building	HS12	HS - Basement Men's Washroom	ND - Open - No action required
Friday, August 13, 2021	Huron Street-215	HU2205B	HU - 2nd Floor Men's Locker Room Shower	59 - Open - Normal operations with preventive maintenance
Tuesday, August 24, 2021	Huron Street-215	HU2205B	HU - 2nd Floor Men's Locker Room Shower	ND - Open - No action required
Thursday, September 16, 2021	Huron Street-215	HU2205B	HU - 2nd Floor Men's Locker Room Shower	28 - Open - Normal operations with preventive maintenance
Friday, September 4, 2020	Huron Street-215	HU719V	HU - 7th Floor Men's Washroom	ND - Open - No action required
Friday, September 4, 2020	Huron Street-215	HU715	HU - 7th Floor Women's Washroom	ND - Open - No action required
Friday, August 13, 2021	Huron Street-215	HU929A	HU - 9th Floor Men's Washroom	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN128	IN - 1st Floor All-Gender Near IN131 (Left)	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN102	IN - 1st Floor Innis Cafe Sink (Right)	ND - Open - No action required
Tuesday, November 10, 2020	Innis College		IN - 1st Floor Water Fountain Near 131	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN203	IN - 2nd Floor All-Gender Washroom Near IN204W	ND - Open - No action required
Tuesday, November 10, 2020	Innis College		IN - 3RD Floor All-Gender Washroom Beside 317E	ND - Open - No action required
Tuesday, November 10, 2020	Innis College		IN - E WING 1st Floor Kitchen Near 131	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN130	IN - E WING 1st Floor Kitchen Near 131	ND - Open - No action required
Tuesday, November 10, 2020	Innis College		IN - W WING 1st Floor All-Gender Washroom Near Cafe	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS422	IS - Residence Suite Kitchen Sink	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS734	IS - Residence Suite Shower	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS215	IS - Residence Suite Washroom Sink	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS546	IS - Residence Suite Washroom Sink	ND - Open - No action required
Wednesday, December 16, 2020	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	330 - Closed - Isolation point of use, remediation required
Tuesday, April 27, 2021	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	490 - Closed - Isolation point of use, remediation required
Friday, October 8, 2021	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	890 - Closed - Isolation point of use, remediation required
Wednesday, December 16, 2020	J. Robert S. Prichard Alumni House		DR - 2nd Floor Kitchen	91 - Open - Normal operations with preventive maintenance
Tuesday, April 27, 2021	J. Robert S. Prichard Alumni House		DR - 2nd Floor Kitchen	28 - Open - Normal operations with preventive maintenance
Wednesday, December 16, 2020	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	310 - Closed - Isolation point of use, remediation required



Tuesday, April 27, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	150 - Closed - Isolation point of use, remediation required
Tuesday, September 21, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	95 - Open - Normal operations with preventive maintenance
Friday, October 8, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	110 - Closed - Isolation point of use, remediation required
Friday, October 29, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	417	JH- 4th Floor Kitchen	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH500W	JH- 5th Floor All-Gender Washroom Across 515	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH700M	JH- 7th Floor Men's Washroom Across 714	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH900W	JH- 9th Floor Women's Washroom Across 912	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building	RL14081	RL - 14th Floor Kitchentte	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building		RL - 1st Floor Women's Washroom Beside 1131	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building	RL2008	RL - 2nd Floor Washroom Shower	ND - Open - No action required
Thursday, September 17, 2020	John P. Roberts Library Building	4-002	RL - 4th Floor Accessible Washroom	ND - Open - No action required
Thursday, September 17, 2020	John P. Roberts Library Building	7-005	RL - 7th Floor Women's Washroom	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building		RL - 8th Floor Staff Elevator Lobby Kitchen	ND - Open - No action required
Thursday, September 17, 2020	John P. Roberts Library Building		Water Fountain Near Room 1016	ND - Open - No action required
Thursday, February 25, 2021	Koffler House		KP - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, November 17, 2021	Koffler House	KP204	KP - 2nd Floor Accessible Washroom Shower	ND - Open - No action required
Thursday, February 25, 2021	Koffler House	KP215B	KP - 2nd Floor Female Ablution	4.5 - Open - No action required
Wednesday, June 23, 2021	Koffler House	KP215B	KP - 2nd Floor Female Ablution	ND - Open - No action required
Wednesday, November 17, 2021	Koffler House	KP215A	KP - 2nd Floor Male Ablution	ND - Open - No action required
Thursday, February 25, 2021	Koffler House		KP - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, February 25, 2021	Koffler House		KP - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 17, 2021	Koffler House	KP305	KP - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, September 9, 2021	Koffler Student Services Centre	KS113W	KS - 1st Floor All-Gender Washroom inside Health & Wellness Suite 111	24 - Open - Normal operations with preventive maintenance
Wednesday, November 25, 2020	Koffler Student Services Centre		KS - 1st Floor Kitchen Inside K133K	ND - Open - No action required
Thursday, September 9, 2021	Koffler Student Services Centre	KS202W	KS - 2nd Floor All-Gender Washroom inside Student Experience (KS202)	63 - Open - Normal operations with preventive maintenance
Wednesday, November 25, 2020	Koffler Student Services Centre		KS - 2nd Floor Shower Inside K232	ND - Open - No action required
Wednesday, November 25, 2020	Koffler Student Services Centre		KS - 3rd Floor Kitchen Inside KS325	ND - Open - No action required
Thursday, September 9, 2021	Koffler Student Services Centre	KS304	KS - 3rd Floor Kitchen Near Student Life Admin	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM20B	Davenport Wing - LM - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM215	Davenport Wing - LM - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM355B	Davenport Wing - LM - 3rd Floor Office Kitchennette	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM463	Davenport Wing - LM - 4th Floor Office Kitchennette	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	Davenport Wing	LM - 1st Floor Teaching Lab Sink LM117	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM236	LM - 2nd Floor All-Gender Washroom	5.3 - Open - No action required
Tuesday, June 22, 2021	Lash Miller Chemical Laboratories	LM236	LM - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM253	LM - 2nd Floor Office Kitchennette	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	Davenport Wing	LM - 2nd Floor Women's Washroom Across LM203	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	Davenport Wing	LM - 3RD Floor MEN'S Washroom Beside 350	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM428	LM - 4th Floor Kitchen	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	Davenport Wing	LM - 4TH Floor Kitchen 458	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM411	LM - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM511	LM - 5th Floor Lab Sink	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM616	LM - 6th Floor Office Kitchennette	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM624	LM - Kitchen	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM140	LM - Lab	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building		MB - 2nd Floor Accessible Washroom	ND - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB226	MB - 2nd Floor Lounge	12 - Open - Normal operations with preventive maintenance
Thursday, October 21, 2021	Lassonde Mining Building	MB226	MB - 2nd Floor Lounge	7.4 - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB301B	MB - 3rd Floor Lab Room Inside MB301	ND - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB407B	MB - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB68	MB - Basement Graduate Office	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB52	MB - Basement Men's Washroom	8.8 - Open - No action required
Wednesday, June 23, 2021	Lassonde Mining Building	MB52	MB - Basement Men's Washroom	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB301	MB - Lab Tap	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB118	MB - Student Lounge	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB225	PB - 2nd Floor All-Gender Washroom inside Student Lounge	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB332A	PB - 3rd Floor Kitchennette Sink inside Student Study Room	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building		PB - 5th Floor Lounge	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB612	PB - 6th Floor Graduate Student Common Room	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building		PB - 6th Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB742	PB - 7th Floor Men's Washroom	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building		PB - Basement Accessible Washroom	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building	PB1243	PB - Lab Tap	ND - Open - No action required
Thursday, November 4, 2021	Lillian Massey Building	LI129	LI - 1st Floor All-Gender Washroom	ND - Open - No action required
Thursday, November 4, 2021	Lillian Massey Building	LI212	LI - 2nd Floor Accessible Washroom Shower	ND - Open - No action required
Thursday, January 21, 2021	Lillian Massey Building		LI - 2nd Floor Kitchen	ND - Open - No action required
Thursday, January 21, 2021	Lillian Massey Building		LI - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, January 21, 2021	Lillian Massey Building		LI - 3rd Floor Kitchen	ND - Open - No action required
Thursday, November 4, 2021	Lillian Massey Building	LI342	LI - 3rd Floor Men's Washroom	ND - Open - No action required
Thursday, February 4, 2021	Louis B. Stewart Observatory (UTSU)		SO - 1st Floor Kitchen	100 - Open - Normal operations with preventive maintenance
Thursday, February 4, 2021	Louis B. Stewart Observatory (UTSU)		SO - 1st Floor Washroom	32 - Open - Normal operations with preventive maintenance
Thursday, February 4, 2021	Louis B. Stewart Observatory (UTSU)		SO - Basement Washroom	21 - Open - Normal operations with preventive maintenance
Tuesday, January 19, 2021	Luella Massey studio Theatre	GM05	GM - Basement All-Gender Washroom Left	ND - Open - No action required
Tuesday, January 19, 2021	Luella Massey studio Theatre	GM04	GM - Basement All-Gender Washroom Right	ND - Open - No action required
Tuesday, August 31, 2021	Luella Massey Studio Theatre	GM07	GM - Basement Custodian Room Sink	ND - Open - No action required
Tuesday, August 31, 2021	Luella Massey Studio Theatre	GM01	GM - Basement Kitchen Sink	ND - Open - No action required
Friday, October 15, 2021	Macdonald-Mowat House	MM314	MM - 1st Floor Accessible Washroom	ND - Open - No action required
Friday, October 15, 2021	Macdonald-Mowat House	MM210	MM - 2nd Floor All-Gender Washroom	ND - Open - No action required
Friday, October 15, 2021	Macdonald-Mowat House	MM108	MM - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, October 28, 2020	Macdonald-Mowat House	MM209	MM - All-Gender Washroom	ND - Open - No action required
Wednesday, October 28, 2020	Macdonald-Mowat House	MM312	MM - All-Gender Washroom	ND - Open - No action required
Wednesday, October 28, 2020	Macdonald-Mowat House	MM106	MM - Kitchen	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	16th Floor	M2 - 16th Floor Kitchen	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	1st Floor	M2 - 1st Floor Men's Washroom Beside Elevator	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	14th Floor	M2 - Lab Hand Wash Sink in 1416K Entrance	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	15th Floor	M2 - Lab Sink 1560BB	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)		1st Floor Men's Washroom	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)	691	6th Floor SGC Room 691 Kitchen Tap	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)	708	7th Floor SGC Room 708 Lab Sink	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)		8th Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE163	GE - 1st Floor All-Gender Washroom (Left)	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE130B	GE - 1st Floor Kitchen Sink	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House		GE - 1st Floor Men's Washroom Beside 110	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House		GE - 2nd Floor All-Gender Washroom Across 252	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE318	GE - 3rd Floor All-Gender Washroom Near GE314	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House		GE - Basement All-Gender Washroom	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House		GE - Basement Kitchen	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE020	GE - Basement Women's Washroom	ND - Open - No action required
Thursday, September 24, 2020	McCaul street-254/256		3rd Floor Lunch Room	ND - Open - No action required
Wednesday, September 22, 2021	McCaul Street-254/256	RM116	RM - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, September 22, 2021	McCaul Street-254/256		RM - 2nd Floor Water Fountain Near RM208	ND - Open - No action required
Wednesday, September 22, 2021	McCaul Street-254/256	RM414	RM - 4th Floor Kitchen	ND - Open - No action required
Wednesday, September 22, 2021	McCaul Street-254/256	RM510	RM - 5th Floor Men's Washroom	ND - Open - No action required
Thursday, September 24, 2020	McCaul street-254/256	508	Shower Room	ND - Open - No action required
Thursday, September 24, 2020	McCaul street-254/256		Water Fountain Across Room 117	ND - Open - No action required
Thursday, September 24, 2020	McCaul street-254/256	507	Women's Washroom	ND - Open - No action required
Wednesday, October 7, 2020	McCaul street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	18 - Open - Normal operations with preventive maintenance
Tuesday, December 8, 2020	McCaul street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	55 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	McCaul street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	ND - Open - No action required
Tuesday, June 1, 2021	McCaul street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	88 - Open - Normal operations with preventive maintenance
Monday, July 19, 2021	McCaul Street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	56 - Open - Normal operations with preventive maintenance
Monday, August 23, 2021	McCaul Street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	18 - Open - Normal operations with preventive maintenance
Wednesday, October 27, 2021	McCaul Street-263	OA104	OA - 1st Floor All-Gender Washroom (Left)	ND - Open - No action required
Wednesday, October 7, 2020	McCaul street-263		OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Tuesday, June 1, 2021	McCaul street-263		OA - 2nd Floor Lab Inside Well-Being Centre	11 - Open - Normal operations with preventive maintenance
Monday, July 19, 2021	McCaul Street-263		OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Monday, August 23, 2021	McCaul Street-263		OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Thursday, February 18, 2021	McCaul street-263	OA318	OA - 3rd Floor Men's Washroom	340 - Closed - Isolation point of use, remediation required
Wednesday, March 10, 2021	McCaul street-263	OA318	OA - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, June 1, 2021	McCaul street-263	OA318	OA - 3rd Floor Men's Washroom	ND - Open - No action required
Monday, July 19, 2021	McCaul Street-263	OA318	OA - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, October 7, 2020	McCaul street-263		OA - 4th Floor Women's Washroom Beside OA406A	12 - Open - Normal operations with preventive maintenance
Tuesday, December 8, 2020	McCaul street-263		OA - 4th Floor Women's Washroom Beside OA406A	18 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	McCaul street-263		OA - 4th Floor Women's Washroom Beside OA406A	2.2 - Open - No action required
Wednesday, March 10, 2021	McCaul street-263		OA - 4th Floor Women's Washroom Beside OA406A	2.2 - Open - No action required
Tuesday, June 1, 2021	McCaul street-263		OA - 4th Floor Women's Washroom Beside OA406A	11 - Open - Normal operations with preventive maintenance
Monday, July 19, 2021	McCaul Street-263		OA - 4th Floor Women's Washroom Beside OA406A	ND - Open - No action required
Monday, August 23, 2021	McCaul Street-263		OA - 4th Floor Women's Washroom Beside OA406A	ND - Open - No action required
Thursday, February 18, 2021	McCaul street-263	OA512	OA - 5th Floor Kitchen	ND - Open - No action required
Wednesday, October 7, 2020	McCaul street-263		OA - Kitchen Across OA513	ND - Open - No action required
Tuesday, September 7, 2021	McLennan Physical Laboratories	MP127	MP - 1st Floor Lab Sink	ND - Open - No action required
Monday, September 14, 2020	McLennan Physical Laboratories	MP132	MP - 1st Men's Washroom	ND - Open - No action required
Tuesday, September 7, 2021	McLennan Physical Laboratories	MP254	MP - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, September 7, 2021	McLennan Physical Laboratories	MP031	MP - Basement Men's Washroom	ND - Open - No action required
Monday, September 14, 2020	McLennan Physical Laboratories	MP239	MP - Lab	ND - Open - No action required
Monday, September 14, 2020	McLennan Physical Laboratories		MP - Water Fountain Near MP0103	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building		MR - 1st Floor Kitchen Beside Elevator	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR220	MR - 2nd Floor Kitchen Near Elevators	11 - Open - Normal operations with preventive maintenance



Wednesday, October 21, 2020	McMurrich Building		MR - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR314	MR - 3rd Floor Women's Washroom	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR403	MR - 4th Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building		MR - 4th Floor MEN'S Washroom	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building	10A	MR - All-Gender Washroom	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR10A	MR - Basement All-Gender Washroom	ND - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building		MC - 1st Floor Men's Washroom Beside the Elevator	34 - Open - Normal operations with preventive maintenance
Friday, February 19, 2021	Mechanical Engineering Building		MC - 1st Floor Men's Washroom Beside the Elevator	98 - Open - Normal operations with preventive maintenance
Tuesday, April 13, 2021	Mechanical Engineering Building		MC - 1st Floor Men's Washroom Beside the Elevator	ND - Open - No action required
Monday, May 3, 2021	Mechanical Engineering Building		MC - 1st Floor Men's Washroom Beside the Elevator	14 - Open - Normal operations with preventive maintenance
Tuesday, May 18, 2021	Mechanical Engineering Building		MC - 1st Floor Men's Washroom Beside the Elevator	1.1 - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building	MC330	MC - 3rd Floor Kitchen	15 - Open - Normal operations with preventive maintenance
Friday, February 19, 2021	Mechanical Engineering Building	MC330	MC - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, April 13, 2021	Mechanical Engineering Building	MC330	MC - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building		MC - 4th Floor Shower Beside MC413	5.2 - Open - No action required
Friday, February 19, 2021	Mechanical Engineering Building		MC - 4th Floor Shower Beside MC413	19 - Open - Normal operations with preventive maintenance
Tuesday, April 13, 2021	Mechanical Engineering Building		MC - 4th Floor Shower Beside MC413	ND - Open - No action required
Monday, May 3, 2021	Mechanical Engineering Building		MC - 4th Floor Shower Beside MC413	ND - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building	MC55	MC - Basement Lab Sink	67 - Open - Normal operations with preventive maintenance
Friday, February 19, 2021	Mechanical Engineering Building	MC55	MC - Basement Lab Sink	18 - Open - Normal operations with preventive maintenance
Tuesday, April 13, 2021	Mechanical Engineering Building	MC55	MC - Basement Lab Sink	55 - Open - Normal operations with preventive maintenance
Monday, May 3, 2021	Mechanical Engineering Building	MC55	MC - Basement Lab Sink	6.6 - Open - No action required
Tuesday, May 18, 2021	Mechanical Engineering Building	MC55	MC - Basement Lab Sink	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building		MS - 1st Floor Water Fountain Near MS1228	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS2171	MS - 2nd Floor Lunch Room Kitchen	ND - Open - No action required
Monday, August 30, 2021	Medical Sciences Building		MS - 2nd Floor So Sushi Right Sink in the Cafeteria	ND - Open - No action required
Monday, August 30, 2021	Medical Sciences Building		MS - 2nd Floor Starbucks Far Right Sink	ND - Open - No action required
Monday, August 30, 2021	Medical Sciences Building		MS - 2nd Floor Tim Hortons Back Room Sink	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS3235	MS - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building		MS - 3rd Floor Women's Washroom	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS5234	MS - 5th Floor Lunch Room Kitchen	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building		MS - Fountain Near MS6235	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building	MS4243	MS - Kitchen	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building	MS5336	MS - Lab	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall		MO - 13th Floor All-Gender Shower	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall	MO500	MO - 5th Floor Kitchen	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall		MO - 9th Floor All-Gender Washroom	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall		MO - Basement Common Shower	ND - Open - No action required
Monday, November 1, 2021	Munk School of Global Affairs & Public Policy - Graham Library	MK108	MK - 1st Floor Kitchen	ND - Open - No action required
Wednesday, January 13, 2021	Munk School of Global Affairs & Public Policy - Graham Library	MK105	MK - 1st Floor Washroom away from Elevator	ND - Open - No action required
Monday, November 1, 2021	Munk School of Global Affairs & Public Policy - Graham Library	MK204	MK - 2nd Floor All-Gender Washroom Near Elevators	ND - Open - No action required
Wednesday, January 13, 2021	Munk School of Global Affairs & Public Policy - Graham Library	MK305	MK - 3rd Floor All-Gender Accessible Washroom	ND - Open - No action required
Wednesday, January 13, 2021	Munk School of Global Affairs & Public Policy - Graham Library	MK005K	MK - Basement Kitchen	ND - Open - No action required
Monday, November 1, 2021	Munk School of Global Affairs & Public Policy - Graham Library	MK005K	MK - Basement Kitchen	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship		1st Floor Women's Washroom	ND - Open - No action required
Tuesday, September 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY211	MY - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship		MY - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, September 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY606	MY - 6th Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, September 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY772K	MY - 7th Floor Kitchen Sink	ND - Open - No action required
Tuesday, September 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY40	MY - Basement Kitchen Sink Near MY38	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship	MY512	MY - Kitchen	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship	MY870	MY - Kitchen	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR462	NR - Common Room Kitchen Sink	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR855	NR - All-Gender Washroom Shower	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR750	NR - All-Gender Washroom Sink	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR641	NR - Don Suite Kitchen Sink	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for studies in Education		11th Floor Water Fountain	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for studies in Education		1st Floor Women's Washroom	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for studies in Education		7th Floor men's Washroom	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for studies in Education	3-399	Kitchen - 3-399	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI12-130	OI - 12th Floor Kitchen Inside Nexus Lounge	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI2-239	OI - 2nd Floor Kitchen Inside Centre for Women's Studies in Education	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI5-300	OI - 5th Floor Women's Washroom	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education		OI - 9th Floor Water Fountain Near OI9-100	ND - Open - No action required
Monday, February 22, 2021	Queen's Park Crescent East-39		ME - 1st Floor Kitchen	960 - Closed - Isolation point of use, remediation required
Thursday, August 26, 2021	Queen's Park Crescent East-39		ME - 1st Floor Kitchen	23 - Open - Normal operations with preventive maintenance
Monday, February 22, 2021	Queen's Park Crescent East-39		ME - 2nd Floor Washroom Across from Fireplace	ND - Open - No action required
Monday, February 22, 2021	Queen's Park Crescent East-39	ME204	ME - 2nd Floor Washroom All-Gender	55 - Open - Normal operations with preventive maintenance
Thursday, August 26, 2021	Queen's Park Crescent East-39	ME204	ME - 2nd Floor Washroom All-Gender	26 - Open - Normal operations with preventive maintenance
Monday, February 22, 2021	Queen's Park Crsc. E.-39A		ML - 2nd Floor Washroom	ND - Open - No action required
Friday, November 26, 2021	Queen's Park Crsc. E.-39A	MLS	ML - 2nd Floor Washroom	ND - Open - No action required
Wednesday, October 7, 2020	Ramsay Wright Laboratories		RW - 2nd Floor Men's Washroom	ND - Open - No action required
Monday, November 2, 2020	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	80 - Open - Normal operations with preventive maintenance
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	23 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	ND - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	12 - Open - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	30 - Open - Normal operations with preventive maintenance
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	15 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW334A	RW - 3RD Floor Men's Washroom	17 - Open - Normal operations with preventive maintenance
Monday, November 2, 2020	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	42 - Open - Normal operations with preventive maintenance
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	11 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	ND - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	ND - Open - No action required
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	ND - Open - No action required
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	4.7 - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	15 - Open - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	27 - Open - Normal operations with preventive maintenance
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	ND - Open - No action required
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	13 - Open - Normal operations with preventive maintenance
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	28 - Open - Normal operations with preventive maintenance
Monday, November 2, 2020	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	3.8 - Open - No action required
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	18 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	4.3 - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	15 - Open - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	6.5 - Open - No action required
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	12 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW401	RW - Kitchen Inside Admin Office	24 - Open - Normal operations with preventive maintenance
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW604	RW - Research Lab	14 - Open - Normal operations with preventive maintenance
Monday, November 2, 2020	Ramsay Wright Laboratories	RW604	RW - Research Lab	34 - Open - Normal operations with preventive maintenance
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW604	RW - Research Lab	46 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW604	RW - Research Lab	7.3 - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW604	RW - Research Lab	19 - Open - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW604	RW - Research Lab	20 - Open - Normal operations with preventive maintenance
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW604	RW - Research Lab	40 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW604	RW - Research Lab	22 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories		RW 2nd Floor Women's Washroom	ND - Open - No action required
Friday, May 14, 2021	Ramsay Wright Laboratories		RW 3rd Floor Women's Washroom	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building		RU - 10th Floor Water Fountain	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building		RU - 1st Floor men's Washroom	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU402	RU - 4th Floor Accessible Washroom	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building	420	RU - 4th Floor Orthotics Lab Sink Room 420	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU718	RU - 7th Floor Accessible Shower	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU730	RU - 7th Floor Clinical Lab Sink	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU72	RU - Basement Accessible Shower	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building		RU - Basement Shower	ND - Open - No action required
Thursday, September 2, 2021	Rosebrugh Building	RS108B	RS - 1st Floor Lab Sink	ND - Open - No action required
Thursday, September 2, 2021	Rosebrugh Building	RS102	RS - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Rosebrugh Building		RS - 2nd Floor Water Fountain Near RS211	ND - Open - No action required
Thursday, September 2, 2020	Rosebrugh Building		RS - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Rosebrugh Building	RS420B	RS - 4th Floor Kitchen Sink	5100 - Closed - Isolation point of use, remediation required
Tuesday, September 28, 2021	Rosebrugh Building	RS420B	RS - 4th Floor Kitchen Sink	26 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Rosebrugh Building	RS420B	RS - 4th Floor Kitchen Sink	ND - Open - No action required
Thursday, September 24, 2020	Rosebrugh Building		RS - 4th Floor Men's Washroom	ND - Open - No action required
Thursday, September 24, 2020	Rosebrugh Building	RS421	RS - Research Lab	ND - Open - No action required
Thursday, September 24, 2020	Rosebrugh Building		Water Fountain Near RS105	ND - Open - No action required
Tuesday, October 12, 2021	Rotman School of Management	RT112A	RT - 1st Floor Second Cup Cafe Sink	ND - Open - No action required
Tuesday, October 12, 2021	Rotman School of Management	RT221	RT - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, October 12, 2021	Rotman School of Management	RT304	RT - 3rd Floor Kitchennette Near RT310	ND - Open - No action required
Tuesday, October 12, 2021	Rotman School of Management	RT6025	RT - 6th Floor Kitchen	ND - Open - No action required
Wednesday, November 11, 2020	Rotman School of Management	RT390A	RT - Kitchen	ND - Open - No action required
Tuesday, October 12, 2021	Rotman School of Management	RT390A	RT - Kitchen	ND - Open - No action required
Wednesday, November 11, 2020	Rotman School of Management	RT4063	RT - Men's Washroom	ND - Open - No action required
Wednesday, November 11, 2020	Rotman School of Management	RT1050C	RT - PHD Lounge	ND - Open - No action required
Wednesday, November 11, 2020	Rotman School of Management		RT - Water Fountain Near RT114	ND - Open - No action required
Wednesday, November 11, 2020	Rotman School of Management	RT223	RT - Women's Washroom	ND - Open - No action required
Wednesday, November 11, 2020	Rotman School of Management	RT8061	RT - Women's Washroom	ND - Open - No action required
Wednesday, September 1, 2021	Sandford Fleming Building	SF1014	SF - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, September 1, 2021	Sandford Fleming Building	SF3105	SF - 3rd Floor Women's Washroom	ND - Open - No action required
Wednesday, September 1, 2021	Sandford Fleming Building		SF - 4th Floor Water Fountain Near 4202	ND - Open - No action required



Monday, September 14, 2020	Sandford Fleming Building	SF2107	SF - Men's Washroom	ND - Open - No action required
Monday, September 14, 2020	Sandford Fleming Building		SF - Sink in Basement Near Hardhat Cafe	ND - Open - No action required
Monday, September 14, 2020	Sandford Fleming Building		SF - Water Fountain Near SF1013	ND - Open - No action required
Monday, November 30, 2020	School of Continuing studies		CS - 1st Floor Accessible Washroom Beside ELEVAOR	ND - Open - No action required
Friday, October 15, 2021	School of Continuing Studies	CS118	CS - 1st Floor Women's Washroom	ND - Open - No action required
Monday, November 30, 2020	School of Continuing Studies		CS - 2nd Floor Kitchen	ND - Open - No action required
Friday, October 15, 2021	School of Continuing Studies	CS415	CS - 4th Floor Accessible Washroom	ND - Open - No action required
Monday, November 30, 2020	School of Continuing Studies		CS - 4th Floor Women's Washroom	ND - Open - No action required
Friday, October 15, 2021	School of Continuing Studies	CS10	CS - Basement Kitchen	ND - Open - No action required
Wednesday, October 7, 2020	School of Graduate studies	RM105	1st Floor Kitchen Beside Room 105	ND - Open - No action required
Wednesday, October 7, 2020	School of Graduate studies		2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, October 7, 2020	School of Graduate studies		3rd Floor Washroom	ND - Open - No action required
Friday, October 8, 2021	School of Graduate Studies		GS - 1st Floor All-Gender Washroom	ND - Open - No action required
Friday, October 8, 2021	School of Graduate Studies		GS - 2nd Floor Women's Washroom	ND - Open - No action required
Friday, October 8, 2021	School of Graduate Studies		GS - 3rd Floor Kitchen	ND - Open - No action required
Friday, September 11, 2020	Sidney Smith Hall	SS1002	SS - 1st Floor Men's Washroom	ND - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall	SS1055	SS - 1st Floor Women's Washroom	ND - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall		SS - 4th Floor Water Fountain near S54082	ND - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall	SS6029	SS - 6th Floor Lounge Kitchen	2.8 - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall	SS406	SS - Basement Men's Washroom	ND - Open - No action required
Friday, September 11, 2020	Sidney Smith Hall	SS404	SS - Sid's Cafe	ND - Open - No action required
Friday, September 11, 2020	Sidney Smith Hall		SS - Water Fountain Near SS1043	ND - Open - No action required
Wednesday, October 6, 2021	Simcoe Hall	SI210W	SI - 2nd Floor All-Gender Washroom Inside SI210	ND - Open - No action required
Monday, September 21, 2020	Simcoe Hall	SI228	SI - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, October 6, 2021	Simcoe Hall	SI23A	SI - Basement Kitchen Near SI23	ND - Open - No action required
Monday, September 21, 2020	Simcoe Hall	SI8A	SI - Basement Men's Washroom	ND - Open - No action required
Wednesday, October 6, 2021	Simcoe Hall		SI - Basement Women's Washroom Near SI9	ND - Open - No action required
Monday, September 21, 2020	Simcoe Hall	SI107	SI - Kitchen Tap Inside Room 107	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD386	SD - All-Gender Washroom Shower (Jeanneret)	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD265	SD - All-Gender Washroom Sink (Wallace)	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD47	SD - Kitchen Sink in Basement	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD121	SD - Shower in Washroom (Loudan)	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-665		XG - 1st Floor Kitchen	ND - Open - No action required
Friday, August 13, 2021	Spadina Avenue-665		XG - 1st Floor Kitchen	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-665		XG - 1st Floor Women's Washroom	ND - Open - No action required
Friday, August 13, 2021	Spadina Avenue-665		XG - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703		IA - 1st Floor Washroom	ND - Open - No action required
Wednesday, October 13, 2021	Spadina Avenue-703	IA107B	IA - 1st Floor Washroom	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703		IA - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703		IA - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703		IA - 3rd Floor Shower	ND - Open - No action required
Wednesday, October 13, 2021	Spadina Avenue-703	IA303	IA - 3rd Floor Shower	ND - Open - No action required
Monday, November 16, 2020	st. George street-121	IR101A	IR - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, September 28, 2021	St. George Street-121	IR101	IR - 1st Floor Women's Washroom	ND - Open - No action required
Monday, November 16, 2020	st. George street-121		IR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, September 28, 2021	St. George Street-121	IR209	IR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Monday, November 16, 2020	st. George street-121	IR21	IR - Basement Kitchen	ND - Open - No action required
Tuesday, September 28, 2021	St. George Street-121	IR21	IR - Basement Kitchen	ND - Open - No action required
Monday, November 23, 2020	st. George street-123	WA105B	WA - 1st Floor Accessible Washroom Beside 107	ND - Open - No action required
Monday, November 23, 2020	st. George street-123		WA - 1st Floor Kitchen	ND - Open - No action required
Monday, November 23, 2020	st. George street-123		WA - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, September 23, 2021	St. George Street-123	WA205	WA - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, September 23, 2021	St. George Street-123	WA306	WA - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, September 23, 2021	St. George Street-123	WA304K	WA - 3rd Floor Kitchen	ND - Open - No action required
Monday, November 30, 2020	st. George street-162		CO - 1st Floor Kitchen	ND - Open - No action required
Wednesday, October 20, 2021	St. George Street-162	CO112	CO - 1st Floor Women's Washroom	ND - Open - No action required
Monday, November 30, 2020	st. George street-162		CO - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 20, 2021	St. George Street-162	CO209	CO - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 20, 2021	St. George Street-162	CO306	CO - 3rd Floor Men's Washroom Shower	ND - Open - No action required
Monday, November 30, 2020	st. George street-162		CO - 3RD Floor TUB Tap	ND - Open - No action required
Monday, November 30, 2020	st. George street-162		CO - Basement Washroom	ND - Open - No action required
Thursday, October 15, 2020	st. George street-45	PG209	PG - 2nd Floor Kitchen	ND - Open - No action required
Monday, September 13, 2021	St. George Street-45		PG - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, October 15, 2020	st. George street-45		PG - 2nd Floor Women's Washroom	ND - Open - No action required
Monday, September 13, 2021	St. George Street-45		PG - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, October 15, 2020	st. George street-45	PG303B	PG - 3rd Floor Lab Sink	ND - Open - No action required
Monday, September 13, 2021	St. George Street-45	PG303B	PG - 3rd Floor Lab Sink	ND - Open - No action required
Tuesday, October 27, 2020	st. George street-45		PG - Basement Men's Washroom	ND - Open - No action required
Monday, September 13, 2021	St. George Street-45	PG2A	PG - Basement Men's Washroom	3 - Open - No action required
Wednesday, February 3, 2021	stewart Building	309	EP - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, February 3, 2021	stewart Building	EP406	EP - 4th Floor Women's Washroom	12 - Open - Normal operations with preventive maintenance
Monday, March 8, 2021	stewart Building	EP406	EP - 4th Floor Women's Washroom	ND - Open - No action required
Friday, June 11, 2021	stewart Building	EP406	EP - 4th Floor Women's Washroom	37 - Open - Normal operations with preventive maintenance
Wednesday, February 3, 2021	stewart Building	503	EP - 5th Floor All-Gender Accessible Washroom	5.7 - Open - No action required
Friday, June 11, 2021	stewart Building	EP510	EP - All-Gender Accessible Washroom	4.8 - Open - No action required
Wednesday, February 3, 2021	stewart Building	EP3	EP - Basement Men's Washroom	ND - Open - No action required
Friday, June 11, 2021	stewart Building	EP3	EP - Basement Men's Washroom	ND - Open - No action required
Thursday, January 14, 2021	Sussex Avenue-40		SX - 2nd Floor Kitchen	ND - Open - No action required
Thursday, January 14, 2021	Sussex Avenue-40		SX - 2nd Floor Washroom	ND - Open - No action required
Thursday, December 3, 2020	Sussex Court		SC - 1st Floor Accessible Washroom	ND - Open - No action required
Thursday, December 3, 2020	Sussex Court		SC - 1st Floor Men's Locker Room Shower	ND - Open - No action required
Thursday, December 3, 2020	Sussex Court		SC - 3rd Floor Kitchen	49 - Open - Normal operations with preventive maintenance
Wednesday, December 9, 2020	Sussex Court		SC - 3rd Floor Kitchen	80 - Open - Normal operations with preventive maintenance
Monday, March 15, 2021	Sussex Court		SC - 3rd Floor Kitchen	12 - Open - Normal operations with preventive maintenance
Friday, April 30, 2021	Sussex Court		SC - 3rd Floor Kitchen	75 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Sussex Court		SC - 3rd Floor Kitchen	30 - Open - Normal operations with preventive maintenance
Tuesday, June 1, 2021	Sussex Court		SC - 3rd Floor Kitchen	4.1 - Open - No action required
Monday, June 28, 2021	Sussex Court		SC - 3rd Floor Kitchen	ND - Open - No action required
Thursday, July 22, 2021	Sussex Court		SC - 3rd Floor Kitchen	ND - Open - No action required
Thursday, December 3, 2020	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	240 - Closed - Isolation point of use, remediation required
Wednesday, December 9, 2020	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	190 - Closed - Isolation point of use, remediation required
Monday, March 15, 2021	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	75 - Open - Normal operations with preventive maintenance
Friday, April 30, 2021	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	97 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	64 - Open - Normal operations with preventive maintenance
Tuesday, June 1, 2021	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	5.3 - Open - No action required
Monday, June 28, 2021	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	40 - Open - Normal operations with preventive maintenance
Thursday, July 22, 2021	Sussex Court	SC504	SC - 5th Floor All-Gender Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Terrence Donnelly Ctr for Cellular & Biomolecular Res		DC - 10th Floor Kitchen	ND - Open - No action required
Wednesday, October 6, 2021	Terrence Donnelly Ctr for Cellular & Biomolecular Res	DC1040	DC - 10th Floor Lab Sink	ND - Open - No action required
Wednesday, October 6, 2021	Terrence Donnelly Ctr for Cellular & Biomolecular Res	DC1200K	DC - 12th Floor Kitchen	ND - Open - No action required
Tuesday, September 22, 2020	Terrence Donnelly Ctr for Cellular & Biomolecular Res		DC - 13th Floor Men's Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Terrence Donnelly Ctr for Cellular & Biomolecular Res		DC - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, October 6, 2021	Terrence Donnelly Ctr for Cellular & Biomolecular Res	DC313	DC - 3rd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 6, 2021	Terrence Donnelly Ctr for Cellular & Biomolecular Res	DC515	DC - 5th Floor Men's Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Terrence Donnelly Ctr for Cellular & Biomolecular Res	DC530	DC - Lab	ND - Open - No action required
Tuesday, October 6, 2020	Thomas Fisher Rare Book Library Building	R116	1st Floor Lab (Book Fixing)	ND - Open - No action required
Tuesday, October 6, 2020	Thomas Fisher Rare Book Library Building	R135	1st Women's Washroom	ND - Open - No action required
Tuesday, October 6, 2020	Thomas Fisher Rare Book Library Building	R003	Basement Men's Washroom	ND - Open - No action required
Thursday, November 4, 2021	Thomas Fisher Rare Book Library Building	RB116	RB - 1st Floor Lab Sink	ND - Open - No action required
Thursday, November 4, 2021	Thomas Fisher Rare Book Library Building	RB406	RB - 4th Floor Caretakers Closet	ND - Open - No action required
Thursday, November 4, 2021	Thomas Fisher Rare Book Library Building	RB03	RB - Subbasement Men's Washroom	ND - Open - No action required
Thursday, November 4, 2021	Thomas Fisher Rare Book Library Building	RB02	RB - Subbasement Sink Near RB11	ND - Open - No action required
Friday, June 4, 2021	TWH - Krembil Discovery Tower	6KD421	6KD - All-Gender Washroom Sink	ND - Open - No action required
Friday, June 4, 2021	TWH - Krembil Discovery Tower	6KD420	6KD - Lunchroom Sink	ND - Open - No action required
Friday, June 4, 2021	TWH - Krembil Discovery Tower	6KD426	6KD - Men's Washroom Sink	ND - Open - No action required
Monday, September 28, 2020	University College	UC275A	UC - 2nd Floor Accessible Washroom	ND - Open - No action required
Wednesday, September 23, 2020	University College	UC378A	UC - 3rd Floor Accessible Washroom	12 - Open - Normal operations with preventive maintenance
Monday, September 28, 2020	University College	UC378A	UC - 3rd Floor Accessible Washroom	62 - Open - Normal operations with preventive maintenance
Monday, October 5, 2020	University College	UC378A	UC - 3rd Floor Accessible Washroom	44 - Open - Normal operations with preventive maintenance
Tuesday, March 16, 2021	University College	UC378A	UC - 3rd Floor Accessible Washroom	ND - Open - No action required
Thursday, September 9, 2021	University College	UC378A	UC - 3rd Floor Accessible Washroom	8.5 - Open - No action required
Tuesday, October 5, 2021	University College	UC378A	UC - 3rd Floor Accessible Washroom	ND - Open - No action required
Monday, October 18, 2021	University College	UC378A	UC - 3rd Floor Accessible Washroom	ND - Open - No action required
Monday, October 5, 2020	University College	UCF302	UC - 3rd Floor All-Gender Washroom	18 - Open - Normal operations with preventive maintenance
Tuesday, March 16, 2021	University College	UCF302	UC - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, September 9, 2021	University College	UCF302	UC - 3rd Floor All-Gender Washroom	7.6 - Open - No action required
Tuesday, October 5, 2021	University College	UCF302	UC - 3rd Floor All-Gender Washroom	ND - Open - No action required
Monday, October 18, 2021	University College	UCF302	UC - 3rd Floor All-Gender Washroom	8.4 - Open - No action required
Monday, October 5, 2020	University College	Inside Junior Common Room	UC - All-Gender Washroom (Left) Across from Diabolos' Coffee Cafe	360 - Closed - Isolation point of use, remediation required
Tuesday, March 16, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Left) Across from Diabolos' Coffee Cafe	590 - Closed - Isolation point of use, remediation required
Monday, May 10, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Left) Across from Diabolos' Coffee Cafe	30 - Open - Normal operations with preventive maintenance
Wednesday, June 9, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Left) Across from Diabolos' Coffee Cafe	16 - Open - Normal operations with preventive maintenance
Wednesday, June 30, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Left) Across from Diabolos' Coffee Cafe	62 - Open - Normal operations with preventive maintenance
Tuesday, March 16, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Right) Across from Diabolos' Coffee Cafe	2400 - Closed - Isolation point of use, remediation required
Monday, May 10, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Right) Across from Diabolos' Coffee Cafe	240 - Closed - Isolation point of use, remediation required
Wednesday, June 9, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Right) Across from Diabolos' Coffee Cafe	160 - Closed - Isolation point of use, remediation required
Wednesday, June 30, 2021	University College	Inside Junior Common Room	UC - All-Gender Washroom (Right) Across from Diabolos' Coffee Cafe	91 - Open - Normal operations with preventive maintenance
Monday, September 28, 2020	University College	UC89A	UC - Basement Men's Washroom	2600 - Closed - Isolation point of use, remediation required



Monday, October 5, 2020	University College	UC89A	UC - Basement Men's Washroom	11 - Open - Normal operations with preventive maintenance
Tuesday, March 16, 2021	University College	UC89A	UC - Basement Men's Washroom	91 - Open - Normal operations with preventive maintenance
Monday, May 10, 2021	University College	UC89A	UC - Basement Men's Washroom	430 - Closed - Isolation point of use, remediation required
Wednesday, June 9, 2021	University College	UC89A	UC - Basement Men's Washroom	52 - Open - Normal operations with preventive maintenance
Wednesday, June 30, 2021	University College	UC89A	UC - Basement Men's Washroom	90 - Open - Normal operations with preventive maintenance
Thursday, September 9, 2021	University College	UC89A	UC - Basement Men's Washroom	13000 - Closed - Isolation point of use, remediation required
Tuesday, October 5, 2021	University College	UC89A	UC - Basement Men's Washroom	2800 - Closed - Isolation point of use, remediation required
Monday, October 18, 2021	University College	UC89A	UC - Basement Men's Washroom	8000 - Closed - Isolation point of use, remediation required
Wednesday, September 23, 2020	University College	UC89	UC - Basement Women's Washroom	410 - Closed - Isolation point of use, remediation required
Monday, September 28, 2020	University College	UC89	UC - Basement Women's Washroom	280 - Closed - Isolation point of use, remediation required
Monday, October 5, 2020	University College	UC89	UC - Basement Women's Washroom	190 - Closed - Isolation point of use, remediation required
Tuesday, March 16, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Monday, May 10, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Wednesday, June 9, 2021	University College	UC89	UC - Basement Women's Washroom	630 - Closed - Isolation point of use, remediation required
Wednesday, June 30, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Thursday, September 9, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Tuesday, October 5, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Monday, October 5, 2020	University College	UC154	UC - Gentlemen's Washroom	ND - Open - No action required
Monday, October 5, 2020	University College	UCB102	UC - Men's Staff Washroom	ND - Open - No action required
Monday, October 5, 2020	University College	UCS4B	UC - Staff Ladies Washroom	ND - Open - No action required
Wednesday, September 23, 2020	University College		UC - Water Fountain Near UC89	ND - Open - No action required
Monday, August 30, 2021	University College Union	UP110	UP - 1st Floor Washroom (Commuter Centre)	30 - Open - Normal operations with preventive maintenance
Friday, September 10, 2021	University College Union	UP110	UP - 1st Floor Washroom (Commuter Centre)	410 - Closed - Isolation point of use, remediation required
Wednesday, September 29, 2021	University College Union	UP110	UP - 1st Floor Washroom (Commuter Centre)	23 - Open - Normal operations with preventive maintenance
Monday, August 30, 2021	University College Union	UP208	UP - 2nd Floor Changing Room Sink	ND - Open - No action required
Monday, August 30, 2021	University College Union	UP206	UP - 2nd Floor Men's Shower	3.1 - Open - No action required
Friday, September 10, 2021	University College Union	UP206	UP - 2nd Floor Men's Shower	5.5 - Open - No action required
Wednesday, September 29, 2021	University College Union	UP206	UP - 2nd Floor Men's Shower	ND - Open - No action required
Monday, August 30, 2021	University College Union		UP - 3rd Floor Dean's Residence Washroom	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace studies (UTIAS)	AS160	AS - Cafeteria Kitchen Sink	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace studies (UTIAS)	AS125A	AS - Lab Sink	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace studies (UTIAS)		AS - Water Fountain (Unfiltered) Near AS154	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace studies (UTIAS)	AS181	AS - Women's Washroom Shower	ND - Open - No action required
Friday, August 13, 2021	Varsity Centre	VA113	VA - 1st Floor Changing Room Shower	ND - Open - No action required
Friday, August 13, 2021	Varsity Centre	VAD1008	VA - 1st Floor Men's Washroom	ND - Open - No action required
Wednesday, September 9, 2020	Varsity Centre	VA115	VA - Change Room	ND - Open - No action required
Wednesday, September 9, 2020	Varsity Centre	VA119	VA - Change Room	ND - Open - No action required
Friday, October 29, 2021	Visitor's Centre	VIB18H	VI - Basement Seminar Room Kitchennette	ND - Open - No action required
Wednesday, March 3, 2021	Visitor's Centre	VIB17	VI - Men's Accessible Washroom	ND - Open - No action required
Friday, October 29, 2021	Visitor's Centre	VIB17	VI - Men's Accessible Washroom	ND - Open - No action required
Wednesday, March 3, 2021	Visitor's Centre	VIB20	VI - Women's Accessible Washroom	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB344	Lab	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB238	Undergrad Common's Room	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building		Water Fountain Near WB123	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB143	WB - 1st Floor Undergraduate Common Room	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB217	WB - 2nd Floor Office Kitchennette	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB355	WB - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building		WB - 3rd Floor Water Fountain Near WB327	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB53A	Women's Washroom	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - 1st Floor Shower Closet to Pool	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB36C	WS - Basement Men's Changing Room Shower	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB7E	WS - Basement Pool Men's Varsity Changing Room Shower	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB8E	WS - Basement Pool Women's Varsity Changing Room Shower	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB31	WS - Basement Women's Changing Room Shower	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - Family Change Room	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - First Floor Accessible Washroom	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - Men's Change Room Sample 1	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - Men's Change Room Sample 2	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - Women's Change Room Sample 1	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building		WS - Women's Change Room Sample 2	ND - Open - No action required
Thursday, September 16, 2021	Wetmore Hall-New College	WE103	WE - 1st Floor Accessible Washroom	ND - Open - No action required
Tuesday, December 15, 2020	Wetmore Hall-New College	WE114	WE - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, December 15, 2020	Wetmore Hall-New College		WE - 1st Floor Water Fountain Near Room 114	ND - Open - No action required
Tuesday, December 15, 2020	Wetmore Hall-New College	WE296	WE - 2nd Floor All-Gender Washroom	ND - Open - No action required
Thursday, September 16, 2021	Wetmore Hall-New College	WE296	WE - 2nd Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, December 15, 2020	Wetmore Hall-New College	WE296	WE - 2nd Floor Washroom Shower	ND - Open - No action required
Thursday, September 16, 2021	Wetmore Hall-New College	WE322	WE - 3rd Floor All-Gender Washroom Shower	ND - Open - No action required
Thursday, September 16, 2021	Wetmore Hall-New College	WE452	WE - 4th Floor All-Gender Washroom	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	FA110	WT - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	CO238	WT - 2nd Floor Kitchen	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	MU378	WT - 3rd Floor Shower	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	FE69	WT - Basement Shower	ND - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI2054	WI - 2nd Floor Kitchen Sink	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College		WI - 2nd Floor Sink "Coffee Shed"	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI3071	WI - 3rd Floor All-Gender Washroom	6.4 - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI3071	WI - 3rd Floor All-Gender Washroom	3.1 - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI3071	WI - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI3075	WI - 3rd Floor Common Room Kitchen Sink	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI4002	WI - 4th Floor Common Room Sink	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI4003	WI - 4th Floor Women's Washroom Shower	ND - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI4071	WI - 4th Floor Women's Washroom Sink	5 - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI4071	WI - 4th Floor Women's Washroom Sink	ND - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI5071	WI - 5th Floor All-Gender Washroom Sink	4.3 - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI6057A	WI - 6th Floor All-Gender Washroom Sink	3.4 - Open - No action required
Tuesday, November 10, 2020	Woodsworth College	107G	WW - 1st Floor Kitchen	ND - Open - No action required
Tuesday, November 10, 2020	Woodsworth College		WW - 1st Floor Women's Washroom Near 121	ND - Open - No action required
Tuesday, November 10, 2020	Woodsworth College		WW - 2nd Floor All-Gender Washroom Near 227	ND - Open - No action required
Thursday, September 30, 2021	Woodsworth College	WW212	WW - 2nd Floor Kitchen	ND - Open - No action required
Thursday, September 30, 2021	Woodsworth College		WW - 2nd Floor Kitchennette Near WW227	ND - Open - No action required
Thursday, September 30, 2021	Woodsworth College	WW7	WW - Basement Women's Washroom	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO1001	WO - 10th Floor Kitchen Sink	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO1702	WO - 17th Floor Bathroom 1 Shower	ND - Open - No action required
Monday, February 1, 2021	Woodsworth College Residence		WO - 1st Floor Kitchen	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence		WO - 1st Floor Kitchen	ND - Open - No action required
Monday, February 1, 2021	Woodsworth College Residence		WO - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO503	WO - 5th Floor Bathroom 1 Sink	ND - Open - No action required
Monday, February 1, 2021	Woodsworth College Residence		WO - Basement Men's Washroom	ND - Open - No action required