

Table 4 - Water Testing - UTM Results - July 14, 2022				Level	GU/mL	Level	CFU/mL
				1	<10	1	<10
				2	10-100	2	10-100
				3	>100	3	>100
				ND - None detected		ND - None detected	
Test Date	Building	Room Tested	Room Description	Room Status q-PCR results		Room Status - culture (validation) results	
21-Apr-21	Erindale Hall	Suite 207		n/a		ND - Open	No action required
21-Apr-21	HIMALC Building	Rm253	Caretaker closet on level 2	n/a		ND - Open	No action required
21-Apr-21	Oscar Peterson Hall	Rm 600C	6th Floor- Caretaking Closet	n/a		ND - Open	No action required
21-Apr-21	Roy Ivor Hall, BLOCK A	Rm 606		n/a		ND - Open	No action required
21-Apr-21	Roy Ivor Hall, BLOCK B	Rm 621		n/a		ND - Open	No action required
21-Apr-21	Roy Ivor Hall, BLOCK C		Main Floor Caretakers closet	n/a		ND - Open	No action required
21-Apr-21	Roy Ivor Hall, BLOCK D	Rm 645		n/a		ND - Open	No action required
21-Apr-21	WG Davis Building	DC5036	Greenhouse	n/a		ND - Open	No action required
21-Apr-21	WG Davis Building, ABCD Block	DV5004	5th floor washroom	n/a		90 - Open	Normal operations with preventive maintenance
30-Apr-21	WG Davis Building, ABCD Block	DV5004	5th floor washroom	ND - Open	No action required	n/a	
7-Jun-21	Margarth Valley 154		Townhouse	n/a		ND - Open	No action required
7-Jun-21	Leacock Lane 132		Townhouse	n/a		ND - Open	No action required
7-Jun-21	Putnam Place 107		Townhouse	n/a		ND - Open	No action required
7-Jun-21	McLuhan Ct 56		Townhouse	n/a		ND - Open	No action required
7-Jun-21	Leacock Lane 148		Townhouse	n/a		ND - Open	No action required
7-Jun-21	McLuhan Ct. 88		Townhouse	n/a		ND - Open	No action required
7-Jun-21	McGrath Valley 225		Townhouse	n/a		ND - Open	No action required
7-Jun-21	Putnam Place 95		Townhouse	n/a		ND - Open	No action required
20-Jul-21	MN building		Hot Water Tank (HWT) 1	n/a		3 - Open	No action required
20-Jul-21	MN building		Hot Water Tank (HWT) 2	n/a		ND - Open	No action required
20-Jul-21	MN building		Hot Water faucet (HW)	n/a		ND - Open	No action required
20-Jul-21	Deerfield Hall		Hot Water Tank (HWT) 3	n/a		1 - Open	No action required
20-Jul-21	Deerfield Hall		Hot Water Tank (HWT) 2	n/a		ND - Open	No action required
20-Jul-21	Deerfield Hall		Hot Water Tank (HWT) 1	n/a		ND - Open	No action required
20-Jul-21	Deerfield Hall		Hot Water faucet (HW)	n/a		4 - Open	No action required
10-Aug-21	RAWC	Men's locker rm 115	Hot Water faucet (HW)	n/a		ND - Open	No action required
10-Aug-21	RAWC		Hot Water Tank (HWT) 1	n/a		ND - Open	No action required
10-Aug-21	RAW		Hot Water Tank (HWT) 2	n/a		ND - Open	No action required
10-Aug-21	HSC	Penhouse Mech Room	Hot Water faucet (HW)	n/a		ND - Open	No action required
10-Aug-21	DV JKL	Caretaking closet Rm 1111	Hot Water faucet (HW)	n/a		ND - Open	No action required
24-Aug-21	CCT		Hot Water Tank (HWT) 1	n/a		ND - Open	No action required
24-Aug-21	CCT		Hot Water Tank (HWT) 2	n/a		ND - Open	No action required
24-Aug-21	CCT	4199 - sink in caretaking closet	Hot Water (HW) faucet	n/a		ND - Open	No action required
24-Aug-21	IB	29 - sink in basement mechanical room	Hot Water (HW) faucet	n/a		ND - Open	No action required
24-Aug-21	IB		Hot Water Tank (HWT) 1	n/a		ND - Open	No action required
2-Dec-21	Central Utilities Plant	BSMT	Basement (HWT)	n/a		ND - Open	No action required
2-Dec-21	Student Centre	136	Mechanical Room (HWT #1)	n/a		ND - Open	No action required
2-Dec-21	Student Centre	136	Mechanical Room (HWT #2)	n/a		ND - Open	No action required
2-Dec-21	Student Centre	209	Kitchen tap	n/a		ND - Open	No action required
2-Dec-21	Instructional Centre (IB)	29	Mechanical Room (HWT #1)	n/a		ND - Open	No action required
2-Dec-21	Instructional Centre (IB)	29	Mechanical Room (HWT #2)	n/a		ND - Open	No action required
2-Dec-21	Instructional Centre (IB)	105	Pantry (HWT#3)	n/a		ND - Open	No action required
2-Dec-21	Research Greenhouse	100	Mechanical Room (HWT)	n/a		ND - Open	No action required
2-Dec-21	Lislehurst Building	BSMT	Basement (HWT #1)	n/a		1 - Open	No action required
2-Dec-21	Lislehurst Building	BSMT	Basement (HWT#2)	n/a		ND - Open	No action required
2-Dec-21	Lislehurst Building	Kitchen	Kitchen tap	n/a		ND - Open	No action required
2-Dec-21	Early Learning Centre	113	Hot Water Tank	n/a		1 - Open	No action required
2-Dec-21	Early Learning Centre	113	laundry sink tap	n/a		ND - Open	No action required
2-Dec-21	Alumni House	1A	Mechanical Room (HWT)	n/a		ND - Open	No action required
2-Dec-21	Alumni House	3	kitchen tap	n/a		ND - Open	No action required
2-Dec-21	Kaneff Building	269	Mechanical Room (HWT #1)	n/a		ND - Open	No action required
2-Dec-21	Kaneff Building	131	CC slop sink tap	n/a		ND - Open	No action required
2-Dec-21	Kaneff Building	269	Mechanical Room (HWT #2)	n/a		ND - Open	No action required
2-Dec-21	Innovation Complex	L1274	Mechanical Room (HWT #1)	n/a		ND - Open	No action required
2-Dec-21	Innovation Complex	L1274	Mechanical Room (HWT #2)	n/a		ND - Open	No action required
2-Dec-21	Academic Annex	111A	Hot Water Tank	n/a		ND - Open	No action required
14-Jul-22	Central Utilities Plant	BSMT	Basement (HWT)	n/a		ND - Open	No action required
14-Jul-22	WG Davis Building, ABCD Block	BSMT, Block A	Basement (HWT)	n/a		ND - Open	No action required
14-Jul-22	RAWC Building	Basement	Hot Water Tank #1	n/a		ND - Open	No action required
14-Jul-22	RAWC Building	Pool Tunnel	Pool Tunnel HWT #2	n/a		ND - Open	No action required
14-Jul-22	Central Utilities Plant	Lunch room	Lunch Room	n/a		ND - Open	No action required
14-Jul-22	WG Davis Building, ABCD Block	DV3029	Caretaking closet	n/a		12 - Open	Normal operations with preventative maintenance
28-Jul-22	WG Davis Building, ABCD Block	DV3029	Caretaking closet	0.5 GU/ml-Open	No action required		
14-Jul-22	WG Davis Building, JKL	Rm 1111		n/a		ND - Open	No action required
14-Jul-22	RAWC Building	Family Change Room	Family Change Room	n/a		ND - Open	No action required