

Table 2 - Water Testing - St. George - Historical Results (qPCR) - March 24, 2023

Test Date	Building	Room Tested	Room Description	Room Status
Wednesday, February 24, 2021	107 St George Garage	PK101A	PK - P1 All-Gender Washroom	ND - Open - No action required
Tuesday, December 8, 2022	107 St George Garage	PK101A	PK - P1 All-Gender Washroom	ND - Open - No action required
Wednesday, February 24, 2021	107 St George Garage	PK126	PK - P1 Storage Room	ND - Open - No action required
Tuesday, December 6, 2022	107 St George Garage	PK128	PK - P1 Storage Room	ND - Open - No action required
Tuesday, November 29, 2022	90 Wellesley - Faculty of Music	JP155	JP - 1st Floor All-Gender Washroom	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	JP132	JP - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, December 1, 2021	90 Wellesley - Faculty of Music	JP261	JP - 2nd Floor Practice Room	ND - Open - No action required
Tuesday, November 29, 2022	90 Wellesley - Faculty of Music	JP208	JP - 2nd Floor Practice Room	ND - Open - No action required
Wednesday, December 1, 2021	90 Wellesley - Faculty of Music	JP387	JP - 3rd Floor Men's Washroom Shower	ND - Open - No action required
Wednesday, December 1, 2021	90 Wellesley - Faculty of Music	JP313	JP - 3rd Floor Office	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	JP333	JP - 3rd Floor Practice Room	ND - Open - No action required
Wednesday, December 1, 2021	90 Wellesley - Faculty of Music	JP302	JP - 3rd Floor Women's Washroom Shower	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	JP432	JP - 4th Floor Men's Washroom	ND - Open - No action required
Tuesday, November 29, 2022	90 Wellesley - Faculty of Music	JP402	JP - 4th Floor Women's Washroom	ND - Open - No action required
Tuesday, November 29, 2022	90 Wellesley - Faculty of Music	JP61A	JP - Basement All-Gender Washroom	ND - Open - No action required
Thursday, March 4, 2021	90 Wellesley - Faculty of Music	JP	JP - Basement Water Fountain Beside Room 17	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building	AP130	AP - 1st Floor Lab Sink	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building	AP102	AP - 1st Floor Student Lounge Kitchen	3 - Open - No action required
Tuesday, June 22, 2021	Anthropology Building	AP102	AP - 1st Floor Student Lounge Kitchen	ND - Open - No action required
Tuesday, March 14, 2023	Anthropology Building	AP102	AP - 1st Floor Student Lounge Kitchen	ND - Open - No action required
Monday, October 18, 2021	Anthropology Building	AP275K	AP - 2nd Floor Water Fountain Near Department of Anthropology Administrative Offices	5 - Open - No action required
Friday, February 11, 2022	Anthropology Building	AP275K	AP - 2nd Floor Water Fountain Near Department of Anthropology Administrative Offices	ND - Open - No action required
Tuesday, February 22, 2022	Anthropology Building	AP275K	AP - 2nd Floor Water Fountain Near Department of Anthropology Administrative Offices	ND - Open - No action required
Tuesday, March 8, 2022	Anthropology Building	AP275K	AP - 2nd Floor Water Fountain Near Department of Anthropology Administrative Offices	ND - Open - No action required
Tuesday, March 14, 2023	Anthropology Building	AP319	AP - 3rd Floor All-Gender Accessible Washroom (Right)	4.9 - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP390K	AP - 3rd Floor Water Fountain Near AP390	ND - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	27 - Open - Normal operations with preventive maintenance
Tuesday, September 7, 2021	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	260 - Closed - Sanitation point of use, remediation required
Thursday, September 23, 2021	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	ND - Open - No action required
Monday, October 4, 2021	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	27 - Open - Normal operations with preventive maintenance
Monday, October 18, 2021	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, February 22, 2022	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, March 8, 2022	Anthropology Building	AP411	AP - 4th Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, March 14, 2023	Anthropology Building	AP518	AP - 5th Floor Lab Sink Near Door	ND - Open - No action required
Monday, October 26, 2020	Anthropology Building	AP510K	AP - 5th Floor Water Fountain Near AP500	ND - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP510K	AP - 5th Floor Water Fountain Near AP500	ND - Open - No action required
Tuesday, March 14, 2023	Anthropology Building	AP569	AP - Basement All-Gender Washroom	13 - Open - Normal operations with preventive maintenance
Monday, October 26, 2020	Anthropology Building	AP569	AP - Basement Women's Changeroom	ND - Open - No action required
Tuesday, August 24, 2021	Anthropology Building	AP569	AP - Basement Women's Changeroom	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building	AB100A	AB - 1st Floor Left All-Gender Washroom	29 - Open - Normal operations with preventive maintenance
Thursday, March 8, 2022	Astronomy & Astrophysics Building	AB100A	AB - 1st Floor Left All-Gender Washroom	ND - Open - No action required
Thursday, July 14, 2022	Astronomy & Astrophysics Building	AB100A	AB - 1st Floor Left All-Gender Washroom	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building	AB201	AB - 2nd Floor Lounge Kitchennette	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building	AB55	AB - Basement Lab Sink (Left)	ND - Open - No action required
Thursday, September 29, 2020	Astronomy & Astrophysics Building	AB	AB - Basement Men's Washroom	ND - Open - No action required
Thursday, August 26, 2021	Astronomy & Astrophysics Building	AB55K	AB - Basement Water Fountain Near AB52 (Decommissioned 20220907)	32 - Open - Normal operations with preventive maintenance
Thursday, March 8, 2022	Astronomy & Astrophysics Building	AB55K	AB - Basement Water Fountain Near AB52 (Decommissioned 20220907)	32 - Open - Normal operations with preventive maintenance
Thursday, July 14, 2022	Astronomy & Astrophysics Building	AB55K	AB - Basement Water Fountain Near AB52 (Decommissioned 20220907)	32 - Open - Normal operations with preventive maintenance
Wednesday, September 7, 2022	Astronomy & Astrophysics Building	AB55K	AB - Basement Water Fountain Near AB52 (Decommissioned 20220907)	320 - Closed - Sanitation point of use, remediation required
Tuesday, September 29, 2020	Astronomy & Astrophysics Building	AB102	AB - Kitchen	ND - Open - No action required
Tuesday, September 29, 2020	Astronomy & Astrophysics Building	AB73A	AB - Lab	ND - Open - No action required
Tuesday, September 29, 2020	Astronomy & Astrophysics Building	AB215K	AB - Women's Washroom	ND - Open - No action required
Tuesday, February 14, 2023	Bahen Centre for Information Technology	BA2010K	BA - 2nd Floor Kitchen	ND - Open - No action required
Thursday, October 22, 2020	Bahen Centre for Information Technology	BA3280K	BA - 3rd Floor Water Fountain Near BA3285	ND - Open - No action required
Tuesday, September 21, 2021	Bahen Centre for Information Technology	BA4153	BA - 4th Floor All-Gender Washroom	ND - Open - No action required
Tuesday, September 21, 2021	Bahen Centre for Information Technology	BA5284	BA - 5th Floor Men's Washroom	ND - Open - No action required
Thursday, October 22, 2020	Bahen Centre for Information Technology	BA5286	BA - 5th Floor Women's Washroom	ND - Open - No action required
Tuesday, February 14, 2023	Bahen Centre for Information Technology	BA6131	BA - 6th Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, February 14, 2023	Bahen Centre for Information Technology	BA7284	BA - 7th Floor Men's Washroom	ND - Open - No action required
Thursday, October 22, 2020	Bahen Centre for Information Technology	BA8224	BA - 8th Floor Lab Sink	ND - Open - No action required
Tuesday, September 21, 2021	Bahen Centre for Information Technology	BA8202	BA - 8th Floor Lab Sink	ND - Open - No action required
Tuesday, February 14, 2023	Bahen Centre for Information Technology	BA8113	BA - Basement Women's Washroom	ND - Open - No action required
Tuesday, November 22, 2022	Bancroft Building	BF113	BF - 1st Floor Kitchen	ND - Open - No action required
Thursday, August 28, 2021	Bancroft Building	BF112	BF - 1st Floor Women's Washroom	ND - Open - No action required
Monday, November 2, 2020	Bancroft Building	BF213	BF - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, November 22, 2022	Bancroft Building	BF212	BF - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, August 28, 2021	Bancroft Building	BF319K	BF - 3rd Floor Water Fountain	ND - Open - No action required
Tuesday, November 22, 2022	Bancroft Building	BF320	BF - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, November 2, 2020	Bancroft Building	BF321	BF - 3rd Men's Washroom	ND - Open - No action required
Tuesday, November 22, 2022	Bancroft Building	BF416A	BF - 4th Floor Men's Washroom	ND - Open - No action required
Monday, November 2, 2020	Bancroft Building	BF414K	BF - 4th Floor Water Fountain	ND - Open - No action required
Thursday, August 28, 2021	Bancroft Building	BF416	BF - 4th Floor Women's Washroom	ND - Open - No action required
Wednesday, November 25, 2020	Banting Institute	BI2	BI - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, November 25, 2020	Banting Institute	BI326	BI - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, March 21, 2023	Banting Institute	BI327	BI - 3rd Floor Women's Washroom	ND - Open - No action required
Tuesday, December 7, 2021	Banting Institute	BI531	BI - 5th Floor Collaboration Room Kitchennette	6.9 - Open - No action required
Tuesday, May 24, 2022	Banting Institute	BI531	BI - 5th Floor Collaboration Room Kitchennette	6.4 - Open - No action required
Tuesday, March 21, 2023	Banting Institute	BI531	BI - 5th Floor Collaboration Room Kitchennette	ND - Open - No action required
Tuesday, December 7, 2021	Banting Institute	BI10	BI - Sub-basement Office Kitchennette	23 - Open - Normal operations with preventive maintenance
Tuesday, May 24, 2022	Banting Institute	BI10	BI - Sub-basement Office Kitchennette	ND - Open - No action required
Tuesday, March 21, 2023	Banting Institute	BI10	BI - Sub-basement Office Kitchennette	ND - Open - No action required
Wednesday, November 25, 2020	Banting Institute	BI121K	BI - Water Fountain Near BI104	5.3 - Open - No action required
Tuesday, December 7, 2021	Banting Institute	BI121K	BI - Water Fountain Near BI104	ND - Open - No action required
Tuesday, May 24, 2022	Banting Institute	BI121K	BI - Water Fountain Near BI104	ND - Open - No action required
Tuesday, March 21, 2023	Banting Institute	BI121K	BI - Water Fountain Near BI104	ND - Open - No action required
Tuesday, January 19, 2021	Bloor Street West-371	FE135	FE - 1st Floor Kitchen	ND - Open - No action required
Monday, March 15, 2021	Bloor Street West-371	FE135	FE - 1st Floor Kitchen	ND - Open - No action required
Wednesday, September 28, 2022	Bloor Street West-371	FE117	FE - 1st Floor Staff Women's Washroom	2.4 - Open - No action required
Tuesday, January 19, 2021	Bloor Street West-371	FE226	FE - 2nd Floor Accessible Washroom	ND - Open - No action required
Wednesday, September 28, 2022	Bloor Street West-371	FE238	FE - 2nd Floor Departmental Lounge Kitchennette	ND - Open - No action required
Tuesday, January 19, 2021	Bloor Street West-371	FE322	FE - 3rd Floor Lab Sink	20 - Open - Normal operations with preventive maintenance
Monday, March 15, 2021	Bloor Street West-371	FE322	FE - 3rd Floor Lab Sink	ND - Open - No action required
Wednesday, September 28, 2022	Bloor Street West-371	FE336	FE - 3rd Floor Men's Washroom	2.3 - Open - No action required
Wednesday, September 28, 2022	Bloor Street West-371	FE31B	FE - Basement All-Gender Washroom	2 - Open - No action required
Tuesday, January 19, 2021	Bloor Street West-371	FE21A	FE - Basement Men's Washroom	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP155	LW - 1st Floor All-Gender Washroom	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP247	LW - 2nd Floor All-Gender Washroom	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP249	LW - 2nd Floor All-Gender Washroom	ND - Open - No action required
Friday, June 18, 2021	Bora Laskin Law Library	LWP231	LW - 2nd Floor Kitchen	ND - Open - No action required
Thursday, September 22, 2020	Borden Building North	NB104A	NB - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Thursday, September 30, 2021	Borden Building North	NB104A	NB - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, January 31, 2023	Borden Building North	NB104A	NB - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Thursday, September 30, 2021	Borden Building North	NB216A	NB - 2nd Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Borden Building North	NB213	NB - 2nd Floor Kitchen	ND - Open - No action required
Thursday, September 30, 2021	Borden Building North	NB210	NB - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, January 31, 2023	Borden Building North	NB210	NB - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, September 22, 2020	Borden Building North	NB319	NB - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, January 31, 2023	Borden Building North	NB318	NB - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South	SB101	SB - 1st Floor Kitchen	ND - Open - No action required
Tuesday, January 31, 2023	Borden Building South	SB101	SB - 1st Floor Kitchen	ND - Open - No action required
Tuesday, January 31, 2023	Borden Building South	SB204	SB - 2nd Floor Men's Washroom	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB209	SB - 2nd Floor Office Kitchennette	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South	SB201B	SB - 2nd Floor Women's Washroom	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB201	SB - 2nd Floor Women's Washroom Shower	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South	SB313	SB - 3rd Floor All-Gender Washroom	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB313	SB - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, January 31, 2023	Borden Building South	SB314	SB - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Borden Building South	SB308	SB - 3rd Floor Men's Washroom	ND - Open - No action required
Friday, September 10, 2021	Borden Building South	SB308	SB - 3rd Floor Men's Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	44 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	47 - Open - Normal operations with preventive maintenance
Thursday, September 17, 2020	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	95 - Open - Normal operations with preventive maintenance
Monday, September 21, 2020	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	81 - Open - No action required
Friday, September 25, 2020	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Friday, October 2, 2020	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL116	NL - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Friday, September 11, 2020	C. David Naylor Building	NL109	NL - 1st Floor Kitchen	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	2.6 - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	7.5 - Open - No action required
Thursday, September 9, 2021	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	4 - Open - No action required
Tuesday, March 14, 2023	C. David Naylor Building	NL212	NL - 2nd Floor All-Gender Washroom	ND - Open - Normal operations with preventive maintenance
Wednesday, July 14, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sinks	ND - Open - No action required
Friday, September 11, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	ND - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	ND - Open - Normal operations with preventive maintenance
Friday, September 18, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	8.5 - Open - No action required

Level	GU/ml
1	<10
2	10-100
3	>100

GU = Genomic Units

Thursday, October 15, 2020	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	15 - Open - Normal operations with preventive maintenance
Thursday, May 6, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	ND - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	1.8 - Open - No action required
Thursday, September 9, 2021	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	ND - Open - No action required
Tuesday, March 14, 2023	C. David Naylor Building	NL217	NL - 2nd Floor Lab Sink	4 - Open - No action required
Friday, September 18, 2020	C. David Naylor Building	NL221	NL - 2nd Floor Research Kitchen Lab	5.4 - Open - No action required
Thursday, September 9, 2021	C. David Naylor Building	NL221	NL - 2nd Floor Research Kitchen Lab	ND - Open - No action required
Thursday, September 15, 2020	C. David Naylor Building	NL324	NL - 3rd Floor All-Gender Accessible Washroom	34 - Open - Normal operations with preventive maintenance
Monday, September 21, 2020	C. David Naylor Building	NL324	NL - 3rd Floor All-Gender Accessible Washroom	11 - Open - Normal operations with preventive maintenance
Thursday, May 6, 2021	C. David Naylor Building	NL324	NL - 3rd Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, March 14, 2023	C. David Naylor Building	NL324	NL - 3rd Floor All-Gender Accessible Washroom	3.8 - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL308	NL - 3rd Floor Kitchen	3.3 - Open - No action required
Tuesday, March 14, 2023	C. David Naylor Building	NL308	NL - 3rd Floor Kitchen	76 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building	NL326A	NL - 3rd Floor Men's Washroom	ND - Open - No action required
Friday, September 11, 2020	C. David Naylor Building	NL4A	NL - Basement Accessible Washroom	20 - Open - Normal operations with preventive maintenance
Sunday, September 13, 2020	C. David Naylor Building	NL4A	NL - Basement Accessible Washroom	37 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building	NL4A	NL - Basement Accessible Washroom	6 - Open - No action required
Friday, October 2, 2020	C. David Naylor Building	NL4A	NL - Basement Accessible Washroom	4.7 - Open - No action required
Thursday, May 6, 2021	C. David Naylor Building	NL4A	NL - Basement Accessible Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL11	NL - Basement Kitchen	5.8 - Open - No action required
Tuesday, September 15, 2020	C. David Naylor Building	NL11	NL - Basement Kitchen	3.6 - Open - No action required
Thursday, May 6, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	ND - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	39 - Open - Normal operations with preventive maintenance
Thursday, September 9, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	52 - Open - Normal operations with preventive maintenance
Thursday, September 23, 2021	C. David Naylor Building	NL11	NL - Basement Kitchen	ND - Open - No action required
Tuesday, March 14, 2023	C. David Naylor Building	NL11	NL - Basement Kitchen	15 - Open - Normal operations with preventive maintenance
Sunday, September 13, 2020	C. David Naylor Building	NL5A	NL - Basement Men's Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL5B	NL - Basement Women's Washroom	12 - Open - Normal operations with preventive maintenance
Tuesday, September 15, 2020	C. David Naylor Building	NL5B	NL - Basement Women's Washroom	6.3 - Open - No action required
Thursday, October 15, 2020	C. David Naylor Building	NL5B	NL - Basement Women's Washroom	4.3 - Open - No action required
Wednesday, July 14, 2021	C. David Naylor Building	NL5B	NL - Basement Women's Washroom	ND - Open - No action required
Sunday, September 13, 2020	C. David Naylor Building	NL	NL - Water Fountain in the Basement	ND - Open - No action required
Wednesday, October 28, 2020	Canadiana Gallery	CG146	CG - 1st Floor All-Gender Washroom	4 - Open - No action required
Wednesday, December 9, 2020	Canadiana Gallery	CG146	CG - 1st Floor All-Gender Washroom	29 - Open - Normal operations with preventive maintenance
Thursday, January 28, 2021	Canadiana Gallery	CG146	CG - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, February 17, 2021	Canadiana Gallery	CG146	CG - 1st Floor All-Gender Washroom	ND - Open - No action required
Tuesday, August 2, 2022	Canadiana Gallery	CG146	CG - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 28, 2020	Canadiana Gallery	CG200	CG - 2nd Floor Kitchen	ND - Open - No action required
Thursday, October 11, 2022	Canadiana Gallery	CG1819	CG - 2nd Floor All-Gender Washroom	ND - Open - No action required
Thursday, January 28, 2021	Canadiana Gallery	CG52	CG - Basement Kitchen	7.6 - Open - No action required
Wednesday, February 17, 2021	Canadiana Gallery	CG52	CG - Basement Kitchen	ND - Open - No action required
Tuesday, August 2, 2022	Canadiana Gallery	CG52	CG - Basement Kitchen	ND - Open - No action required
Tuesday, September 15, 2020	Canadiana Gallery	CG52	CG - Basement Kitchen	19 - Open - Normal operations with preventive maintenance
Thursday, October 11, 2022	Canadiana Gallery	CG52	CG - Basement Kitchen	6.2 - Open - No action required
Tuesday, December 6, 2022	Canadiana Gallery	CG52	CG - Basement Kitchen	92 - Open - Normal operations with preventive maintenance
Monday, December 19, 2022	Canadiana Gallery	CG52	CG - Basement Kitchen	79 - Open - Normal operations with preventive maintenance
Tuesday, January 31, 2023	Canadiana Gallery	CG52	CG - Basement Kitchen	77 - Open - Normal operations with preventive maintenance
Wednesday, February 21, 2023	Canadiana Gallery	CG52	CG - Basement Kitchen	ND - Open - No action required
Wednesday, February 17, 2021	Canadiana Gallery	CG52A	CG - Basement Men's Washroom	ND - Open - No action required
Thursday, January 28, 2021	Canadiana Gallery	CG61K	CG - Basement Water Fountain Near CG53	ND - Open - No action required
Wednesday, October 28, 2020	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	35 - Open - Normal operations with preventive maintenance
Wednesday, December 9, 2020	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	19 - Open - Normal operations with preventive maintenance
Thursday, January 28, 2021	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	22 - Open - Normal operations with preventive maintenance
Wednesday, February 17, 2021	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	6.4 - Open - No action required
Tuesday, August 2, 2022	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	350 - Closed - Isolation point of use, remediation required
Tuesday, September 13, 2022	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	180 - Closed - Isolation point of use, remediation required
Tuesday, October 11, 2022	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	1.5 - Open - No action required
Tuesday, December 6, 2022	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	1.7 - Open - No action required
Tuesday, January 31, 2023	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	1.6 - Closed - Isolation point of use, remediation required
Tuesday, February 21, 2023	Canadiana Gallery	CG51A	CG - Basement Women's Washroom	1.2 - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - 2nd Floor Shower	160 - Closed - Isolation point of use, remediation required
Tuesday, July 27, 2021	Central Steam Plant		ST - 2nd Floor Shower	ND - Open - No action required
Wednesday, September 15, 2021	Central Steam Plant		ST - 2nd Floor Shower	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - 2nd Floor Shower	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - Chemical room	ND - Open - No action required
Thursday, October 29, 2020	Central Steam Plant		ST - Lunchroom sink	ND - Open - No action required
Tuesday, March 7, 2023	Centre for Biological Timing and Cognition (CBTC)	RW154	RW - 1st Floor Kitchen	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)	RW171	RW - 1st Floor Men's Washroom	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)	RW170	RW - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, March 7, 2023	Centre for Biological Timing and Cognition (CBTC)	RW286	RW - 2nd Floor All-Gender Accessible Washroom (Left of Water Fountain)	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)	RW284	RW - 2nd Floor All-Gender Accessible Washroom (Right of Water Fountain)	ND - Open - No action required
Wednesday, May 19, 2021	Centre for Biological Timing and Cognition (CBTC)	RW278	RW - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, March 7, 2023	Centre for Biological Timing and Cognition (CBTC)	RW380	RW - 3rd Floor Lab Sink Near Exit	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-30	C11001	C1 - 9th Floor Apartment Bathroom Sink	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-30	C11424	C1 - 14th Floor Kitchen	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-30	C11424	C1 - 14th Floor Shower	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-30	C11621	C1 - 16th Floor Apartment Shower	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-30	C11907	C1 - 19th Floor Apartment Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-35	C21218	C2 - 17th Floor Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-30	C1425	C1 - 4th Floor Washroom	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-30	C1717	C1 - 7th Floor Apartment Kitchen Sink	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-35	C21005	C2 - 10th Floor Apartment Kitchen Sink	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-35	C21109	C2 - 11th Floor Apartment Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-35	C21114	C2 - 11th Floor Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-35	C21507	C2 - 15th Floor Shower	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-35	C21717	C2 - 17th Floor Apartment Bathroom Sink	ND - Open - No action required
Tuesday, November 30, 2021	Charles St. West-35	C22001	C2 - 20th Floor Apartment Shower	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-35	C2706	C2 - 7th Floor Kitchen	ND - Open - No action required
Thursday, March 11, 2021	Charles St. West-35	CN1025	CN - 10th Floor Washroom Sink	ND - Open - No action required
Friday, May 28, 2021	Chestnut Residence and Conference Centre	CN1643	CN - 16th Floor Washroom Sink	ND - Open - No action required
Friday, May 28, 2021	Chestnut Residence and Conference Centre	CN2428	CN - 24th Floor Washroom Shower Spout (Tap)	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building	BN1	BN - 1st Floor Pool All-Gender Washroom Near BN107D	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN107D	BN - 1st Floor Pool Shower Near BN107D	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building	BN107B	BN - 1st Floor Staff Shower	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN107B	BN - 1st Floor Staff Shower	8 - Open - No action required
Friday, June 24, 2022	Clara Benson Building	BN107B	BN - 1st Floor Staff Shower	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN224	BN - 2nd Floor All-Gender Washroom	18 - Open - Normal operations with preventive maintenance
Friday, October 8, 2021	Clara Benson Building	BN224	BN - 2nd Floor All-Gender Washroom	24 - Open - Normal operations with preventive maintenance
Friday, June 24, 2022	Clara Benson Building	BN224	BN - 2nd Floor All-Gender Washroom	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building	BN	BN - 2nd Floor Women's Washroom	ND - Open - No action required
Friday, October 1, 2021	Clara Benson Building	BN316	BN - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, January 18, 2021	Clara Benson Building	BN137	BN - All-Gender Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Claude T. Bissell Building	109	BL - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Claude T. Bissell Building	226	BL - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, September 16, 2021	Claude T. Bissell Building	BL321	BL - 3rd Floor Kitchen	ND - Open - No action required
Thursday, September 16, 2021	Claude T. Bissell Building	BL407A	BL - 4th Floor Staff Washroom	ND - Open - No action required
Thursday, September 16, 2021	Claude T. Bissell Building	BL684	BL - 6th Floor Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Claude T. Bissell Building	729	BL - 7th Floor Kitchen	ND - Open - No action required
Wednesday, January 20, 2021	College Street-229		CZ - 1st Floor Men's Washroom	ND - Open - No action required
Thursday, December 17, 2020	College Street-229		CZ - 2nd Floor Kitchen	ND - Open - No action required
Thursday, December 17, 2020	College Street-229		CZ - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, December 17, 2020	College Street-229		CZ - 2nd Floor Women's Washroom	5.6 - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, January 20, 2021	College Street-229		CZ - 3rd Floor Kitchen	ND - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, October 4, 2021	College Street-229		CZ - 5th Floor Kitchen	ND - Open - No action required
Wednesday, January 20, 2021	College Street-229		CZ - 5th Floor Staff Men's Washroom	ND - Open - No action required
Thursday, October 4, 2021	College Street-229		CZ - 2nd Floor Staff Women's Washroom	ND - Open - No action required
Thursday, November 26, 2020	College Street-88	ZC119	ZC - 1st Floor Kitchen	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC110	ZC - 1st Floor Men's Washroom	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC106	ZC - 1st Floor Office Kitchenette	ND - Open - No action required
Thursday, November 26, 2020	College Street-88	ZC105	ZC - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, November 26, 2020	College Street-88	ZC104	ZC - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, November 29, 2022	College Street-88	ZC210A	ZC - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, November 26, 2020	College Street-88	ZC203	ZC - 2nd Floor Office Kitchen	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC203	ZC - 2nd Floor Office Kitchen	ND - Open - No action required
Monday, September 20, 2021	College Street-88	ZC211A	ZC - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX125A	CX - 1st Floor Kitchen	ND - Open - No action required
Friday, February 21, 2023	Communications House	CX125A	CX - 1st Floor Kitchen	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX226	CX - 2nd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, February 21, 2023	Communications House	CX226	CX - 2nd Floor All-Gender Washroom	1.1 - Open - No action required
Wednesday, September 15, 2021	Communications House	CX203	CX - 2nd Floor Janitor's Closet	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX224A	CX - 2nd Floor Kitchen	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX006	CX - Basement Kitchen	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX013	CX - Basement Men's Washroom	ND - Open - No action required
Tuesday, February 21, 2023	Communications House	CX013	CX - Basement Men's Washroom	ND - Open - No action required
Monday, October 26, 2020	Communications House	CX015	CX - Basement Women's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	Communications House	CX015	CX - Basement Women's Washroom	ND - Open - No action required
Friday, October 2, 2020	Convocation Hall	CH112	CH - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, February 28, 2023	Convocation Hall	CH112	CH - 1st Floor All-Gender Accessible Washroom	ND - Open - No action required

Wednesday, August 25, 2021	Convocation Hall		CH - 1st Floor Men's Washroom (S1124)	ND - Open - No action required
Friday, October 2, 2020	Convocation Hall		CH - 1st Floor Women's Washroom (S1142)	ND - Open - No action required
Tuesday, February 28, 2023	Convocation Hall		CH - 1st Floor Women's Washroom (S1142)	ND - Open - No action required
Tuesday, October 13, 2020	Cumberland House	CU107A	CU - 1st Floor Accessible Washroom	11 - Open - Normal operations with preventive maintenance
Monday, June 7, 2021	Cumberland House	CU107A	CU - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, October 25, 2021	Cumberland House	CU107A	CU - 1st Floor Accessible Washroom	ND - Open - No action required
Tuesday, October 13, 2020	Cumberland House	CU105	CU - 1st Floor Women's Washroom	8 - 3 - Open - No action required
Monday, June 7, 2021	Cumberland House	CU105	CU - 1st Floor Women's Washroom	ND - Open - No action required
Monday, October 25, 2021	Cumberland House	CU105	CU - 1st Floor Women's Washroom	ND - Open - No action required
Monday, October 25, 2021	Cumberland House	CU251	CU - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, October 13, 2020	Cumberland House		CU - Basement Men's Washroom	ND - Open - No action required
Tuesday, February 14, 2023	D.L. Pratt Building	PT175	PT - 1st Floor Lab Sink	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT179	PT - 1st Floor Office Kitchen	ND - Open - No action required
Tuesday, February 14, 2023	D.L. Pratt Building	PT272A	PT - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT261K	PT - 2nd Floor Water Fountain Near PT263	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT379	PT - 3rd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT392	PT - 3rd Floor Electrical Engineering Graduate Office Kitchenette	ND - Open - No action required
Tuesday, February 14, 2023	D.L. Pratt Building	PT371K	PT - 3rd Floor Water Fountain Near PT372	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT471	PT - 4th Floor All-Gender Washroom	ND - Open - No action required
Tuesday, February 14, 2023	D.L. Pratt Building	PT473	PT - 4th Floor Meeting Room	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT474A	PT - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, October 21, 2020	D.L. Pratt Building	PT77	PT - Basement Lab Sink	ND - Open - No action required
Wednesday, September 15, 2021	D.L. Pratt Building	PT67	PT - Basement Lab Sink	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building	DA113	DA - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, November 22, 2022	Daniels Building	DA171	DA - 1st Floor Sink Beside Cafe 059	ND - Open - No action required
Monday, December 7, 2020	Daniels Building	DA198	DA - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, November 22, 2022	Daniels Building	DA212	DA - 2nd Floor All-Gender Washroom	ND - Open - No action required
Monday, December 7, 2020	Daniels Building	DA298	DA - 2nd Floor Student Lounge Kitchen	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building	DA290K	DA - 2nd Floor Undergrad Studio Kitchenette (East) Near DA200	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building	DA250K	DA - 2nd Floor Undergrad Studio Kitchenette (West) Near DA250	ND - Open - No action required
Tuesday, November 22, 2022	Daniels Building	DA365K	DA - 3rd Floor Graduate Studio Kitchenette (West) Near DA365	ND - Open - No action required
Monday, December 7, 2020	Daniels Building	DA32A	DA - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, November 22, 2022	Daniels Building	DA262	DA - Basement Men's Washroom	ND - Open - No action required
Wednesday, September 8, 2021	Daniels Building	DN180	DN - 1st Floor Men's Washroom	62 - Open - Normal operations with preventive maintenance
Monday, September 28, 2020	Dentistry Building	DN180	DN - 1st Floor Men's Washroom	39 - Open - Normal operations with preventive maintenance
Friday, October 2, 2020	Dentistry Building	DN180	DN - 1st Floor Men's Washroom	10 - Open - Normal operations with preventive maintenance
Tuesday, November 24, 2020	Dentistry Building	DN180	DN - 1st Floor Men's Washroom	23 - Open - Normal operations with preventive maintenance
Wednesday, January 6, 2021	Dentistry Building	DN180	DN - 1st Floor Men's Washroom	ND - Open - No action required
Friday, March 19, 2021	Dentistry Building	DN180	DN - 1st Floor Men's Washroom	ND - Open - No action required
Thursday, June 2, 2022	Dentistry Building	DN180	DN - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	71 - Open - Normal operations with preventive maintenance
Wednesday, January 6, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	25 - Open - Normal operations with preventive maintenance
Tuesday, January 12, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	12 - Open - Normal operations with preventive maintenance
Tuesday, January 26, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	42 - Open - Normal operations with preventive maintenance
Friday, March 19, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	7 - 1 - Open - No action required
Monday, March 29, 2021	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	7 - 6 - Open - No action required
Thursday, June 2, 2022	Dentistry Building	DN175	DN - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	10 - 0 - Closed - Isolation point of use, remediation required
Wednesday, January 6, 2021	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	ND - Open - No action required
Monday, January 11, 2021	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	9 - Open - No action required
Tuesday, January 26, 2021	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	36 - Open - Normal operations with preventive maintenance
Friday, March 19, 2021	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	30 - Open - Normal operations with preventive maintenance
Monday, March 29, 2021	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, June 2, 2022	Dentistry Building	DN263	DN - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN254	DN - 2nd Floor Women's Washroom	3 - 8 - Open - No action required
Wednesday, January 6, 2021	Dentistry Building	DN254	DN - 2nd Floor Women's Washroom	ND - Open - No action required
Monday, January 11, 2021	Dentistry Building	DN254	DN - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, June 2, 2022	Dentistry Building	DN254	DN - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, September 28, 2020	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	62 - Open - Normal operations with preventive maintenance
Friday, October 2, 2020	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	10 - Open - Normal operations with preventive maintenance
Tuesday, November 24, 2020	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	3 - 4 - Open - No action required
Monday, January 11, 2021	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	63 - Open - Normal operations with preventive maintenance
Tuesday, January 26, 2021	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	6 - 8 - Open - No action required
Friday, March 19, 2021	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	ND - Open - No action required
Thursday, June 2, 2022	Dentistry Building	DN357	DN - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, January 26, 2021	Dentistry Building		DN - 4th Floor All-Gender Accessible Across Kitchen	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building		DN - 4th Floor Kitchen	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building		DN - 4th Floor Lab Sink	ND - Open - No action required
Monday, September 28, 2020	Dentistry Building		DN - 4th Floor Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building	DN410	DN - Lap Tab	ND - Open - No action required
Monday, September 28, 2020	Dentistry Building		DN - Shower Inside Women's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	Dentistry Building	DN228	DN - Water Fountain in DN228	ND - Open - No action required
Tuesday, November 24, 2020	Dentistry Building	DN244	DN - Women's Washroom	1 - Open - No action required
Wednesday, September 28, 2020	Dr. Eric Jackman Institute of Child Study	WR121	WR - 1st Floor All-Gender Washroom	2 - 4 - Open - Normal operations with preventive maintenance
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child Study	WR237	WR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, April 21, 2021	Dr. Eric Jackman Institute of Child Study	WR237	WR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, September 28, 2022	Dr. Eric Jackman Institute of Child Study	WR262	WR - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child Study	WR330	WR - 3rd Floor All-Gender Washroom	30 - Open - Normal operations with preventive maintenance
Thursday, April 15, 2021	Dr. Eric Jackman Institute of Child Study	WR330	WR - 3rd Floor All-Gender Washroom	42 - Open - Normal operations with preventive maintenance
Wednesday, April 21, 2021	Dr. Eric Jackman Institute of Child Study	WR330	WR - 3rd Floor All-Gender Washroom	1 - 5 - Open - No action required
Wednesday, September 28, 2022	Dr. Eric Jackman Institute of Child Study	WR330	WR - 3rd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, September 28, 2022	Dr. Eric Jackman Institute of Child Study	WR381	WR - 3rd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child Study	WR124	WR - All-Gender Washroom	ND - Open - No action required
Thursday, April 15, 2021	Dr. Eric Jackman Institute of Child Study	WR124	WR - All-Gender Washroom	ND - Open - No action required
Wednesday, January 27, 2021	Dr. Eric Jackman Institute of Child Study	WR76	WR - Basement Kitchen	ND - Open - No action required
Wednesday, September 28, 2022	Dr. Eric Jackman Institute of Child Study	WR77	WR - Basement Men's Washroom	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		ER - 1st Floor All-Gender Accessible Washroom (Adult)	ND - Open - No action required
Tuesday, October 25, 2022	Early Learning Centre	ER110	ER - 1st Floor Classroom	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		ER - 1st Floor Kitchen (Food Prep)	ND - Open - No action required
Tuesday, October 25, 2022	Early Learning Centre	ER212	ER - 2nd Floor Classroom	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre		ER - 2nd Floor Kitchen	ND - Open - No action required
Thursday, March 25, 2021	Early Learning Centre	ER302	ER - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, October 25, 2022	Early Learning Centre	ER304	ER - 3rd Floor Staff Lounge Kitchen	ND - Open - No action required
Tuesday, October 25, 2022	Early Learning Centre	ER1	ER - Basement Classroom	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ES1024	ES - North 1st Floor Lab Sink (Right)	ND - Open - No action required
Tuesday, February 21, 2023	Earth Sciences Centre	ES1013	ES - North 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES1033	ES - North 1st Women's Washroom	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ES2056	ES - North 2nd Floor Lab Sink (Left)	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES2054	ES - North 2nd Floor Student Lounge Kitchen	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ES3042	ES - North 3rd Floor Kitchen	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES3073K	ES - North 3rd Floor Water Fountain Near ES3062	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES4076	ES - North 4th Floor Lab Sink	ND - Open - No action required
Tuesday, February 21, 2023	Earth Sciences Centre	ES4051	ES - North 4th Floor Men's Washroom	ND - Open - No action required
Tuesday, February 21, 2023	Earth Sciences Centre	ES3013	ES - North 5th Floor Tool Room Sink	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ESB111	ES - North Basement Senescence Room Sink	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ES1067	ES - South 1st Floor Lab Sink	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES1060K	ES - South 1st Floor Water Fountain Near ES1070	ND - Open - No action required
Tuesday, February 21, 2023	Earth Sciences Centre	ES2095	ES - South 2nd Floor Lab Sink	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ES2100K	ES - South 2nd Floor Water Fountain Near ES2116	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES3119	ES - South 3rd Floor Student Lounge Kitchen	ND - Open - No action required
Tuesday, February 21, 2023	Earth Sciences Centre	ES3100K	ES - South 3rd Floor Water Fountain Near ES3117	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ES4107	ES - South 4th Floor Lounge Kitchenette	ND - Open - No action required
Tuesday, November 3, 2020	Earth Sciences Centre	ES4106	ES - South 4th Floor Men's Washroom	ND - Open - No action required
Friday, August 27, 2021	Earth Sciences Centre	ESB172	ES - South Basement All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, February 21, 2023	Earth Sciences Centre	ESB172	ES - South Basement All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Edward Johnson Building	EJ124A	EJ - 1st Floor Men's Washroom	ND - Open - No action required
Thursday, November 26, 2020	Edward Johnson Building	EJ106A	EJ - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, November 26, 2020	Edward Johnson Building	EJ209K	EJ - 2nd Floor Fountain Near EJ230	ND - Open - No action required
Tuesday, October 5, 2021	Edward Johnson Building	EJ1229	EJ - 2nd Floor Men's Staff Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Edward Johnson Building	EJ209K	EJ - 2nd Floor Water Fountain Near EJ257	ND - Open - No action required
Tuesday, November 8, 2022	Edward Johnson Building	EJ203	EJ - 2nd Floor Women's Staff Washroom	ND - Open - No action required
Thursday, November 26, 2020	Edward Johnson Building		EJ - Basement Men's Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Edward Johnson Building	EJ074A	EJ - Sub-basement Men's Washroom	ND - Open - No action required
Tuesday, October 5, 2021	Edward Johnson Building	ESJ098	EJ - Sub-basement Sink Inside Instrument Room	ND - Open - No action required
Tuesday, October 5, 2021	Edward Johnson Building		EJ - Sub-basement Water Fountain Near EJ073A	ND - Open - No action required
Wednesday, November 4, 2020	Electrometallurgy Lab		EL - Washroom	ND - Open - No action required
Monday, October 25, 2021	Electrometallurgy Lab		EL - Washroom	ND - Open - No action required
Thursday, October 29, 2020	Engineering Annex	EA107	EA - 1st Floor Kitchenette Inside EA107	11 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	Engineering Annex	EA107	EA - 1st Floor Kitchen Inside EA107	ND - Open - No action required
Tuesday, May 18, 2021	Engineering Annex	EA107	EA - 1st Floor Kitchenette Inside EA107	ND - Open - No action required
Friday, June 10, 2022	Engineering Annex	EA107	EA - 1st Floor Kitchenette Inside EA107	ND - Open - No action required
Thursday, February 18, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	18 - Open - Normal operations with preventive maintenance
Monday, April 19, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	18 - Open - Normal operations with preventive maintenance
Tuesday, May 4, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, May 18, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, July 29, 2021	Engineering Annex	EA102	EA - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, October 29, 2020	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	00 - Closed - Isolation point of use, remediation required
Thursday, February 18, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	10 - 0 - Closed - Isolation point of use, remediation required
Monday, April 19, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	38 - Open - Normal operations with preventive maintenance
Tuesday, May 4, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	63 - Open - Normal operations with preventive maintenance
Tuesday, May 18, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, July 7, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	82 - Open - Normal operations with preventive maintenance

Thursday, July 29, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	20 - Open - Normal operations with preventive maintenance
Monday, August 9, 2021	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	7.2 - Open - No action required
Friday, June 10, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	98 - Open - Normal operations with preventive maintenance
Tuesday, June 28, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	24 - Open - Normal operations with preventive maintenance
Thursday, July 14, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	34 - Open - Normal operations with preventive maintenance
Thursday, July 28, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	42 - Open - Normal operations with preventive maintenance
Monday, August 15, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, September 13, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	1.1 - Open - No action required
Tuesday, October 4, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	18 - Open - Normal operations with preventive maintenance
Tuesday, October 25, 2022	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	6.8 - Open - No action required
Tuesday, March 14, 2023	Engineering Annex	EA204	EA - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, October 29, 2020	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	26 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	22 - Open - Normal operations with preventive maintenance
Monday, April 19, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	67 - Open - Normal operations with preventive maintenance
Tuesday, May 4, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	180 - Closed - Isolation point of use, remediation required
Tuesday, May 18, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	260 - Closed - Isolation point of use, remediation required
Wednesday, July 7, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	770 - Closed - Isolation point of use, remediation required
Thursday, July 29, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	800 - Closed - Isolation point of use, remediation required
Monday, August 9, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	24 - Open - Normal operations with preventive maintenance
Monday, November 29, 2021	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	8.4 - Open - No action required
Friday, June 10, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	2100 - Closed - Isolation point of use, remediation required
Tuesday, June 28, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	290 - Closed - Isolation point of use, remediation required
Thursday, July 14, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	90 - Open - Normal operations with preventive maintenance
Thursday, July 28, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	21 - Open - Normal operations with preventive maintenance
Monday, August 15, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	34 - Open - Normal operations with preventive maintenance
Tuesday, September 13, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	80 - Open - Normal operations with preventive maintenance
Tuesday, October 4, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	13 - Open - Normal operations with preventive maintenance
Tuesday, October 25, 2022	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	7.8 - Open - No action required
Tuesday, March 14, 2023	Engineering Annex	EA307	EA - 3rd Floor Men's Washroom	ND - Open - No action required
Thursday, October 29, 2020	Engineering Annex	EA307	EA - Water Fountain Near EA205	ND - Open - No action required
Tuesday, January 12, 2021	Enrollment Services	AD -	AD - 1st Floor Kitchen	ND - Open - No action required
Tuesday, October 18, 2022	Enrollment Services	AD119	AD - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, October 18, 2022	Enrollment Services	AD219A	AD - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, January 12, 2021	Enrollment Services	AD219	AD - 2nd Floor Men's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Enrollment Services	AD217	AD - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Enrollment Services	AD319	AD - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, January 12, 2021	Enrollment Services	AD317	AD - 3rd Floor Women's Washroom	ND - Open - No action required
Tuesday, October 18, 2022	Enrollment Services	AD317	AD - 3rd Floor Men's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Enrollment Services	AD319A	AD - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, October 18, 2022	Enrollment Services	AD419	AD - 4th Floor Men's Washroom	ND - Open - No action required
Tuesday, March 21, 2023	Exam Centre	EX136	EX - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, November 5, 2020	Exam Centre	EX242	EX - 2nd Floor All-Gender Washroom	ND - Open - No action required
Friday, October 22, 2021	Exam Centre	EX294	EX - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, March 21, 2023	Exam Centre	EX292	EX - 2nd Floor Women's Washroom	ND - Open - No action required
Tuesday, March 21, 2023	Exam Centre	EX347	EX - 3rd Floor All-Gender Accessible Washroom (Right)	2.1 - Open - No action required
Friday, October 22, 2021	Exam Centre	EX388	EX - 3rd Floor Kitchen	ND - Open - No action required
Thursday, November 5, 2020	Exam Centre	EX332	EX - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, November 5, 2020	Exam Centre	EX -	EX - 4th Floor Kitchen	ND - Open - No action required
Friday, October 22, 2021	Exam Centre	EX451	EX - 4th Floor Men's Washroom	12 - Open - Normal operations with preventive maintenance
Wednesday, October 27, 2021	Exam Centre	EX451	EX - 4th Floor Men's Washroom	22 - Open - Normal operations with preventive maintenance
Thursday, February 24, 2022	Exam Centre	EX451	EX - 4th Floor Men's Washroom	2.1 - Open - No action required
Thursday, March 10, 2022	Exam Centre	EX451	EX - 4th Floor Men's Washroom	ND - Open - No action required
Thursday, March 24, 2022	Exam Centre	EX451	EX - 4th Floor Men's Washroom	1 - Open - No action required
Tuesday, March 21, 2023	Exam Centre	EX451	EX - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, October 27, 2021	Exam Centre	EX451	EX - 4th Floor Men's Washroom Accessible Stall Sink	14 - Open - Normal operations with preventive maintenance
Thursday, February 24, 2022	Exam Centre	EX451	EX - 4th Floor Men's Washroom Accessible Stall Sink	ND - Open - No action required
Thursday, March 10, 2022	Exam Centre	EX451	EX - 4th Floor Men's Washroom Accessible Stall Sink	ND - Open - No action required
Thursday, March 24, 2022	Exam Centre	EX451	EX - 4th Floor Men's Washroom Accessible Stall Sink	ND - Open - No action required
Wednesday, October 27, 2021	Exam Centre	EX453	EX - 4th Floor Women's Washroom	ND - Open - No action required
Thursday, February 24, 2022	Exam Centre	EX453	EX - 4th Floor Women's Washroom	ND - Open - No action required
Thursday, March 10, 2022	Exam Centre	EX453	EX - 4th Floor Women's Washroom	ND - Open - No action required
Thursday, March 24, 2022	Exam Centre	EX453	EX - 4th Floor Women's Washroom	ND - Open - No action required
Wednesday, December 3, 2020	Factor-Inventash Faculty of Social Work	SK137K	SK - 1st Floor Water Fountain	ND - Open - No action required
Wednesday, November 10, 2022	Factor-Inventash Faculty of Social Work	SK157K	SK - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, October 14, 2021	Factor-Inventash Faculty of Social Work	SK237	SK - 2nd Floor Men's Washroom	3.1 - Open - No action required
Thursday, December 3, 2020	Factor-Inventash Faculty of Social Work	SK313	SK - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, October 14, 2021	Factor-Inventash Faculty of Social Work	SK320A	SK - 3rd Floor Kitchennette Inside Lounge	ND - Open - No action required
Wednesday, November 24, 2022	Factor-Inventash Faculty of Social Work	SK444	SK - 4th Floor Kitchen	8 - Open - No action required
Thursday, October 14, 2021	Factor-Inventash Faculty of Social Work	SK47K	SK - 4th Floor Water Fountain	ND - Open - No action required
Wednesday, November 2, 2022	Factor-Inventash Faculty of Social Work	SK613	SK - 6th Floor All-Gender Washroom	4.9 - Open - No action required
Thursday, December 3, 2020	Factor-Inventash Faculty of Social Work	SK705	SK - 7th Floor Women's Washroom	ND - Open - No action required
Wednesday, November 2, 2022	Factor-Inventash Faculty of Social Work	SK37	SK - Basement Men's Washroom	5.1 - Open - No action required
Thursday, March 25, 2021	Faculty Club	FC -	FC - 1st Floor Accessible Washroom	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC103	FC - 1st Floor Bar Sink by Accessible Washroom	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC107	FC - 1st Floor Dining Hall Bar Sink	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club	FC -	FC - 1st Floor Kitchen	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC -	FC - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, November 25, 2021	Faculty Club	FC14	FC - Basement Men's Changing Room	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club	FC -	FC - Basement Pub Tap	ND - Open - No action required
Thursday, March 25, 2021	Faculty Club	FC -	FC - Basement Women's Washroom	ND - Open - No action required
Monday, December 14, 2020	Faculty of Law	LWJ102	LW - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Faculty of Law	LWJ102	LW - 1st Floor Men's Washroom	ND - Open - No action required
Friday, December 3, 2021	Faculty of Law	LWJ100	LW - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Faculty of Law	LWJ211	LW - 2nd Floor Kitchennette	ND - Open - No action required
Tuesday, April 20, 2021	Faculty of Law	LWJ222	LW - 2nd Floor Women's Washroom	ND - Open - No action required
Friday, December 3, 2021	Faculty of Law	LWJ347	LW - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, April 20, 2021	Faculty of Law	LWJ317	LW - 3rd Floor Kitchennette	ND - Open - No action required
Tuesday, November 8, 2022	Faculty of Law	LWJ336	LW - 3rd Floor Women's Washroom	2.2 - Open - No action required
Tuesday, April 20, 2021	Faculty of Law	LWJ433	LW - 4th Floor All-Gender Washroom	ND - Open - No action required
Friday, December 3, 2021	Faculty of Law	LWJ475	LW - 4th Floor All-Gender Washroom	ND - Open - No action required
Friday, December 3, 2021	Faculty of Law	LWJ417	LW - 4th Floor Kitchen	ND - Open - No action required
Tuesday, November 8, 2022	Faculty of Law	LWJ401K	LW - 4th Floor Kitchennette	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall	FA107A	FH - 1st Floor Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall	FH -	FH - 2nd Floor Washroom	5.8 - Open - No action required
Friday, June 25, 2021	Falconer Hall	FH -	FH - 2nd Floor Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall	FH -	FH - 3rd Floor All-Gender Washroom	ND - Open - No action required
Thursday, April 8, 2021	Falconer Hall	FA10	FH - Basement Female Washroom	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building	LG110	LG - 1st Floor All-Gender Washroom	ND - Open - No action required
Thursday, October 29, 2020	Fasken Martineau Building	LG110	LG - 1st Floor All-Gender Washroom	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG207	LG - 2nd Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, October 25, 2022	Fasken Martineau Building	LG200	LG - 2nd Floor Conference Room	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building	LG211	LG - 2nd Floor Family Law Division Office	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG318	LG - 3rd Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, October 25, 2022	Fasken Martineau Building	LG311	LG - 3rd Floor All-Gender Washroom Shower	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building	LG317	LG - 3rd Floor Criminal Law Office	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG314	LG - 3rd Floor Office	ND - Open - No action required
Tuesday, October 25, 2022	Fasken Martineau Building	LG12A	LG - Basement All-Gender Washroom	ND - Open - No action required
Thursday, February 25, 2021	Fasken Martineau Building	LG18	LG - Basement Kitchen	ND - Open - No action required
Thursday, November 25, 2021	Fasken Martineau Building	LG18	LG - Basement Kitchen	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	F1106	F1 - 1st Floor Kitchen	ND - Open - No action required
Tuesday, November 8, 2022	Fields Inst for Research in Math Science	F1105K	F1 - 1st Floor Water Fountain Near F1157	1.7 - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	F1157	F1 - 1st Floor Women's Washroom	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	F204	F1 - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, November 8, 2022	Fields Inst for Research in Math Science	F208	F1 - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	F208K	F1 - 2nd Floor Water Fountain Near F206	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	F305	F1 - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	F347	F1 - 3rd Floor Women's Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Fields Inst for Research in Math Science	F347	F1 - 3rd Floor Women's Washroom	ND - Open - No action required
Tuesday, October 27, 2020	Fields Inst for Research in Math Science	F447	F1 - 4th Floor All-Gender Washroom	ND - Open - No action required
Monday, September 13, 2021	Fields Inst for Research in Math Science	F447	F1 - 4th Floor All-Gender Washroom	ND - Open - No action required
Tuesday, November 8, 2022	Fields Inst for Research in Math Science	F405	F1 - 4th Floor All-Gender Washroom	ND - Open - No action required
Monday, December 14, 2020	Flavelle House	FL222	FL - 2nd Floor Kitchen	ND - Open - No action required
Wednesday, June 2, 2021	Flavelle House	FL222	FL - 2nd Floor Kitchen	6.4 - Open - No action required
Thursday, July 22, 2021	Flavelle House	FL222	FL - 2nd Floor Kitchen	ND - Open - No action required
Monday, December 14, 2020	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	80 - Open - Normal operations with preventive maintenance
Monday, March 15, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	40 - Open - Normal operations with preventive maintenance
Thursday, April 20, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	26 - Open - Normal operations with preventive maintenance
Wednesday, June 2, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	170 - Closed - Isolation point of use, remediation required
Monday, June 20, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	26 - Closed - Isolation point of use, remediation required
Thursday, July 22, 2021	Flavelle House	FL336	FL - 3rd Floor Women's Washroom	ND - Open - No action required
Monday, March 15, 2021	Flavelle House	FL134	LW - 1st Floor Kitchen	ND - Open - No action required
Thursday, November 12, 2020	Gage Building	GA101	GA - 1st Floor Accessible Washroom	30 - Open - Normal operations with preventive maintenance
Monday, January 25, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	800 - Closed - Isolation point of use, remediation required
Tuesday, March 2, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	48 - Open - Normal operations with preventive maintenance
Monday, March 8, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	74 - Open - Normal operations with preventive maintenance
Monday, March 22, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	13 - Open - Normal operations with preventive maintenance
Monday, March 29, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Wednesday, April 7, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, April 19, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, April 26, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required
Monday, May 17, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	5.6 - Open - No action required
Tuesday, May 25, 2021	Gage Building	GA101	GA - 1st Floor Accessible Washroom	ND - Open - No action required







Wednesday, August 25, 2021	Haultain Building	HA53	HA - Basement Lab Sink	19 - Open - Normal operations with preventive maintenance
Monday, June 6, 2022	Haultain Building	HA53	HA - Basement Lab Sink	ND - Open - No action required
Monday, August 15, 2022	Haultain Building	HA53	HA - Basement Lab Sink	ND - Open - No action required
Tuesday, September 20, 2022	Haultain Building	HA53	HA - Basement Lab Sink	ND - Open - No action required
Tuesday, September 22, 2020	Haultain Building	HA102	HA - Workshop	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS172	HS - 1st Floor Simulation Lab Sink	ND - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS172	HS - 1st Floor Simulation Lab Sink	ND - Open - No action required
Friday, June 3, 2022	Health Sciences Building	HS268	HS - 2nd Floor All-Gender Washroom	9.5 - Open - No action required
Friday, June 10, 2022	Health Sciences Building	HS268	HS - 2nd Floor All-Gender Washroom	ND - Open - No action required
Monday, July 4, 2022	Health Sciences Building	HS268	HS - 2nd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, July 19, 2022	Health Sciences Building	HS268	HS - 2nd Floor All-Gender Washroom	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS391V	HS - 3rd Floor Water Fountain Inside Women's Washroom	ND - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS391V	HS - 3rd Floor Water Fountain Inside Women's Washroom	ND - Open - No action required
Friday, June 3, 2022	Health Sciences Building	HS493	HS - 4th Floor Men's Washroom	ND - Open - No action required
Friday, June 3, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	9 - Open - No action required
Friday, June 10, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	ND - Open - No action required
Monday, July 4, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	19 - Open - Normal operations with preventive maintenance
Tuesday, July 19, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	7.1 - Open - No action required
Tuesday, August 2, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	8.7 - Open - No action required
Tuesday, August 23, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	ND - Open - No action required
Tuesday, September 13, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	16 - Open - Normal operations with preventive maintenance
Tuesday, October 4, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	5.4 - Open - No action required
Tuesday, October 25, 2022	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	8.7 - Open - No action required
Tuesday, March 14, 2023	Health Sciences Building	HS572	HS - 5th Floor Kitchen Inside Staff Lounge	7.8 - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	12 - Open - Normal operations with preventive maintenance
Tuesday, December 8, 2020	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	8.5 - Open - No action required
Tuesday, April 27, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	4.4 - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	ND - Open - No action required
Friday, August 6, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	4.8 - Open - No action required
Wednesday, August 25, 2021	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	28 - Open - Normal operations with preventive maintenance
Friday, June 3, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	3.8 - Open - No action required
Friday, June 10, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	ND - Open - No action required
Monday, July 4, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	2.3 - Open - No action required
Monday, July 19, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	1.1 - Open - No action required
Tuesday, August 2, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	39 - Open - Normal operations with preventive maintenance
Tuesday, August 23, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	8.3 - Open - No action required
Tuesday, September 13, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	3.6 - Open - No action required
Tuesday, October 4, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	19 - Open - Normal operations with preventive maintenance
Tuesday, October 25, 2022	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	7.8 - Open - No action required
Tuesday, March 14, 2023	Health Sciences Building	HS600	HS - 6th Floor Kitchen Inside Staff Lounge	3.7 - Open - No action required
Friday, June 3, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	1800 - Closed - Isolation point of use, remediation required
Friday, June 10, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	34 - Open - Normal operations with preventive maintenance
Wednesday, July 6, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	66 - Open - Normal operations with preventive maintenance
Tuesday, July 19, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	28 - Open - Normal operations with preventive maintenance
Tuesday, August 2, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	7.3 - Open - No action required
Tuesday, August 23, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	ND - Open - No action required
Tuesday, September 13, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	ND - Open - No action required
Tuesday, October 4, 2022	Health Sciences Building	HS726	HS - 7th Floor Women's Washroom	ND - Open - No action required
Monday, October 19, 2020	Health Sciences Building	HS12	HS - Basement All-Gender Washroom (previously Men's Washroom)	ND - Open - No action required
Tuesday, December 8, 2020	Health Sciences Building	HS12	HS - Basement All-Gender Washroom (previously Men's Washroom)	3.4 - Open - No action required
Tuesday, April 27, 2021	Health Sciences Building	HS12	HS - Basement All-Gender Washroom (previously Men's Washroom)	ND - Open - No action required
Tuesday, July 27, 2021	Health Sciences Building	HS12	HS - Basement All-Gender Washroom (previously Men's Washroom)	ND - Open - No action required
Friday, June 3, 2022	Health Sciences Building	HS12	HS - Basement All-Gender Washroom (previously Men's Washroom)	ND - Open - No action required
Friday, August 13, 2021	Huron Street-215	HU2205B	HU - 2nd Floor Men's Locker Room Shower	52 - Open - Normal operations with preventive maintenance
Tuesday, August 24, 2021	Huron Street-215	HU2205B	HU - 2nd Floor Men's Locker Room Shower	ND - Open - No action required
Thursday, September 16, 2021	Huron Street-215	HU2205B	HU - 2nd Floor Men's Locker Room Shower	28 - Open - Normal operations with preventive maintenance
Friday, September 4, 2020	Huron Street-215	HU719V	HU - 7th Floor Men's Washroom	ND - Open - No action required
Friday, September 4, 2020	Huron Street-215	HU715	HU - 7th Floor Women's Washroom	ND - Open - No action required
Friday, August 13, 2021	Huron Street-215	HU920A	HU - 9th Floor Men's Washroom	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN128	IN - 1st Floor All-Gender Near IN131 (Left)	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN102	IN - 1st Floor Innis Cafe Sink (Right)	ND - Open - No action required
Tuesday, November 10, 2020	Innis College		IN - 1st Floor Water Fountain Near 131	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN203	IN - 2nd Floor All-Gender Washroom Near IN204W	ND - Open - No action required
Tuesday, November 10, 2020	Innis College	IN203	IN - 2nd Floor All-Gender Washroom Beside 317E	ND - Open - No action required
Tuesday, November 10, 2020	Innis College	IN130	IN - E WING 1st Floor Kitchen Near 131	ND - Open - No action required
Friday, September 17, 2021	Innis College	IN130	IN - E WING 1st Floor Kitchen Near 131	ND - Open - No action required
Tuesday, November 10, 2020	Innis College		IN - W WING 1st Floor All-Gender Washroom Near Cafe	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS422	IS - Residence Suite Kitchen Sink	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS734	IS - Residence Suite Shower	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS215	IS - Residence Suite Washroom Sink	ND - Open - No action required
Thursday, May 27, 2021	Innis College Student Residence	IS546	IS - Residence Suite Washroom Sink	ND - Open - No action required
Wednesday, December 16, 2020	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	330 - Closed - Isolation point of use, remediation required
Tuesday, April 27, 2021	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	490 - Closed - Isolation point of use, remediation required
Friday, October 8, 2021	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	80 - Closed - Isolation point of use, remediation required
Friday, December 3, 2021	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	190 - Closed - Isolation point of use, remediation required
Monday, January 24, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	640 - Closed - Isolation point of use, remediation required
Friday, February 4, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	220 - Closed - Isolation point of use, remediation required
Thursday, February 24, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	440 - Closed - Isolation point of use, remediation required
Tuesday, March 8, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	80 - Closed - Isolation point of use, remediation required
Tuesday, March 22, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	36 - Open - Normal operations with preventive maintenance
Tuesday, April 5, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	14 - Open - Normal operations with preventive maintenance
Tuesday, April 19, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	12 - Open - Normal operations with preventive maintenance
Friday, May 13, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	ND - Open - No action required
Tuesday, September 13, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	20 - Closed - Isolation point of use, remediation required
Tuesday, October 4, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	120 - Closed - Isolation point of use, remediation required
Tuesday, November 22, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	52 - Open - Normal operations with preventive maintenance
Tuesday, December 13, 2022	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	34 - Open - Normal operations with preventive maintenance
Tuesday, January 17, 2023	J. Robert S. Prichard Alumni House	DR105	DR - 1st Floor All-Gender Washroom	45 - Open - No action required
Wednesday, December 16, 2020	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	11 - Open - Normal operations with preventive maintenance
Tuesday, April 27, 2021	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	28 - Open - Normal operations with preventive maintenance
Friday, May 13, 2022	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	66 - Open - Normal operations with preventive maintenance
Tuesday, September 13, 2022	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	12 - Open - Normal operations with preventive maintenance
Tuesday, October 4, 2022	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	6.6 - Open - No action required
Tuesday, November 22, 2022	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	9.1 - Open - No action required
Tuesday, December 13, 2022	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	2.5 - Open - No action required
Tuesday, January 17, 2023	J. Robert S. Prichard Alumni House	DR208	DR - 2nd Floor Kitchen	3.3 - Open - No action required
Wednesday, December 16, 2020	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	310 - Closed - Isolation point of use, remediation required
Tuesday, April 27, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	660 - Closed - Isolation point of use, remediation required
Tuesday, September 21, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	95 - Open - Normal operations with preventive maintenance
Friday, October 8, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	110 - Closed - Isolation point of use, remediation required
Friday, October 29, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	ND - Open - No action required
Friday, December 3, 2021	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	ND - Open - No action required
Friday, May 13, 2022	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	480 - Closed - Isolation point of use, remediation required
Tuesday, September 13, 2022	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	3.8 - Open - No action required
Tuesday, October 4, 2022	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	26 - Open - Normal operations with preventive maintenance
Tuesday, November 22, 2022	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	25 - Open - Normal operations with preventive maintenance
Tuesday, December 13, 2022	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	12 - Open - Normal operations with preventive maintenance
Tuesday, January 17, 2023	J. Robert S. Prichard Alumni House	DR326A	DR - 3rd Floor Women's Washroom	8 - Open - No action required
Tuesday, October 18, 2022	Jackman Humanities Building	JH1041	JH - 10th Floor Kitchen	ND - Open - No action required
Tuesday, October 18, 2022	Jackman Humanities Building	JH1000	JH - 1st Floor All-Gender Washroom	ND - Open - No action required
Thursday, December 2, 2021	Jackman Humanities Building	JH236W	JH - 2nd Floor All-Gender Washroom	ND - Open - No action required
Thursday, December 2, 2021	Jackman Humanities Building	JH336A	JH - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, October 18, 2022	Jackman Humanities Building	JH490M	JH - 4th Floor All-Gender Washroom	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH417	JH - 4th Floor Kitchen	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH500W	JH - 5th Floor All-Gender Washroom	ND - Open - No action required
Thursday, December 2, 2021	Jackman Humanities Building	JH615	JH - 6th Floor Staff Lounge Kitchen	ND - Open - No action required
Tuesday, October 18, 2022	Jackman Humanities Building	JH720	JH - 7th Floor Kitchen	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH700M	JH - 7th Floor Men's Washroom	ND - Open - No action required
Thursday, December 2, 2021	Jackman Humanities Building	JH800M	JH - 8th Floor Men's Washroom	ND - Open - No action required
Monday, April 12, 2021	Jackman Humanities Building	JH900W	JH - 9th Floor Women's Washroom	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building	RL14081	RL - 14th Floor Kitchenette	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building		RL - 1st Floor Women's Washroom Beside 1131	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building	RL2008	RL - 2nd Floor Washroom Shower	ND - Open - No action required
Thursday, February 25, 2021	John P. Roberts Library Building	4-002	RL - 4th Floor Accessible Washroom	ND - Open - No action required
Thursday, September 17, 2020	John P. Roberts Library Building	7-005	RL - 7th Floor Women's Washroom	ND - Open - No action required
Tuesday, August 17, 2021	John P. Roberts Library Building		RL - 8th Floor Staff Elevator Lobby Kitchen	ND - Open - No action required
Thursday, September 17, 2020	John P. Roberts Library Building		RL - Water Fountain Near Room 1016	ND - Open - No action required
Tuesday, January 31, 2023	Koffler House	KP102	KP - 1st Floor Men's Washroom	ND - Open - No action required
Thursday, February 25, 2021	Koffler House	KP103	KP - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, November 17, 2021	Koffler House	KP204	KP - 2nd Floor Accessible Washroom Shower	ND - Open - No action required
Thursday, February 25, 2021	Koffler House	KP215B	KP - 2nd Floor Female Ablution	4.5 - Open - No action required
Wednesday, June 23, 2021	Koffler House	KP215B	KP - 2nd Floor Female Ablution	ND - Open - No action required
Tuesday, January 31, 2023	Koffler House	KP215B	KP - 2nd Floor Female Ablution	ND - Open - No action required
Wednesday, November 17, 2021	Koffler House	KP215A	KP - 2nd Floor Male Ablution	ND - Open - No action required
Thursday, February 25, 2021	Koffler House	KP205	KP - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, February 25, 2021	Koffler House	KP303	KP - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, January 31, 2023	Koffler House	KP303	KP - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 17, 2021	Koffler House	KP303	KP - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, September 9, 2021	Koffler Student Services Centre	KS113W	KS - 1st Floor All-Gender Washroom Inside Health & Wellness Suite 111	24 - Open - Normal operations with preventive maintenance
Wednesday, March 2, 2022	Koffler Student Services Centre	KS113W	KS - 1st Floor All-Gender Washroom Inside Health & Wellness Suite 111	ND - Open - No action required
Thursday, March 17, 2022	Koffler Student Services Centre	KS113W	KS - 1st Floor All-Gender Washroom Inside Health & Wellness Suite 111	ND - Open - No action required
Thursday, March 31, 2022	Koffler Student Services Centre	KS113W	KS - 1st Floor All-Gender Washroom Inside Health & Wellness Suite 111	ND - Open - No action required



Wednesday, November 25, 2020	Koffler Student Services Centre		KS - 1st Floor Kitchen Inside K133K	ND - Open - No action required
Thursday, September 9, 2021	Koffler Student Services Centre	KS202W	KS - 2nd Floor All-Gender Washroom Inside Student Experience (KS202)	63 - Open - Normal operations with preventive maintenance
Wednesday, March 2, 2022	Koffler Student Services Centre	KS202W	KS - 2nd Floor All-Gender Washroom Inside Student Experience (KS202)	ND - Open - No action required
Thursday, March 17, 2022	Koffler Student Services Centre	KS202W	KS - 2nd Floor All-Gender Washroom Inside Student Experience (KS202)	ND - Open - No action required
Thursday, March 31, 2022	Koffler Student Services Centre	KS202W	KS - 2nd Floor All-Gender Washroom Inside Student Experience (KS202)	ND - Open - No action required
Wednesday, November 25, 2020	Koffler Student Services Centre		KS - 2nd Floor Shower Inside KS232	ND - Open - No action required
Wednesday, November 25, 2020	Koffler Student Services Centre		KS - 3rd Floor Kitchen Inside KS325	ND - Open - No action required
Thursday, September 9, 2021	Koffler Student Services Centre	KS304	KS - 3rd Floor Kitchen Near Student Life Admin	ND - Open - No action required
Tuesday, December 8, 2022	Lash Miller Chemical Laboratories	LM150A	LM - 1st Floor Admin Office Kitchen	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM140	LM - 1st Floor Lab Sink	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM236A	LM - 2nd Floor All-Gender Washroom	5.3 - Open - No action required
Tuesday, June 22, 2021	Lash Miller Chemical Laboratories	LM236A	LM - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM253	LM - 2nd Floor Office Kitchenette	ND - Open - No action required
Tuesday, December 6, 2022	Lash Miller Chemical Laboratories	LM124	LM - 3rd Floor Men's Washroom	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	LM428	LM - 4th Floor Kitchen	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM428	LM - 4th Floor Kitchen	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM411A	LM - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM511	LM - 5th Floor Lab Sink	ND - Open - No action required
Tuesday, December 6, 2022	Lash Miller Chemical Laboratories	LM516	LM - 5th Floor Lab Sink	ND - Open - No action required
Thursday, October 8, 2020	Lash Miller Chemical Laboratories	LM624	LM - 6th Floor Kitchen	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM616	LM - 6th Floor Office Kitchenette	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	LM117	LM - Davenport Wing 1st Floor Teaching Lab Sink	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM208	LM - Davenport Wing 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM215	LM - Davenport Wing 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, December 6, 2022	Lash Miller Chemical Laboratories	LM217	LM - Davenport Wing 2nd Floor Teaching Lab Handwash Sink to Left of LM217A	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	LM205	LM - Davenport Wing 2nd Floor Women's Washroom	ND - Open - No action required
Monday, November 9, 2020	Lash Miller Chemical Laboratories	LM351A	LM - Davenport Wing 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM359B	LM - Davenport Wing 3rd Floor Office Kitchenette	ND - Open - No action required
Tuesday, December 6, 2022	Lash Miller Chemical Laboratories	LM453	LM - Davenport Wing 4th Floor All-Gender Washroom	ND - Open - No action required
Wednesday, November 3, 2021	Lash Miller Chemical Laboratories	LM463	LM - Davenport Wing 4th Floor Office Kitchenette	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB - 2nd Floor Accessible Washroom	MB - 2nd Floor Accessible Washroom	ND - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB226	MB - 2nd Floor Lounge	12 - Open - Normal operations with preventive maintenance
Thursday, October 21, 2021	Lassonde Mining Building	MB226	MB - 2nd Floor Lounge	14 - Open - No action required
Friday, August 5, 2022	Lassonde Mining Building	MB226	MB - 2nd Floor Lounge	50 - Open - Normal operations with preventive maintenance
Wednesday, October 13, 2021	Lassonde Mining Building	MB301B	MB - 3rd Floor Lab Room Inside MB301	ND - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB407B	MB - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, October 13, 2021	Lassonde Mining Building	MB68	MB - Basement Graduate Office	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB53	MB - Basement Men's Washroom	5.8 - Open - No action required
Wednesday, June 23, 2021	Lassonde Mining Building	MB53	MB - Basement Men's Washroom	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB301	MB - Lab Tap	ND - Open - No action required
Tuesday, October 6, 2020	Lassonde Mining Building	MB118	MB - Student Lounge	ND - Open - No action required
Tuesday, March 7, 2023	Leslie L. Dan Pharmacy Building	PB1128	PB - 11th Floor Lab Sink (Near PB1172)	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building	PB1243	PB - 12th Floor Lab Sink	ND - Open - No action required
Tuesday, March 7, 2023	Leslie L. Dan Pharmacy Building	PB210	PB - 2nd Basement Men's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB225	PB - 2nd Floor All-Gender Washroom Inside Student Lounge	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB332A	PB - 3rd Floor Kitchenette Sink inside Student Study Room	ND - Open - No action required
Tuesday, March 7, 2023	Leslie L. Dan Pharmacy Building	PB435	PB - 4th Floor All-Gender Washroom	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building	PB5	PB - 5th Floor Lounge	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB612	PB - 6th Floor Graduate Student Common Room	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building	PB644	PB - 6th Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Leslie L. Dan Pharmacy Building	PB742	PB - 7th Floor Men's Washroom	ND - Open - No action required
Tuesday, March 7, 2023	Leslie L. Dan Pharmacy Building	PB820	PB - 8th Floor Women's Washroom	ND - Open - No action required
Thursday, November 5, 2020	Leslie L. Dan Pharmacy Building	PB	PB - Basement Accessible Washroom	ND - Open - No action required
Thursday, November 4, 2021	Lillian Massey Building	LI129	LI - 1st Floor All-Gender Washroom	ND - Open - No action required
Tuesday, November 15, 2022	Lillian Massey Building	LI105	LI - 1st Floor All-Gender Washroom	ND - Open - No action required
Thursday, November 4, 2021	Lillian Massey Building	LI212	LI - 2nd Floor Accessible Washroom Shower	ND - Open - No action required
Tuesday, November 15, 2022	Lillian Massey Building	LI228	LI - 2nd Floor All-Gender Washroom (Left)	2.2 - Open - No action required
Thursday, January 21, 2021	Lillian Massey Building	LI	LI - 2nd Floor Kitchen	ND - Open - No action required
Thursday, January 21, 2021	Lillian Massey Building	LI	LI - 2nd Floor Women's Washroom	ND - Open - No action required
Thursday, January 21, 2021	Lillian Massey Building	LI312B	LI - 3rd Floor Kitchen (Great Hall)	ND - Open - No action required
Tuesday, November 15, 2022	Lillian Massey Building	LI339	LI - 3rd Floor Kitchen (University Advancement)	ND - Open - No action required
Thursday, November 4, 2021	Lillian Massey Building	LI342	LI - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, November 15, 2022	Lillian Massey Building	LB016	LI - Basement Lunch Room	ND - Open - No action required
Thursday, February 4, 2021	Louis B. Stewart Observatory (UTSU)	SO - 1st Floor Kitchen	SO - 1st Floor Kitchen	100 - Open - Normal operations with preventive maintenance
Thursday, February 4, 2021	Louis B. Stewart Observatory (UTSU)	SO - 1st Floor Washroom	SO - 1st Floor Washroom	32 - Open - Normal operations with preventive maintenance
Thursday, February 4, 2021	Louis B. Stewart Observatory (UTSU)	SO - Basement Washroom	SO - Basement Washroom	21 - Open - Normal operations with preventive maintenance
Tuesday, January 19, 2021	Luella Massey Studio Theatre	GM05	GM - Basement All-Gender Washroom (Left)	ND - Open - No action required
Tuesday, December 8, 2022	Luella Massey Studio Theatre	GM05	GM - Basement All-Gender Washroom (Left)	ND - Open - No action required
Tuesday, January 19, 2021	Luella Massey Studio Theatre	GM04	GM - Basement All-Gender Washroom (Right)	ND - Open - No action required
Tuesday, August 31, 2021	Luella Massey Studio Theatre	GM07	GM - Basement Custodian Room Sink	ND - Open - No action required
Tuesday, August 31, 2021	Luella Massey Studio Theatre	GM01	GM - Basement Workshop	ND - Open - No action required
Tuesday, December 6, 2022	Luella Massey Studio Theatre	GM01	GM - Basement Workshop	ND - Open - No action required
Friday, October 15, 2021	Macdonald-Mowat House	MM108	MM - 1st Floor All-Gender Washroom	ND - Open - No action required
Tuesday, December 13, 2022	Macdonald-Mowat House	MM107	MM - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 28, 2020	Macdonald-Mowat House	MM106	MM - 1st Floor Kitchen	ND - Open - No action required
Wednesday, October 28, 2020	Macdonald-Mowat House	MM209	MM - 2nd Floor All-Gender Washroom	ND - Open - No action required
Friday, October 15, 2021	Macdonald-Mowat House	MM210	MM - 2nd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, December 13, 2022	Macdonald-Mowat House	MM209	MM - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 28, 2020	Macdonald-Mowat House	MM312	MM - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, December 13, 2022	Macdonald-Mowat House	MM313	MM - 3rd Floor All-Gender Washroom	ND - Open - No action required
Friday, October 15, 2021	Macdonald-Mowat House	MM314	MM - 3rd Floor Kitchen	ND - Open - No action required
Friday, December 10, 2021	MARS 2	M21140	M2 - 11th Floor Kitchen Inside Suite M21140	ND - Open - No action required
Wednesday, December 8, 2021	MARS 2	M21470K	M2 - 14th Floor Exit Sink Near Service Elevator 3	ND - Open - No action required
Wednesday, December 8, 2021	MARS 2	M21509R	M2 - 15th Floor Aisle 1550R Lab Sink	ND - Open - No action required
Wednesday, December 8, 2021	MARS 2	M21641	M2 - 16th Floor Anteroom Sink	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	M2 - 16th Floor	M2 - 16th Floor Kitchen	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	1st Floor	M2 - 1st Floor Men's Washroom Beside Elevator	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	14th Floor	M2 - Lab Hand Wash Sink in 1416K Entrance	ND - Open - No action required
Tuesday, February 23, 2021	MARS 2	15th Floor	M2 - 1st Floor Staff Lounge Kitchen	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)		1st Floor Men's Washroom	ND - Open - No action required
Thursday, December 16, 2021	MaRS South (SGC)		6th Floor Lab Sink Near Room 621	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)	691	6th Floor SGC Room 691 Kitchen Tap	ND - Open - No action required
Thursday, December 16, 2021	MaRS South (SGC)	621	6th Floor Sink in Room 621	ND - Open - No action required
Thursday, December 16, 2021	MaRS South (SGC)	708	7th Floor Sink in Room 708	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)	708	7th Floor SGC Room 708 Lab Sink	ND - Open - No action required
Wednesday, March 17, 2021	MaRS South (SGC)		8th Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE163	GE - 1st Floor All-Gender Washroom (Left)	ND - Open - No action required
Wednesday, November 2, 2022	Max Gluskin House	GE161	GE - 1st Floor All-Gender Washroom (Right)	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE198	GE - 1st Floor Kitchen Sink	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House	GE118	GE - 1st Floor Men's Washroom	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House	GE251	GE - 2nd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, November 2, 2022	Max Gluskin House	GE220	GE - 2nd Floor All-Gender Washroom	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE318	GE - 3rd Floor All-Gender Washroom	ND - Open - No action required
Wednesday, November 2, 2022	Max Gluskin House	GE340	GE - 3rd Floor Staff Lounge Kitchen	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House	GE063	GE - Basement All-Gender Washroom	ND - Open - No action required
Monday, November 23, 2020	Max Gluskin House	GE073	GE - Basement Kitchen	ND - Open - No action required
Wednesday, November 2, 2022	Max Gluskin House	GE018	GE - Basement Men's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Max Gluskin House	GE020	GE - Basement Women's Washroom	ND - Open - No action required
Thursday, September 24, 2020	McCaui Street-254/256	RM1	RM - 1st Floor Water Fountain Near RM117	ND - Open - No action required
Tuesday, October 18, 2022	McCaui Street-254/256	RM1	RM - 1st Floor Water Fountain Near RM117	ND - Open - No action required
Wednesday, September 22, 2021	McCaui Street-254/256	RM116	RM - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, October 18, 2022	McCaui Street-254/256	RM215V	RM - 2nd Floor Kitchen	ND - Open - No action required
Wednesday, September 22, 2021	McCaui Street-254/256	RM1	RM - 2nd Floor Water Fountain Near RM208	ND - Open - No action required
Thursday, September 24, 2020	McCaui Street-254/256	RM2	RM - 2nd Floor Lunch Room	ND - Open - No action required
Tuesday, October 18, 2022	McCaui Street-254/256	RM3	RM - 3rd Floor Water Fountain Near RM315	ND - Open - No action required
Wednesday, September 22, 2021	McCaui Street-254/256	RM414	RM - 4th Floor Kitchen	ND - Open - No action required
Tuesday, October 18, 2022	McCaui Street-254/256	RM411	RM - 4th Floor Men's Washroom	1.7 - Open - No action required
Wednesday, September 22, 2021	McCaui Street-254/256	RM510	RM - 5th Floor Men's Washroom	ND - Open - No action required
Thursday, September 24, 2020	McCaui Street-254/256	RM208	RM - 5th Floor Shower Room	ND - Open - No action required
Thursday, September 24, 2020	McCaui Street-254/256	RM507	RM - 5th Floor Women's Washroom	ND - Open - No action required
Wednesday, October 7, 2020	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	18 - Open - Normal operations with preventive maintenance
Tuesday, December 8, 2020	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	55 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	ND - Open - No action required
Tuesday, June 1, 2021	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	63 - Open - Normal operations with preventive maintenance
Monday, July 19, 2021	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	58 - Open - Normal operations with preventive maintenance
Monday, August 23, 2021	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	18 - Open - Normal operations with preventive maintenance
Wednesday, October 27, 2021	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	ND - Open - No action required
Friday, January 28, 2022	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	18 - Open - Normal operations with preventive maintenance
Friday, February 4, 2022	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	8.4 - Open - No action required
Tuesday, March 21, 2023	McCaui Street-263	OA104	OA - 1st Floor All-Gender Washroom #1 (Left)	1.3 - Open - No action required
Wednesday, October 7, 2020	McCaui Street-263	OA219	OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Tuesday, June 1, 2021	McCaui Street-263	OA219	OA - 2nd Floor Lab Inside Well-Being Centre	11 - Open - Normal operations with preventive maintenance
Monday, July 19, 2021	McCaui Street-263	OA219	OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Monday, August 23, 2021	McCaui Street-263	OA219	OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Friday, January 28, 2022	McCaui Street-263	OA219	OA - 2nd Floor Lab Inside Well-Being Centre	ND - Open - No action required
Tuesday, March 21, 2023	McCaui Street-263	OA223	OA - 2nd Floor Women's Staff Washroom	360 - Closed - Isolation point of use, remediation required
Tuesday, March 21, 2023	McCaui Street-263	OA313	OA - 3rd Floor Kitchen	ND - Open - No action required
Thursday, February 18, 2021	McCaui Street-263	OA318	OA - 3rd Floor Men's Washroom	340 - Closed - Isolation point of use, remediation required
Wednesday, March 10, 2021	McCaui Street-263	OA318	OA - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, June 1, 2021	McCaui Street-263	OA318	OA - 3rd Floor Men's Washroom	ND - Open - No action required
Monday, July 19, 2021	McCaui Street-263	OA318	OA - 3rd Floor Men's Washroom	ND - Open - No action required
Friday, January 28, 2022	McCaui Street-263	OA405D	OA - 4th Floor Kitchen Sink	ND - Open - No action required

Wednesday, October 7, 2020	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	12 - Open - Normal operations with preventive maintenance
Tuesday, December 8, 2020	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	18 - Open - Normal operations with preventive maintenance
Thursday, February 18, 2021	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	22 - Open - No action required
Wednesday, March 10, 2021	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	22 - Open - No action required
Tuesday, June 1, 2021	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	11 - Open - Normal operations with preventive maintenance
Monday, July 19, 2021	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	ND - Open - No action required
Monday, August 23, 2021	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	ND - Open - No action required
Friday, January 28, 2022	McCaul Street-263	QA405	QA- 4th Floor Women's Washrom	ND - Open - No action required
Tuesday, March 21, 2023	McCaul Street-263	QA507	QA- 5th Floor All-Gender Washroom	18 - Open - No action required
Wednesday, October 7, 2020	McCaul Street-263	OA512	OA- 5th Floor Kitchen	ND - Open - No action required
Thursday, February 18, 2021	McCaul Street-263	OA512	OA- 5th Floor Kitchen	ND - Open - No action required
Tuesday, September 7, 2021	McLennan Physical Laboratories	MP127	MP - 1st Floor Lab Sink	ND - Open - No action required
Monday, September 14, 2020	McLennan Physical Laboratories	MP132	MP - 1st Men's Washroom	ND - Open - No action required
Tuesday, September 7, 2021	McLennan Physical Laboratories	MP254	MP - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, September 7, 2021	McLennan Physical Laboratories	MP031	MP - Basement Men's Washroom	ND - Open - No action required
Monday, September 14, 2020	McLennan Physical Laboratories	MP239	MP - Lab	ND - Open - No action required
Monday, September 14, 2020	McLennan Physical Laboratories	MP	MP - Water Fountain Near MP0103	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building	MR110	MR - 1st Floor Kitchen	ND - Open - No action required
Tuesday, November 29, 2022	McMurrich Building	MR111	MR - 1st Floor Women's Washrom	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR220	MR - 2nd Floor Kitchen	11 - Open - Normal operations with preventive maintenance
Tuesday, May 24, 2022	McMurrich Building	MR220	MR - 2nd Floor Kitchen	ND - Open - No action required
Friday, June 10, 2022	McMurrich Building	MR220	MR - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, October 11, 2022	McMurrich Building	MR220	MR - 2nd Floor Kitchen	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building	MR313	MR - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR314	MR - 3rd Floor Women's Washrom	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR403A	MR - 4th Floor All-Gender Washrom	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building	MR403	MR - 4th Floor Men's Washrom	ND - Open - No action required
Tuesday, October 11, 2022	McMurrich Building	MR403	MR - 4th Floor Men's Washrom	ND - Open - No action required
Wednesday, October 21, 2020	McMurrich Building	MR10A	MR - Basement All-Gender Washrom	ND - Open - No action required
Tuesday, September 14, 2021	McMurrich Building	MR10A	MR - Basement All-Gender Washrom	ND - Open - No action required
Tuesday, November 29, 2022	McMurrich Building	MR10	MR - Basement Men's Washrom	ND - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	34 - Open - Normal operations with preventive maintenance
Friday, February 19, 2021	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	98 - Open - Normal operations with preventive maintenance
Tuesday, April 13, 2021	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	ND - Open - No action required
Monday, May 3, 2021	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	14 - Open - Normal operations with preventive maintenance
Tuesday, May 18, 2021	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	11 - Open - No action required
Tuesday, August 2, 2022	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	15 - Open - Normal operations with preventive maintenance
Wednesday, August 24, 2022	Mechanical Engineering Building	MC128A	MC - 1st Floor Men's Washrom	11 - Open - Normal operations with preventive maintenance
Wednesday, October 14, 2020	Mechanical Engineering Building	MC330	MC - 3rd Floor Kitchen	15 - Normal operations with preventive maintenance
Friday, February 19, 2021	Mechanical Engineering Building	MC330	MC - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, April 13, 2021	Mechanical Engineering Building	MC330	MC - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building	MC	MC - 4th Floor Shower Beside MC413	52 - Open - No action required
Friday, February 19, 2021	Mechanical Engineering Building	MC	MC - 4th Floor Shower Beside MC413	19 - Open - Normal operations with preventive maintenance
Tuesday, April 13, 2021	Mechanical Engineering Building	MC	MC - 4th Floor Shower Beside MC413	ND - Open - No action required
Monday, May 3, 2021	Mechanical Engineering Building	MC	MC - 4th Floor Shower Beside MC413	ND - Open - No action required
Wednesday, October 14, 2020	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	67 - Open - Normal operations with preventive maintenance
Friday, February 19, 2021	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	18 - Open - Normal operations with preventive maintenance
Tuesday, April 13, 2021	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	55 - Open - Normal operations with preventive maintenance
Tuesday, May 3, 2021	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	18 - Open - No action required
Tuesday, May 18, 2021	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	ND - Open - No action required
Thursday, July 14, 2022	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	66 - Open - Normal operations with preventive maintenance
Wednesday, August 24, 2022	Mechanical Engineering Building	MC55A	MC - Basement Lab Sink	97 - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS1271	MS - 1st Floor Water Fountain Near MS1228	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS2171	MS - 2nd Floor Lunch Room Kitchen	ND - Open - No action required
Monday, August 30, 2021	Medical Sciences Building	MS	MS - 2nd Floor So Sushi Right Sink in the Cafeteria	ND - Open - No action required
Monday, August 30, 2021	Medical Sciences Building	MS	MS - 2nd Floor Starbucks Far Right Sink	ND - Open - No action required
Monday, August 30, 2021	Medical Sciences Building	MS	MS - 2nd Floor Tim Hortons Back Room Sink	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS3235	MS - 3rd Floor Men's Washrom	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building	MS330	MS - 3rd Floor Women's Washrom	ND - Open - No action required
Wednesday, August 11, 2021	Medical Sciences Building	MS5234	MS - 5th Floor Lunch Room Kitchen	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building	MS	MS - Fountain Near MS6235	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building	MS4243	MS - Kitchen	ND - Open - No action required
Wednesday, September 9, 2020	Medical Sciences Building	MS5336	MS - Lab	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall	MO	MO - 3th Floor All-Gender Shower	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall	MO500	MO - 5th Floor Kitchen	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall	MO	MO - 9th Floor All-Gender Washrom	ND - Open - No action required
Thursday, May 13, 2021	Morrison Hall	MO	MO - Basement Common Shower	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at the Observatory	MK104	MK - 1st Floor All-Gender Washrom (Left)	ND - Open - No action required
Wednesday, January 13, 2021	Munk School of Global Affairs & Public Policy at the Observatory	MK105	MK - 1st Floor All-Gender Washrom (Right)	ND - Open - No action required
Monday, November 1, 2021	Munk School of Global Affairs & Public Policy at the Observatory	MK108	MK - 1st Floor Kitchen	ND - Open - No action required
Monday, November 1, 2021	Munk School of Global Affairs & Public Policy at the Observatory	MK204	MK - 2nd Floor All-Gender Washrom (Left)	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at the Observatory	MK205	MK - 2nd Floor All-Gender Washrom (Right)	ND - Open - No action required
Wednesday, January 13, 2021	Munk School of Global Affairs & Public Policy at the Observatory	MK305	MK - 3rd Floor All-Gender Washrom	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at the Observatory	MK005	MK - Basement All-Gender Washrom	ND - Open - No action required
Wednesday, January 13, 2021	Munk School of Global Affairs & Public Policy at the Observatory	MK005K	MK - Basement Kitchen	ND - Open - No action required
Monday, November 1, 2021	Munk School of Global Affairs & Public Policy at the Observatory	MK005K	MK - Basement Kitchen	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at the Observatory	MK005	MK - Basement Men's Washrom	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at Trinity	MUS163	MU - 1st Floor Kitchen	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at Trinity	MUN214	MU - 2nd Floor All-Gender Washrom	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at Trinity	MUS352	MU - 3rd Floor All-Gender Washrom (Left)	ND - Open - No action required
Tuesday, November 15, 2022	Munk School of Global Affairs & Public Policy at Trinity	MUE043	MU - Basement Men's Washrom	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship	MY108	MY - 1st Floor Women's Washrom	ND - Open - No action required
Tuesday, November 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY211	MY - 2nd Floor Women's Washrom	ND - Open - No action required
Tuesday, February 28, 2023	Myhal Centre for Engineering Innovation and Entrepreneurship	MY208	MY - 2nd Floor Women's Washrom	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship	MY306	MY - 3rd Floor All-Gender Washrom	ND - Open - No action required
Tuesday, February 28, 2023	Myhal Centre for Engineering Innovation and Entrepreneurship	MY406	MY - 4th Floor All-Gender Accessible Washrom Shower	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship	MY523	MY - 5th Floor Kitchen	ND - Open - No action required
Tuesday, November 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY606	MY - 6th Floor All-Gender Washrom Shower	ND - Open - No action required
Tuesday, February 28, 2023	Myhal Centre for Engineering Innovation and Entrepreneurship	MY603	MY - 6th Floor Lounge Kitchen	ND - Open - No action required
Tuesday, September 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY783	MY - 7th Floor Kitchen	ND - Open - No action required
Wednesday, November 4, 2020	Myhal Centre for Engineering Innovation and Entrepreneurship	MY783	MY - 8th Floor Kitchen	ND - Open - No action required
Tuesday, September 14, 2021	Myhal Centre for Engineering Innovation and Entrepreneurship	MY40	MY - Basement Kitchen Sink Near MY38	ND - Open - No action required
Tuesday, February 28, 2023	Myhal Centre for Engineering Innovation and Entrepreneurship	MY104	MY - Basement Men's Washrom	ND - Open - No action required
Thursday, May 20, 2021	New College II	NR462	NR - Common Room Kitchen Sink	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR855	NR - All-Gender Washrom Shower	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR750	NR - All-Gender Washrom Sink	ND - Open - No action required
Thursday, May 20, 2021	New College III	NR641	NR - Don Suite Kitchen Sink	ND - Open - No action required
Wednesday, November 2, 2022	Ontario Institute for Studies in Education	OI10-299	OI - 10th Floor Kitchen	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for Studies in Education	OI4-454	OI - 4th Floor Water Fountain	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI12-130	OI - 12th Floor Kitchen Inside Nexus Lounge	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for Studies in Education	OIC-100A	OI - 1st Floor Women's Washrom	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI2-239	OI - 2nd Floor Kitchen Inside Centre for Women's Studies in Education	ND - Open - No action required
Wednesday, September 17, 2020	Ontario Institute for Studies in Education	OI3-399	OI - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, November 2, 2022	Ontario Institute for Studies in Education	OI4-454	OI - 4th Floor Staff Lounge Kitchen	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI5-301	OI - 5th Floor Women's Washrom	ND - Open - No action required
Wednesday, November 2, 2022	Ontario Institute for Studies in Education	OI6-300	OI - 6th Floor Men's Washrom	ND - Open - No action required
Thursday, September 17, 2020	Ontario Institute for Studies in Education	OI7-300	OI - 7th Floor Men's Washrom	ND - Open - No action required
Wednesday, September 22, 2021	Ontario Institute for Studies in Education	OI8-110	OI - 8th Floor Water Fountain Near OI9-100	ND - Open - No action required
Wednesday, November 2, 2022	Ontario Institute for Studies in Education	OI9-110	OI - Basement Men's Washrom	ND - Open - No action required
Monday, February 22, 2021	Queen's Park Crescent East-39	ME	ME - 1st Floor Kitchen	80 - Closed - Isolation point of use, remediation required
Thursday, August 26, 2021	Queen's Park Crescent East-39	ME	ME - 1st Floor Kitchen	23 - Open - Normal operations with preventive maintenance
Friday, January 7, 2022	Queen's Park Crescent East-39	ME	ME - 1st Floor Kitchen	ND - Open - No action required
Monday, February 22, 2021	Queen's Park Crescent East-39	ME204	ME - 2nd Floor All-Gender Washrom	55 - Open - Normal operations with preventive maintenance
Thursday, August 26, 2021	Queen's Park Crescent East-39	ME204	ME - 2nd Floor All-Gender Washrom	29 - Open - Normal operations with preventive maintenance
Friday, January 7, 2022	Queen's Park Crescent East-39	ME204	ME - 2nd Floor All-Gender Washrom	35 - Open - Normal operations with preventive maintenance
Monday, February 22, 2021	Queen's Park Crescent East-39	ME	ME - 2nd Floor Washrom Across from Fireplace	ND - Open - No action required
Monday, February 22, 2021	Queen's Park Cres. E-39A	ML5	ML - 2nd Floor Washrom	ND - Open - No action required
Friday, January 14, 2022	Queen's Park Cres. E-39A	ML5	ML - 2nd Floor Washrom	ND - Open - No action required
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW230	RW - 2nd Floor Men's Washrom	ND - Open - No action required
Friday, May 14, 2021	Ramsay Wright Laboratories	RW	RW - 2nd Floor Women's Washrom	ND - Open - No action required
Tuesday, December 6, 2022	Ramsay Wright Laboratories	RW230	RW - 2nd Floor Women's Washrom	69 - Open - Normal operations with preventive maintenance
Monday, December 19, 2022	Ramsay Wright Laboratories	RW230	RW - 2nd Floor Women's Washrom	ND - Open - No action required
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW230	RW - 2nd Floor Women's Washrom Accessible Stall Sink	ND - Open - No action required
Monday, December 19, 2022	Ramsay Wright Laboratories	RW230	RW - 2nd Floor Women's Washrom Accessible Stall Sink	4.8 - Open - No action required
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW230	RW - 2nd Floor Women's Washrom Accessible Stall Sink	ND - Open - No action required
Tuesday, December 6, 2022	Ramsay Wright Laboratories	RW330	RW - 3rd Floor Lab Eyewash	7.9 - Open - No action required
Tuesday, December 6, 2022	Ramsay Wright Laboratories	RW303	RW - 3rd Floor Lab Eyewash	10 - Closed - Isolation point of use, remediation required
Monday, December 19, 2022	Ramsay Wright Laboratories	RW303	RW - 3rd Floor Lab Eyewash	7 - Open - No action required
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW303	RW - 3rd Floor Lab Eyewash	ND - Open - No action required
Monday, November 2, 2020	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	80 - Open - Normal operations with preventive maintenance
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	23 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	ND - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	12 - Open - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	30 - Open - Normal operations with preventive maintenance
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	15 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	17 - Open - Normal operations with preventive maintenance
Tuesday, November 29, 2022	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	18 - Open - Normal operations with preventive maintenance
Tuesday, December 13, 2022	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	ND - Open - No action required
Monday, December 19, 2022	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	80 - Closed - Isolation point of use, remediation required
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW334A	RW - 3rd Floor Men's Washrom	9.5 - Open - No action required
Friday, May 14, 2021	Ramsay Wright Laboratories	RW	RW - 3rd Floor Women's Washrom	ND - Open - No action required

Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW335A	RW - 3rd Floor Women's Washroom	1-9 - Open - No action required
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	28 - Open - Normal operations with preventive maintenance
Monday, November 2, 2020	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	38 - Open - No action required
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	18 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	4-3 - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	15 - Open - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	6-5 - Open - No action required
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	12 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	24 - Open - Normal operations with preventive maintenance
Tuesday, November 29, 2022	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	ND - Open - No action required
Tuesday, December 13, 2022	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	9 - Open - No action required
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW401G	RW - 4th Floor Kitchen Inside Admin Office	0-9 - Open - No action required
Monday, November 2, 2020	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	42 - Open - Normal operations with preventive maintenance
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	11 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	ND - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	ND - Open - No action required
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	ND - Open - No action required
Tuesday, December 6, 2022	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	40 - Open - Normal operations with preventive maintenance
Monday, December 19, 2022	Ramsay Wright Laboratories	RW539A	RW - 5th Floor Women's Washroom	48 - Open - Normal operations with preventive maintenance
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW618	RW - 6th Floor Lab Eyewash	7-6 - Open - No action required
Tuesday, December 6, 2022	Ramsay Wright Laboratories	RW605	RW - 6th Floor Lab Eyewash By Lab Sink	82 - Open - Normal operations with preventive maintenance
Monday, December 19, 2022	Ramsay Wright Laboratories	RW605	RW - 6th Floor Lab Eyewash By Lab Sink	10 - Open - Normal operations with preventive maintenance
Tuesday, February 7, 2023	Ramsay Wright Laboratories	RW605	RW - 6th Floor Lab Eyewash By Lab Sink	ND - Open - No action required
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	14 - Open - Normal operations with preventive maintenance
Monday, November 2, 2020	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	34 - Open - Normal operations with preventive maintenance
Thursday, April 29, 2021	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	46 - Open - Normal operations with preventive maintenance
Friday, May 14, 2021	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	7-3 - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	18 - Open - Normal operations with preventive maintenance
Thursday, September 21, 2021	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	20 - Normal operations with preventive maintenance
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	40 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	22 - Open - Normal operations with preventive maintenance
Tuesday, November 29, 2022	Ramsay Wright Laboratories	RW604	RW - 6th Floor Lab Handwash Sink	1-9 - Open - No action required
Wednesday, October 7, 2020	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	47 - Open - No action required
Thursday, July 8, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	15 - Normal operations with preventive maintenance
Tuesday, September 21, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	27 - Open - Normal operations with preventive maintenance
Tuesday, September 28, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	ND - Open - No action required
Thursday, October 7, 2021	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	13 - Open - Normal operations with preventive maintenance
Tuesday, November 29, 2022	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	0-83 - Open - No action required
Tuesday, December 13, 2022	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	10 - Open - Normal operations with preventive maintenance
Monday, December 19, 2022	Ramsay Wright Laboratories	RW08A	RW - Basement Men's Washroom	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building	RU	RU - 10th Floor Water Fountain	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building	RU	RU - 1st Floor men's Washroom	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU402	RU - 4th Floor Accessible Washroom	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building	A20	RU - 7th Floor Catholics Lab Sink Room 420	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU718	RU - 7th Floor Accessible Shower	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU730	RU - 7th Floor Clinical Lab Sink	ND - Open - No action required
Friday, November 26, 2021	Rehabilitation Sciences Building	RU72	RU - Basement Accessible Shower	ND - Open - No action required
Tuesday, March 9, 2021	Rehabilitation Sciences Building	RU	RU - Basement Shower	ND - Open - No action required
Thursday, September 2, 2021	Roseburgh Building	RS108B	RS - 1st Floor Lab Sink	ND - Open - No action required
Thursday, September 2, 2021	Roseburgh Building	RS102	RS - 1st Floor Women's Washroom	ND - Open - No action required
Thursday, September 2, 2021	Roseburgh Building	RS	RS - 2nd Floor Water Fountain Near RS211	ND - Open - No action required
Thursday, September 24, 2020	Roseburgh Building	RS	RS - 3rd Floor Women's Washroom	ND - Open - No action required
Thursday, September 24, 2020	Roseburgh Building	RS420B	RS - 4th Floor Kitchen Sink	850 - Closed - Underpinning of base, remediation required
Tuesday, September 28, 2021	Roseburgh Building	RS420B	RS - 4th Floor Kitchen Sink	28 - Open - Normal operations with preventive maintenance
Thursday, October 7, 2021	Roseburgh Building	RS420B	RS - 4th Floor Kitchen Sink	ND - Open - No action required
Friday, August 5, 2022	Roseburgh Building	RS420B	RS - 4th Floor Kitchen Sink	23 - Open - Normal operations with preventive maintenance
Thursday, September 24, 2020	Roseburgh Building	RS421	RS - 4th Floor Lab Sink	ND - Open - No action required
Thursday, September 24, 2020	Roseburgh Building	RS	RS - 4th Floor Men's Washroom	ND - Open - No action required
Thursday, September 24, 2020	Roseburgh Building	RS	RS - 4th Floor Men's Washroom	ND - Open - No action required
Wednesday, November 11, 2020	Rolman School of Management	RT1050C	RT - 1st Floor PhD Lounge	ND - Open - No action required
Tuesday, October 12, 2021	Rolman School of Management	RT112A	RT - 1st Floor Second Cup Cafe Sink	ND - Open - No action required
Wednesday, November 11, 2020	Rolman School of Management	RT100K	RT - 1st Floor Water Fountain Near RT114	ND - Open - No action required
Tuesday, October 12, 2021	Rolman School of Management	RT121	RT - 2nd Floor Men's Accessible Washroom	ND - Open - No action required
Wednesday, November 11, 2020	Rolman School of Management	RT223	RT - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, November 11, 2020	Rolman School of Management	RT390A	RT - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, October 12, 2021	Rolman School of Management	RT390A	RT - 3rd Floor Kitchen	ND - Open - No action required
Tuesday, October 12, 2021	Rolman School of Management	RT304	RT - 3rd Floor Kitchennette Near RT310	ND - Open - No action required
Tuesday, December 6, 2022	Rolman School of Management	RT364	RT - 3rd Floor Men's Washroom	ND - Open - No action required
Wednesday, November 11, 2020	Rolman School of Management	RT4063	RT - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, December 6, 2022	Rolman School of Management	RT5061	RT - 5th Floor Women's Washroom	ND - Open - No action required
Tuesday, October 12, 2021	Rolman School of Management	RT6025	RT - 6th Floor Kitchen	ND - Open - No action required
Wednesday, November 11, 2020	Rolman School of Management	RT8061	RT - 8th Floor Women's Washroom	ND - Open - No action required
Tuesday, December 6, 2022	Rolman School of Management	RT8061	RT - 8th Floor Kitchen	ND - Open - No action required
Tuesday, December 6, 2022	Rolman School of Management	RTL1001	RTL - 1st Level All-Gender Washroom	ND - Open - No action required
Monday, September 14, 2020	Sandford Fleming Building	SF1011K	SF - 1st Floor Water Fountain Near SF1013	ND - Open - No action required
Wednesday, September 1, 2021	Sandford Fleming Building	SF1014	SF - 1st Floor Women's Washroom	ND - Open - No action required
Monday, September 14, 2020	Sandford Fleming Building	SF2107	SF - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, February 7, 2023	Sandford Fleming Building	SF2207	SF - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, February 7, 2023	Sandford Fleming Building	SF3309	SF - 3rd Floor Kitchen	ND - Open - No action required
Wednesday, September 1, 2021	Sandford Fleming Building	SF3105	SF - 3rd Floor Women's Washroom	ND - Open - No action required
Wednesday, September 1, 2021	Sandford Fleming Building	SF4201K	SF - 4th Floor Water Fountain Near SF4202	ND - Open - No action required
Tuesday, February 7, 2023	Sandford Fleming Building	SF4006	SF - 4th Floor Women's Washroom	ND - Open - No action required
Tuesday, February 7, 2023	Sandford Fleming Building	SF8580	SF - Basement Kitchen	ND - Open - No action required
Monday, September 14, 2020	Sandford Fleming Building	SF	SF - Basement Sink Near Harshad Cafe	ND - Open - No action required
Monday, November 30, 2020	School of Continuing Studies	CS115	CS - 1st Floor Accessible Washroom	ND - Open - No action required
Friday, October 15, 2021	School of Continuing Studies	CS118	CS - 1st Floor Women's Washroom	ND - Open - No action required
Monday, November 30, 2020	School of Continuing Studies	CS	CS - 2nd Floor Kitchen	ND - Open - No action required
Tuesday, October 11, 2022	School of Continuing Studies	CS215	CS - 2nd Floor Men's Accessible Washroom	ND - Open - No action required
Tuesday, October 11, 2022	School of Continuing Studies	CS215	CS - 2nd Floor Men's Washroom	ND - Open - No action required
Friday, October 15, 2021	School of Continuing Studies	CS415	CS - 4th Floor All-Gender Accessible Washroom	ND - Open - No action required
Tuesday, October 11, 2022	School of Continuing Studies	CS415	CS - 4th Floor All-Gender Accessible Washroom	ND - Open - No action required
Monday, November 30, 2020	School of Continuing Studies	CS405	CS - 4th Floor Women's Washroom	ND - Open - No action required
Friday, October 15, 2021	School of Continuing Studies	CS14	CS - Basement Kitchen	ND - Open - No action required
Tuesday, October 11, 2022	School of Continuing Studies	CS14	CS - Basement Kitchen	ND - Open - No action required
Friday, October 8, 2021	School of Graduate Studies	GS108	GS - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 7, 2020	School of Graduate Studies	GS	GS - 1st Floor Kitchen Near GS105	ND - Open - No action required
Tuesday, November 22, 2022	School of Graduate Studies	GS	GS - 1st Floor Kitchen Near GS105	ND - Open - No action required
Wednesday, October 7, 2020	School of Graduate Studies	GS205	GS - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, November 22, 2022	School of Graduate Studies	GS205	GS - 2nd Floor Men's Washroom	ND - Open - No action required
Tuesday, December 13, 2022	School of Graduate Studies	GS205	GS - 2nd Floor Men's Washroom	ND - Open - No action required
Friday, October 8, 2021	School of Graduate Studies	GS204	GS - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, October 7, 2020	School of Graduate Studies	GS303	GS - 3rd Floor All-Gender Washroom	ND - Open - No action required
Tuesday, November 22, 2022	School of Graduate Studies	GS303	GS - 3rd Floor All-Gender Washroom	24 - Open - Normal operations with preventive maintenance
Tuesday, December 13, 2022	School of Graduate Studies	GS303	GS - 3rd Floor All-Gender Washroom	ND - Open - No action required
Friday, October 8, 2021	School of Graduate Studies	GS301	GS - 3rd Floor Kitchen	ND - Open - No action required
Friday, September 11, 2020	Sidney Smith Hall	SS1002	SS - 1st Floor Men's Washroom	ND - Open - No action required
Friday, September 11, 2020	Sidney Smith Hall	SS1040K	SS - 1st Floor Water Fountain Near SS1043	ND - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall	SS1055	SS - 1st Floor Women's Washroom	ND - Open - No action required
Tuesday, November 29, 2022	Sidney Smith Hall	SS2105K	SS - 2nd Floor Water Fountain (Left) Near SS2128A	ND - Open - No action required
Tuesday, November 29, 2022	Sidney Smith Hall	SS3038	SS - 3rd Floor Student Lounge Kitchen	ND - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall	SS4001K	SS - 4th Floor Water Fountain Near SS4082	ND - Open - No action required
Tuesday, November 29, 2022	Sidney Smith Hall	SS5073	SS - 5th Floor Men's Washroom	68 - Open - Normal operations with preventive maintenance
Monday, August 16, 2021	Sidney Smith Hall	SS8029	SS - 6th Floor Lounge Kitchen	2-8 - Open - No action required
Monday, August 16, 2021	Sidney Smith Hall	SS406	SS - Basement Men's Washroom	ND - Open - No action required
Friday, September 11, 2020	Sidney Smith Hall	SS404	SS - Basement Sid's Cafe	ND - Open - No action required
Tuesday, November 29, 2022	Sidney Smith Hall	SS18K	SS - Sub-Basement Water Fountain Near SS51A	ND - Open - No action required
Monday, September 21, 2020	Simcoe Hall	SI107	SI - 1st Floor Kitchen	ND - Open - No action required
Tuesday, February 28, 2023	Simcoe Hall	SI112A	SI - 1st Floor Kitchen Inside VP Communications	ND - Open - No action required
Wednesday, August 25, 2021	Simcoe Hall	SI102A	SI - 1st Floor Kitchen Near Presidential Board Rooms	ND - Open - No action required
Wednesday, October 6, 2021	Simcoe Hall	SI210W	SI - 2nd Floor All-Gender Washroom	ND - Open - No action required
Friday, October 2, 2020	Simcoe Hall	SI	SI - 2nd Floor Kitchen Near President's Office	ND - Open - No action required
Monday, September 21, 2020	Simcoe Hall	SI228	SI - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, August 25, 2021	Simcoe Hall	SI	SI - 2nd Floor Staff Kitchen Near SI250	ND - Open - No action required
Tuesday, February 28, 2023	Simcoe Hall	SI227	SI - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, October 6, 2021	Simcoe Hall	SI23A	SI - Basement Kitchen	ND - Open - No action required
Monday, September 21, 2020	Simcoe Hall	SI8A	SI - Basement Men's Washroom	ND - Open - No action required
Tuesday, February 28, 2023	Simcoe Hall	SI8A	SI - Basement Men's Washroom	ND - Open - No action required
Wednesday, October 6, 2021	Simcoe Hall	SI8B	SI - Basement Women's Washroom	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD1386	SD - All-Gender Washroom Shower (Jeannette)	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD265	SD - All-Gender Washroom Sink (Wallace)	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD47	SD - Kitchen Sink in Basement	ND - Open - No action required
Thursday, May 13, 2021	Sir Daniel Wilson Residence	SD121	SD - Shower in Washroom (Loudan)	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-665	XG109	XG - 1st Floor Kitchentile	ND - Open - No action required
Friday, August 13, 2021	Spadina Avenue-665	XG109	XG - 1st Floor Kitchentile	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-665	XG111	XG - 1st Floor Women's Washroom	ND - Open - No action required
Friday, August 13, 2021	Spadina Avenue-665	XG111	XG - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703	IA107B	IA - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, October 13, 2021	Spadina Avenue-703	IA107B	IA - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, September 28, 2022	Spadina Avenue-703	IA107B	IA - 1st Floor All-Gender Washroom (Right)	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703	IA205	IA - 2nd Floor Men's Washroom	ND - Open - No action required
Wednesday, September 28, 2022	Spadina Avenue-703	IA204	IA - 2nd Floor Women's Washroom	ND - Open - No action required
Wednesday, December 2, 2020	Spadina Avenue-703	IA302	IA - 3rd Floor Kitchen	ND - Open - No action required



Tuesday, December 13, 2022	University College	UCF302	UC - 3rd Floor All-Gender Washroom	45 - Open - Normal operations with preventive maintenance
Tuesday, February 7, 2023	University College	UCF302	UC - 3rd Floor All-Gender Washroom	38 - Open - Normal operations with preventive maintenance
Tuesday, March 7, 2023	University College	UCF302	UC - 3rd Floor All-Gender Washroom	35 - Open - Normal operations with preventive maintenance
Tuesday, February 22, 2022	University College	UC838	UC - Basement All-Gender Washroom	ND - Open - No action required
Tuesday, February 22, 2022	University College	UC844	UC - Basement Kitchen Sink	ND - Open - No action required
Monday, September 28, 2020	University College	UC89A	UC - Basement Men's Washroom	2600 - Closed - Isolation point of use, remediation required
Monday, October 5, 2020	University College	UC89A	UC - Basement Men's Washroom	11 - Open - Normal operations with preventive maintenance
Tuesday, March 16, 2021	University College	UC89A	UC - Basement Men's Washroom	91 - Open - Normal operations with preventive maintenance
Monday, May 10, 2021	University College	UC89A	UC - Basement Men's Washroom	86 - Closed - Isolation point of use, remediation required
Wednesday, June 9, 2021	University College	UC89A	UC - Basement Men's Washroom	52 - Open - Normal operations with preventive maintenance
Wednesday, June 30, 2021	University College	UC89A	UC - Basement Men's Washroom	90 - Open - Normal operations with preventive maintenance
Thursday, September 9, 2021	University College	UC89A	UC - Basement Men's Washroom	13000 - Closed - Isolation point of use, remediation required
Thursday, October 5, 2021	University College	UC89A	UC - Basement Men's Washroom	2600 - Closed - Isolation point of use, remediation required
Monday, October 18, 2021	University College	UC89A	UC - Basement Men's Washroom	2000 - Closed - Isolation point of use, remediation required
Monday, January 24, 2022	University College	UC89A	UC - Basement Men's Washroom	30 - Open - Normal operations with preventive maintenance
Wednesday, March 2, 2022	University College	UC89A	UC - Basement Men's Washroom	ND - Open - No action required
Thursday, March 24, 2022	University College	UC89A	UC - Basement Men's Washroom	ND - Open - No action required
Thursday, April 19, 2022	University College	UC89A	UC - Basement Men's Washroom	ND - Open - No action required
Wednesday, September 23, 2020	University College	UC89	UC - Basement Water Fountain Near UC89	ND - Open - No action required
Monday, October 5, 2020	University College	UC54	UC - Basement Women's Staff Washroom	ND - Open - No action required
Wednesday, September 23, 2020	University College	UC89	UC - Basement Women's Washroom	410 - Closed - Isolation point of use, remediation required
Monday, September 28, 2020	University College	UC89	UC - Basement Women's Washroom	280 - Closed - Isolation point of use, remediation required
Monday, October 5, 2020	University College	UC89	UC - Basement Women's Washroom	180 - Closed - Isolation point of use, remediation required
Tuesday, March 16, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Monday, May 10, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Wednesday, June 9, 2021	University College	UC89	UC - Basement Women's Washroom	230 - Closed - Isolation point of use, remediation required
Wednesday, June 30, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Thursday, September 9, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Tuesday, October 5, 2021	University College	UC89	UC - Basement Women's Washroom	ND - Open - No action required
Monday, August 30, 2021	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	30 - Open - Normal operations with preventive maintenance
Friday, September 10, 2021	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	410 - Closed - Isolation point of use, remediation required
Wednesday, September 29, 2021	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	23 - Open - Normal operations with preventive maintenance
Monday, June 20, 2022	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	ND - Open - No action required
Monday, June 20, 2022	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	ND - Open - No action required
Wednesday, July 6, 2022	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	ND - Open - No action required
Friday, July 15, 2022	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	12 - Open - Normal operations with preventive maintenance
Tuesday, November 15, 2022	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	72 - Open - Normal operations with preventive maintenance
Tuesday, December 13, 2022	University College Union	UP114	UP - 1st Floor All-Gender Washroom (Commuter Centre)	ND - Open - No action required
Tuesday, August 30, 2021	University College Union	UP208	UP - 2nd Floor Men's Washroom Shower	ND - Open - No action required
Monday, August 30, 2021	University College Union	UP206	UP - 2nd Floor Men's Washroom Shower	3.1 - Open - No action required
Friday, September 10, 2021	University College Union	UP206	UP - 2nd Floor Men's Washroom Shower	5.5 - Open - No action required
Wednesday, September 29, 2021	University College Union	UP206	UP - 2nd Floor Men's Washroom Shower	ND - Open - No action required
Monday, June 20, 2022	University College Union	UP206	UP - 2nd Floor Men's Washroom Shower	ND - Open - No action required
Monday, June 20, 2022	University College Union	UP206	UP - 2nd Floor Men's Washroom Shower	ND - Open - No action required
Wednesday, July 6, 2022	University College Union	UP206	UP - 2nd Floor Men's Washroom Shower	ND - Open - No action required
Monday, August 30, 2021	University College Union	UP206	UP - 3rd Floor Dean's Residence Washroom	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace Studies (UTIAS)	AS180	AS - Cafeteria Kitchen Sink	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace Studies (UTIAS)	AS125A	AS - Lab Sink	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace Studies (UTIAS)	AS125A	AS - Water Fountain (Unfiltered) Near AS154	ND - Open - No action required
Thursday, June 3, 2021	University of Toronto Institute for Aerospace Studies (UTIAS)	AS181	AS - Women's Washroom Shower	ND - Open - No action required
Wednesday, September 9, 2020	Varsity Centre	VA115	VA - 1st Floor Change Room	ND - Open - No action required
Wednesday, September 9, 2020	Varsity Centre	VA119	VA - 1st Floor Change Room	ND - Open - No action required
Friday, August 13, 2021	Varsity Centre	VA113	VA - 1st Floor Changing Room Shower	ND - Open - No action required
Friday, August 13, 2021	Varsity Centre	VA11008	VA - 1st Floor Men's Washroom Sink	ND - Open - No action required
Friday, October 29, 2021	Visitor's Centre	VB18H	VI - Basement Seminar Room Kitchenette	ND - Open - No action required
Wednesday, March 3, 2021	Visitor's Centre	VB17	VI - Men's Accessible Washroom	ND - Open - No action required
Friday, October 29, 2021	Visitor's Centre	VB17	VI - Men's Accessible Washroom	ND - Open - No action required
Wednesday, March 3, 2021	Visitor's Centre	VB20	VI - Women's Accessible Washroom	ND - Open - No action required
Tuesday, February 14, 2023	Wallberg Building	WB132	WB - 1st Floor Lab Sink	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB143	WB - 1st Floor Undergraduate Common Room	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB128K	WB - 1st Floor Water Fountain Near WB123	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB217	WB - 2nd Floor Office Kitchenette	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB238	WB - 2nd Floor Undergrad Common's Room	ND - Open - No action required
Tuesday, February 14, 2023	Wallberg Building	WB348	WB - 2nd Floor Kitchen	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB344	WB - 3rd Floor Lab Sink	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB355	WB - 3rd Floor Men's Washroom	ND - Open - No action required
Tuesday, September 7, 2021	Wallberg Building	WB315K	WB - 3rd Floor Water Fountain Near WB327	ND - Open - No action required
Tuesday, February 14, 2023	Wallberg Building	WB355	WB - 4th Floor All-Gender Washroom	ND - Open - No action required
Tuesday, February 14, 2023	Wallberg Building	WB355	WB - 4th Floor All-Gender Washroom	ND - Open - No action required
Thursday, October 22, 2020	Wallberg Building	WB3A	WB - Basement Women's Washroom	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - 1st Floor Shower Closet to Pool	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB36C	WS - Basement Men's Changing Room Shower	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB7E	WS - Basement Pool Men's Varsity Changing Room Shower	ND - Open - No action required
Friday, October 1, 2021	Warren Stevens Building	WSB9E	WS - Basement Pool Women's Varsity Changing Room Shower	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WSB31	WS - Basement Women's Changing Room Shower	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - Family Change Room	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - First Floor Accessible Washroom	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - Men's Change Room Sample 1	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - Men's Change Room Sample 2	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - Women's Change Room Sample 1	ND - Open - No action required
Monday, September 7, 2020	Warren Stevens Building	WS	WS - Women's Change Room Sample 2	ND - Open - No action required
Thursday, September 16, 2021	Welmore Hall-New College	WE103	WE - 1st Floor Accessible Washroom	ND - Open - No action required
Tuesday, December 15, 2020	Welmore Hall-New College	WE114	WE - 1st Floor Men's Washroom	ND - Open - No action required
Tuesday, December 15, 2020	Welmore Hall-New College	WE114	WE - 1st Floor Water Fountain Near Room 114	ND - Open - No action required
Tuesday, December 15, 2020	Welmore Hall-New College	WE296	WE - 2nd Floor All-Gender Washroom	ND - Open - No action required
Thursday, September 16, 2021	Welmore Hall-New College	WE296	WE - 2nd Floor All-Gender Washroom Shower	ND - Open - No action required
Tuesday, December 15, 2020	Welmore Hall-New College	WE296	WE - 2nd Floor Washroom Shower	ND - Open - No action required
Thursday, September 16, 2021	Welmore Hall-New College	WE422	WE - 2nd Floor All-Gender Washroom Shower	ND - Open - No action required
Thursday, September 16, 2021	Welmore Hall-New College	WE452	WE - 4th Floor All-Gender Washroom	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	FA110	WT - 1st Floor All-Gender Washroom	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	CO238	WT - 2nd Floor Kitchen	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	MJ378	WT - 3rd Floor Shower	ND - Open - No action required
Wednesday, May 5, 2021	Whitney Hall	FE69	WT - Basement Shower	ND - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI295A	WI - 2nd Floor Kitchen Sink	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI	WI - 2nd Floor Sink "Coffee Shed"	ND - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI3075	WI - 3rd Floor Common Room Kitchen Sink	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI3071	WI - 3rd Floor Men's Washroom Sink (previously All-Gender Washroom)	6.4 - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI3071	WI - 3rd Floor Men's Washroom Sink (previously All-Gender Washroom)	3.1 - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI3071	WI - 3rd Floor Men's Washroom Sink (previously All-Gender Washroom)	ND - Open - No action required
Tuesday, June 14, 2022	Wilson Hall-New College	WI3071	WI - 3rd Floor Men's Washroom Sink (previously All-Gender Washroom)	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI4002	WI - 4th Floor Common Room Sink	ND - Open - No action required
Thursday, May 20, 2021	Wilson Hall-New College	WI4003	WI - 4th Floor Women's Washroom Shower	ND - Open - No action required
Thursday, May 27, 2021	Wilson Hall-New College	WI4071	WI - 4th Floor Women's Washroom Sink	5 - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI4071	WI - 4th Floor Women's Washroom Sink	ND - Open - No action required
Tuesday, June 14, 2022	Wilson Hall-New College	WI4071	WI - 4th Floor Women's Washroom Sink	ND - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI5071	WI - 5th Floor Women's Washroom Sink (previously All-Gender Washroom)	4.3 - Open - No action required
Tuesday, June 14, 2022	Wilson Hall-New College	WI5071	WI - 5th Floor Women's Washroom Sink (previously All-Gender Washroom)	ND - Open - No action required
Thursday, June 3, 2021	Wilson Hall-New College	WI6057A	WI - 6th Floor Women's Washroom Sink (previously All-Gender Washroom)	3.4 - Open - No action required
Tuesday, June 14, 2022	Wilson Hall-New College	WI6057A	WI - 6th Floor Women's Washroom Sink (previously All-Gender Washroom)	ND - Open - No action required
Tuesday, November 10, 2020	Woodsworth College	WW107G	WW - 1st Floor Kitchen	ND - Open - No action required
Tuesday, November 10, 2020	Woodsworth College	WW	WW - 1st Floor Women's Washroom Near 121	ND - Open - No action required
Tuesday, November 10, 2020	Woodsworth College	WW	WW - 2nd Floor All-Gender Washroom Near 227	ND - Open - No action required
Thursday, September 30, 2021	Woodsworth College	WW212	WW - 2nd Floor Kitchen	ND - Open - No action required
Thursday, September 30, 2021	Woodsworth College	WW	WW - 2nd Floor Kitchenette Near WW227	ND - Open - No action required
Thursday, September 30, 2021	Woodsworth College	WW7	WW - Basement Women's Washroom	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO1001	WO - 10th Floor Kitchen Sink	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO1702	WO - 17th Floor Bathroom 1 Shower	ND - Open - No action required
Monday, February 1, 2021	Woodsworth College Residence	WO	WO - 1st Floor Kitchen	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO	WO - 1st Floor Kitchen	ND - Open - No action required
Monday, February 1, 2021	Woodsworth College Residence	WO	WO - 1st Floor Women's Washroom	ND - Open - No action required
Wednesday, June 2, 2021	Woodsworth College Residence	WO503	WO - 5th Floor Bathroom 1 Sink	ND - Open - No action required
Monday, February 1, 2021	Woodsworth College Residence	WO	WO - Basement Men's Washroom	ND - Open - No action required