Table 3 - Water Testing - UTSC Results - November 10, 2023

Level	GU/mL
1	<10
2	10-100
3	>100

Level	CFU/mL
1	<10
2	10-100
3	>100

ND - None Detected **ND - None Detected**

Test Date	Building	Room Tested	Room Description	Room Status q-PCR results	Room Status - culture (validation) results
Thursday, March 11, 2021	Science Research		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Joan Foley Hall		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Arts and Administration		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Students Centre		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	N'sheemaehn Child Care Centre		Culture Validation	N/A	ND - Open - No action required
Thursday, March 11, 2021	Instructional Centre		Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	K-05		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	L-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	E-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	I-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	H-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	J-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	A-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	B-01		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	G-08		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Thursday, March 18, 2021	H-02		Residence townhouse - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Arts and Administration		1st Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Arts and Administration		2nd Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Instructional Centre - IC40	IC40	Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Instructional Centre		Mechanical room - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Students Centre - SL241	SL241	Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Students Centre		Basement - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Social Sciences		1st Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Social Sciences		3rd Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Joan Foley Hall		1st Floor - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Joan Foley Hall		Boiler Room - Culture Validation	N/A	ND - Open - No action required
Monday, March 29, 2021	Arts and Administration		1st Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Arts and Administration		2nd Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Instructional Centre - IC40	IC40		ND - Open - No action required	N/A
Monday, March 29, 2021	Instructional Centre		Mechanical room	ND - Open - No action required	N/A
Monday, March 29, 2021	Students Centre - SL241	SL241		ND - Open - No action required	N/A
Monday, March 29, 2021	Students Centre		Basement	ND - Open - No action required	N/A
Monday, March 29, 2021	Social Sciences		1st Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Social Sciences		3rd Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Joan Foley Hall		1st Floor	ND - Open - No action required	N/A
Monday, March 29, 2021	Joan Foley Hall		Boiler Room	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Highland Hall		Mechanical Rm.	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Environmental Sciences and Chemistry Building		Rm. 4th floor washroom close to EV431	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Environmental Sciences and Chemistry Building		Rm. 1st floor washroom close to EV121	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Bladen Wing		4th floor washroom close to BV450	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Bladen Wing 2nd floor washroom close to BV222		4th floor washroom close to BV450	ND - Open - No action required	N/A
Wednesday, April 14, 2021	Academic Resource Centre	AC226		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Humanities Wing	HW218		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Science Wing	SW306		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Science Wing	SW522		ND - Open - No action required	N/A
Wednesday, April 14, 2021	Science Research Building	SY141	Initial analysis showed PCR inhibition but re-analysis using a 1.6 GU/ml detection limit showed not detected	ND - Open - No action required	N/A
Friday, June 4, 2021	Miller Lash House	Kitchen	Sink	ND - Open - No action required	N/A
Friday, June 4, 2021	Environmental Sciences and Chemistry Building	Chiller room		ND - Open - No action required	N/A
Friday, June 4, 2021	Science Wing	6th Floor Mechanical room		ND - Open - No action required	N/A
Thursday, June 10, 2021	G-01		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	M-08		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	B-08		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	E-09		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	Residences	Laundry room	Near K-01	ND - Open - No action required	N/A
Thursday, June 10, 2021	K-01		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	A-11		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	I-04		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	F-09		Kitchen sink	ND - Open - No action required	N/A
Thursday, June 10, 2021	H-06		Kitchen sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Joan Foley Hall	Laundry room 100L	Sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Social Sciences Building	1st floor Women washroom	Near MW120	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Environmental Sciences and Chemistry Building	1st floor Women washroom	Near EV121	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Science Research Building	1st floor Women washroom	Near SY141	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Arts and Administration	1st floor Women washroom	Near AA122	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Academic Resource Centre	AC226	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Science Wing	SW306	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Humanities Wing	HW218	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Highland Hall	1st floor Women washroom	Near HL170	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Bladen Wing	BV203	Bathroom sink	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Instructional Centre	1st floor Women washroom	Near IC118	ND - Open - No action required	N/A
Tuesday, August 31, 2021	Student Centre	1st floor Women washroom	Near SL151	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Instructional Centre	IC430A	Domestic hot water	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Science Research Building	4th floor	Domestic hot water	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Humanities Wing	4th floor	Domestic hot water for MW	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Science Wing	SW103B	Domestic hot water for HW, BV, AC, SW	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Humanities Wing	HW 5th floor	Domestic hot water for JFH	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Arts and Administration	Basement	Domestic hot water	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Student Centre	SL033	Domestic hot water	ND - Open - No action required	N/A
Tuesday, December 7, 2021	Environmental Sciences and Chemistry Building	EV 6th floor	Domestic hot water	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Bladen Wing	BV563	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Bladen Wing	BV206A	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Bladen Wing	BV505	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Bladen Wing	BV207A	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Academic Resource Centre	AC227	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Academic Resource Centre	AC205A	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Arts and Administration	AA139	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Arts and Administration	AA137	Faucet	Open - No action required	N/A
Wednesday, December 8, 2021	Arts and Administration	AA408	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Social Sciences Building	MW396	Faucet	ND - Open - No action required	N/A
Wednesday, December 8, 2021	Social Sciences Building	MW296	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Student Centre	SL161	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Student Centre	SL266K	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Environmental Sciences and Chemistry Building	EV431	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Environmental Sciences and Chemistry Building	EV531	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Humanities Wing	HW403	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Humanities Wing	HW104	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Science Wing	SW300E	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Science Wing	SW303M	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Science Wing	SW524A	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Science Research Building	SY366	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Instructional Centre	IC480	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Instructional Centre	IC280	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Highland Hall	HL127	Faucet	ND - Open - No action required	N/A
Thursday, December 9, 2021	Highland Hall	HL516	Faucet	ND - Open - No action required	N/A
Tuesday, December 14, 2021	Arts and Administration	AA137	Faucet	ND - Open - No action required	N/A
Friday, January 28, 2022	Arts and Administration	AA135	Kitchenette faucet near	ND - Open - No action required	N/A
Friday, January 28, 2022	Arts and Administration	AA407	Kitchenette faucet near	ND - Open - No action required	N/A
Friday, January 28, 2022	Arts and Administration	AA121	Drinking fountain near	ND - Open - No action required	N/A
Friday, January 28, 2022	Social Sciences Building	MW296	Faucet	ND - Open - No action required	N/A
Friday, January 28, 2022	Social Sciences Building	MW396	Faucet	ND - Open - No action required	N/A
Friday, January 28, 2022	Social Sciences Building	MW140	Drinking fountain near	ND - Open - No action required	N/A
Friday, January 28, 2022	Instructional Centre	IC280	Kitchenette faucet	ND - Open - No action required	N/A
Friday, January 28, 2022	Instructional Centre	IC480	Kitchenette faucet	ND - Open - No action required	N/A
Friday, January 28, 2022	Instructional Centre	IC380	Kitchenette faucet	ND - Open - No action required	N/A
May 12, 2022	Tennis Court	Valley	Drinking fountain	ND - Open - No action required	N/A
May 12, 2022	Coach House	Valley	Drinking fountain	ND - Open - No action required	N/A
May 12, 2022	Baseball Field	Valley	Drinking fountain	ND - Open - No action required	N/A
May 19, 2022	Coach House	Valley	Drinking fountain	Open - No action required	N/A
May 19, 2022	Tennis Court	Valley	Drinking fountain	ND - Open - No action required	N/A
May 19, 2022	Baseball Diamond	Valley	Elkay fountain	ND - Open - No action required	N/A
May 19, 2022	Baseball Diamond	Valley	Free standing water fountain	ND - Open - No action required	N/A
May 19, 2022	Mechanical Workshop	Valley	Interior water dispenser	ND - Open - No action required	N/A
May 19, 2022	Mechanical Workshop	Valley	Exterior water fountain	ND - Open - No action required	N/A
May 24, 2022	Coach House	Valley	Drinking fountain	Open - No action required	N/A
May 30, 2022	Coach House	Valley	Drinking fountain	ND - Open - No action required	N/A
August 30, 2023	Arts and Administration	Women's washroom near AA122	Sink	ND - Open - No action required	N/A
August 30, 2023	Academic Resource Centre	Women's washroom near AC326	Sink	ND - Open - No action required	N/A
August 30, 2023	Bladen Wing	Women's washroom near BV203	Sink	ND - Open - No action required	N/A
August 30, 2023	Child Care Centre	Main floor staff kitchen	Sink	ND - Open - No action required	N/A
August 30, 2023	Environmental Sciences and Chemistry Building		Cooling Tower	ND - Open - No action required	N/A
August 30, 2023	Humanities Wing	Women's washroom near HW218	Sink	ND - Open - No action required	N/A
August 30, 2023	Highland Hall	Women's washroom near HL170	Sink	ND - Open - No action required	N/A
August 30, 2023	Instructional Centre	Women's washroom first floor	Sink	ND - Open - No action required	N/A
August 30, 2023	Social Sciences	Women's washroom near MW120	Sink	ND - Open - No action required	N/A
August 30, 2023	Student Centre	Women's washroom main floor	Sink	ND - Open - No action required	N/A
August 30, 2023	Science Research Building	Women's washroom main floor	Sink	ND - Open - No action required	N/A
August 30, 2023	Science Wing	Women's washroom near SW306	Sink	ND - Open - No action required	N/A
August 30, 2023	Science Wing	Women's washroom near SW214	Sink	ND - Open - No action required	N/A
August 30, 2023	Joan Foley Hall	First floor laundry room	Sink	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	A1	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	C1	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	E1	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	G9	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	H3	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	J3	ND - Open - No action required	N/A
August 30, 2023	Residence Townhouse	First floor kitchen	L4	ND - Open - No action required	N/A
August 30, 2023	Science Wing	Roof	Main Cooling Tower	Open - No action required	N/A
August 30, 2023	Student Centre	Roof	Cooling Tower	*Inhibition	*PCR inhibition may be caused by presence of chemicals, minerals or DNA of other organisms
August 30, 2023	Social Sciences Building	Roof	Management Tower	ND - Open - No action required	N/A
August 30, 2023	Instructional Centre	Roof	IC Tower	ND - Open - No action required	N/A
August 30, 2023	Environmental Sciences and Chemistry Building	Women's washroom main floor	Sink	ND - Open - No action required	N/A
September 11, 2023	Student Centre	Roof	Cooling Tower	ND - Open - No action required	Retest of the previous inhibition sample