

Table 4 - Water Testing - UTM Results - April 3, 2025				Level	GU/ml	Level	CFU/mL
				1	<10	1	<10
				2	10-100	2	10-100
				3	>100	3	>100
				ND - None detected		ND - None detected	
Test Date	Building	Room Tested	Room Description	Room Status q-PCR results	Room Status - culture (validation) results		
21-Apr-21	Erindale Hall	Suite 207		n/a	ND - Open - No action required		
21-Apr-21	HMALC Building	Rm253	Caretaker closet on level 2	n/a	ND - Open - No action required		
21-Apr-21	Oscar Peterson Hall	Rm 600C	6th Floor- Caretaking Closet	n/a	ND - Open - No action required		
21-Apr-21	Roy Ivor Hall, BLOCK A	Rm 606		n/a	ND - Open - No action required		
21-Apr-21	Roy Ivor Hall, BLOCK B	Rm 621		n/a	ND - Open - No action required		
21-Apr-21	Roy Ivor Hall, BLOCK C		Main Floor Caretakers closet	n/a	ND - Open - No action required		
21-Apr-21	Roy Ivor Hall, BLOCK D	Rm 645		n/a	ND - Open - No action required		
21-Apr-21	WG Davis Building	DC5036	Greenhouse	n/a	ND - Open - No action required		
21-Apr-21	WG Davis Building, ABCD Block	DV5004	5th floor washroom	n/a	90 - Open - Normal operations with preventative maintenance		
30-Apr-21	WG Davis Building, ABCD Block	DV5004	5th floor washroom	ND - Open - No action required	n/a		
7-Jun-21	Margarth Valley 154		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	Leacock Lane 132		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	Putnam Place 107		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	McLuhan Ct 56		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	Leacock Lane 148		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	McLuhan Ct. 88		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	McGrath Valley 225		Townhouse	n/a	ND - Open - No action required		
7-Jun-21	Putnam Place 95		Townhouse	n/a	ND - Open - No action required		
20-Jul-21	MN building		Hot Water Tank (HWT) 1	n/a	3 - Open - No action required		
20-Jul-21	MN building		Hot Water Tank (HWT) 2	n/a	ND - Open - No action required		
20-Jul-21	MN building		Hot Water faucet (HW)	n/a	ND - Open - No action required		
20-Jul-21	Deerfield Hall		Hot Water Tank (HWT) 3	n/a	1 - Open - No action required		
20-Jul-21	Deerfield Hall		Hot Water Tank (HWT) 2	n/a	ND - Open - No action required		
20-Jul-21	Deerfield Hall		Hot Water Tank (HWT) 1	n/a	ND - Open - No action required		
20-Jul-21	Deerfield Hall		Hot Water faucet (HW)	n/a	4 - Open - No action required		
10-Aug-21	RAWC	Men's locker rm 115	Hot Water faucet (HW)	n/a	ND - Open - No action required		
10-Aug-21	RAWC		Hot Water Tank (HWT) 1	n/a	ND - Open - No action required		
10-Aug-21	RAW		Hot Water Tank (HWT) 2	n/a	ND - Open - No action required		
10-Aug-21	HSC	Penhouse Mech Room	Hot Water faucet (HW)	n/a	ND - Open - No action required		
10-Aug-21	DV JKL	Caretaking closet Rm 1111	Hot Water faucet (HW)	n/a	ND - Open - No action required		
24-Aug-21	CCT		Hot Water Tank (HWT) 1	n/a	ND - Open - No action required		
24-Aug-21	CCT		Hot Water Tank (HWT) 2	n/a	ND - Open - No action required		
24-Aug-21	CCT	4199 - sink in caretaking closet	Hot Water (HW) faucet	n/a	ND - Open - No action required		
24-Aug-21	IB	29 - sink in basement mechanical room	Hot Water (HW) faucet	n/a	ND - Open - No action required		
24-Aug-21	IB		Hot Water Tank (HWT) 1	n/a	ND - Open - No action required		
2-Dec-21	Central Utilities Plant	BSMT	Basement (HWT)	n/a	ND - Open - No action required		
2-Dec-21	Student Centre	136	Mechanical Room (HWT #1)	n/a	ND - Open - No action required		
2-Dec-21	Student Centre	136	Mechanical Room (HWT #2)	n/a	ND - Open - No action required		
2-Dec-21	Student Centre	209	Kitchen tap	n/a	ND - Open - No action required		
2-Dec-21	Instructional Centre (IB)	29	Mechanical Room (HWT #1)	n/a	ND - Open - No action required		
2-Dec-21	Instructional Centre (IB)	29	Mechanical Room (HWT #2)	n/a	ND - Open - No action required		
2-Dec-21	Instructional Centre (IB)	105	Pantry (HWT#3)	n/a	ND - Open - No action required		
2-Dec-21	Research Greenhouse	100	Mechanical Room (HWT)	n/a	ND - Open - No action required		
2-Dec-21	Lislehurst Building	BSMT	Basement (HWT #1)	n/a	ND - Open - No action required		
2-Dec-21	Lislehurst Building	BSMT	Basement (HWT#2)	n/a	ND - Open - No action required		
2-Dec-21	Lislehurst Building	Kitchen	Kitchen tap	n/a	ND - Open - No action required		
2-Dec-21	Early Learning Centre	113	Hot Water Tank	n/a	ND - Open - No action required		
2-Dec-21	Early Learning Centre	113	laundry sink tap	n/a	ND - Open - No action required		
2-Dec-21	Alumni House	1A	Mechanical Room (HWT)	n/a	ND - Open - No action required		
2-Dec-21	Alumni House	3	kitchen tap	n/a	ND - Open - No action required		
2-Dec-21	Kaneff Building	269	Mechanical Room (HWT #1)	n/a	ND - Open - No action required		
2-Dec-21	Kaneff Building	131	CC slop sink tap	n/a	ND - Open - No action required		
2-Dec-21	Kaneff Building	269	Mechanical Room (HWT #2)	n/a	ND - Open - No action required		
2-Dec-21	Innovation Complex	I1274	Mechanical Room (HWT #1)	n/a	ND - Open - No action required		
2-Dec-21	Innovation Complex	I1274	Mechanical Room (HWT #2)	n/a	ND - Open - No action required		
2-Dec-21	Academic Annex	111A	Hot Water Tank	n/a	ND - Open - No action required		
14-Jul-22	Central Utilities Plant	BSMT	Basement (HWT)	n/a	ND - Open - No action required		
14-Jul-22	WG Davis Building, ABCD Block	BSMT, Block A	Basement (HWT)	n/a	ND - Open - No action required		
14-Jul-22	RAWC Building	Basement	Hot Water Tank #1	n/a	ND - Open - No action required		
14-Jul-22	RAWC Building	Pool Tunnel	Pool Tunnel HWT #2	n/a	ND - Open - No action required		
14-Jul-22	Central Utilities Plant	Lunch room	Lunch Room	n/a	ND - Open - No action required		
14-Jul-22	WG Davis Building, ABCD Block	DV3029	Caretaking closet	n/a	12 - Open - Normal operations with preventative maintenance		
28-Jul-22	WG Davis Building, ABCD Block	DV3029	Caretaking closet	0.5 GU/ml-Open-No action required			
14-Jul-22	WG Davis Building, JKL	Rm 1111		n/a	ND - Open - No action required		
14-Jul-22	RAWC Building	Family Change Room	Family Change Room	n/a	ND - Open - No action required		
9-Sep-22	Oscar Peterson Hall	6th Floor	Hot Water Tank #1	n/a	ND - Open - No action required		
9-Sep-22	Oscar Peterson Hall	6th Floor	Hot Water Tank #2	n/a	ND - Open - No action required		
9-Sep-22	Oscar Peterson Hall	6th Floor	Hot Water Tank #3	n/a	ND - Open - No action required		
9-Sep-22	Roy Ivor Hall	Block A	Hot Water Tank #1	n/a	ND - Open - No action required		
9-Sep-22	Roy Ivor Hall	Block A	Hot Water Tank #2	n/a	ND - Open - No action required		
9-Sep-22	Roy Ivor Hall	Block B	Hot Water Tank #1	n/a	ND - Open - No action required		
20-Sep-22	Erindale Hall	500W	Hot Water Tank #1	n/a	ND - Open - No action required		
20-Sep-22	Erindale Hall	500W	Hot Water Tank #2	n/a	31 - Open - Normal operations with preventative maintenance		
12-Oct-22	Erindale Hall	500W	Hot Water Tank #2	ND - Open - No action required			
20-Sep-22	Student Centre	Ground	Hot Water Tank #1	n/a	ND - Open - No action required		
20-Sep-22	Student Centre	Ground	Hot Water Tank #2	n/a	ND - Open - No action required		
20-Sep-22	Deerfield Hall		Hot Water Tank #1	n/a	ND - Open - No action required		
20-Sep-22	Deerfield Hall		Hot Water Tank #2	n/a	ND - Open - No action required		
20-Sep-22	Deerfield Hall		Hot Water Tank #3	n/a	ND - Open - No action required		
20-Sep-22	Maanjwive nendamowinan		Hot Water Tank #1	n/a	ND - Open - No action required		
20-Sep-22	Maanjwive nendamowinan		Hot Water Tank #2	n/a	ND - Open - No action required		
20-Sep-22	William G. Davis Building, A Block	Room 1016	Hot Water Tank	n/a	ND - Open - No action required		
6-Oct-22	Erindale Hall	Laundry Room	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Oscar Peterson Hall	Room 128	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Roy Ivor Hall, BLOCK A	Room 601	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Roy Ivor Hall, BLOCK B	Room 616	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Roy Ivor Hall, BLOCK C	Room 631	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Roy Ivor Hall, BLOCK D	Room 641	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Schreiberwood	Room 27	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	McLuhan Court	Room 90	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Putnam Place	Room 115	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Leacock Lane	Room 145	Hot Water faucet (HW)	n/a	ND - Open - No action required		
6-Oct-22	Magrath Valley	Room 154	Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	CCT Building		Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	HMALC Building	C253	Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	Research Greenhouse		Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	Instructional Centre (IB)		Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	Deerfield Hall	Room 1020	Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	Maanjwive nendamowinan		Hot Water faucet (HW)	n/a	ND - Open - No action required		
17-Nov-22	Research Greenhouse	Ground	Hot Water Tank	n/a	ND - Open - No action required		
1-Dec-22	HSC		Hot Water faucet (HW)	n/a	1-Open - No action required		
1-Dec-22	Student Centre		Hot Water faucet (HW)	n/a	ND - Open - No action required		
1-Dec-22	Alumni House		Hot Water faucet (HW)	n/a	1-Open - No action required		
14-Dec-22	CCT Building	CC5140	Hot Water Tank #1	n/a	ND - Open - No action required		
14-Dec-22	HMALC Building	Penthouse	Hot Water Tank	n/a	ND - Open - No action required		
14-Dec-22	Instructional Centre (IB)	Chiller Room 29	Hot Water Tank #1	n/a	ND - Open - No action required		
14-Dec-22	Early Learning Centre		Hot Water Tank	n/a	ND - Open - No action required		
14-Dec-22	Early Learning Centre	Room 113	Hot Water faucet (HW)	n/a	ND - Open - No action required		
14-Dec-22	Kaneff Centre	Room 269	Hot Water Tank #2	n/a	ND - Open - No action required		
14-Dec-22	Kaneff Centre	KN 131A	Hot Water faucet (HW)	n/a	ND - Open - No action required		
14-Dec-22	Innovation Complex		Hot Water Tank #1	n/a	ND - Open - No action required		
14-Dec-22	Innovation Complex		Hot Water Tank #2	n/a	ND - Open - No action required		
14-Dec-22	Academic Annex	AX111A	Hot Water Tank	n/a	ND - Open - No action required		
9-Mar-23	Kaneff Centre		Hot Water Tank #2	n/a	ND - Open - No action required		
9-Mar-23	Roy Ivor Hall	Laundry Room	Hot Water Tank	n/a	ND - Open - No action required		
9-Mar-23	Roy Ivor Hall	Pod B	Hot Water Tank	n/a	ND - Open - No action required		
9-Mar-23	RAWC	Men's Shower	Hot Water faucet (HW)	n/a	ND - Open - No action required		
9-Mar-23	RAWC	Women's Shower	Hot Water faucet (HW)	n/a	ND - Open - No action required		
9-Mar-23	Instructional Centre (IB)	Kitchen	Hot Water Tank	n/a	ND - Open - No action required		
9-Mar-23	Instructional Centre (IB)	Chiller Room	Hot Water Tank	n/a	ND - Open - No action required		
31-Mar-23	Lislehurst Building		DHWT #1	n/a	1-Open - No action required		
31-Mar-23	Lislehurst Building		DHWT #2	n/a	ND - Open - No action required		
31-Mar-23	Lislehurst Building		Potable Hot Water	n/a	1-Open - No action required		
31-Mar-23	Roy Ivor Hall	Pod C	DHWT	n/a	ND - Open - No action required		

31-Mar-23	Roy Ivor Hall	Pod D	DHWT	n/a	ND - Open - No action required
31-Mar-23	RAWC	Spa	Hot Water faucet (HW)	n/a	ND - Open - No action required
17-Jul-23	Kaneff Centre	KN 269	Hot Water Tank #1	n/a	ND - Open - No action required
17-Jul-23	Kaneff Centre	KN 269	Hot Water Tank #2	n/a	ND - Open - No action required
17-Jul-23	Kaneff Centre	KN 131	Hot Water faucet (HW)	n/a	ND - Open - No action required
17-Jul-23	Instructional Centre (IB)	Chiller Room (IB029)	Hot Water faucet (HW)	n/a	ND - Open - No action required
17-Jul-23	Instructional Centre (IB)	Chiller Room (IB029)	DHWT	n/a	ND - Open - No action required
17-Jul-23	Maanjwew nendamowinan	Room 7250	Hot Water Tank #1	n/a	ND - Open - No action required
17-Jul-23	Maanjwew nendamowinan	Room 7250	Hot Water Tank #2	n/a	ND - Open - No action required
17-Jul-23	Maanjwew nendamowinan	Room 1132	Hot Water faucet (HW)	n/a	ND - Open - No action required
17-Jul-23	CCT	Room 4199	Hot Water faucet (HW)	n/a	ND - Open - No action required
17-Jul-23	CCT	Room 5130	Hot Water Tank	n/a	ND - Open - No action required
17-Jul-23	Deerfield Hall	Room 5080	Hot Water Tank #1	n/a	ND - Open - No action required
17-Jul-23	Deerfield Hall	Room 5080	Hot Water Tank #2	n/a	ND - Open - No action required
17-Jul-23	Deerfield Hall	Room 5080	Hot Water Tank #3	n/a	ND - Open - No action required
17-Jul-23	Deerfield Hall	Room 1074	Hot Water faucet (HW)	n/a	ND - Open - No action required
8-Aug-23	Roy Ivor Hall	Pod A Room 603	Potable Hot Water	n/a	ND - Open - No action required
8-Aug-23	Roy Ivor Hall	Pod B Room 618	Potable Hot Water	n/a	ND - Open - No action required
8-Aug-23	Roy Ivor Hall	Pod C Room 632	Potable Hot Water	n/a	ND - Open - No action required
8-Aug-23	Erindale Hall	Room 106	Potable Hot Water	n/a	ND - Open - No action required
8-Aug-23	Oscar Peterson Hall	Lobby Washroom	Potable Hot Water	n/a	ND - Open - No action required
9-Aug-23	Erindale Hall	500W	Hot Water Tank #1	n/a	ND - Open - No action required
9-Aug-23	Erindale Hall	500W	Hot Water Tank #2	n/a	ND - Open - No action required
9-Aug-23	Oscar Peterson Hall	7th Floor	Hot Water Tank #1	n/a	ND - Open - No action required
9-Aug-23	Oscar Peterson Hall	7th Floor	Hot Water Tank #2	n/a	ND - Open - No action required
9-Aug-23	Roy Ivor Hall	Pod B	Hot Water Tank #1	n/a	ND - Open - No action required
9-Aug-23	Roy Ivor Hall	Pod B	Hot Water Tank #2	n/a	ND - Open - No action required
9-Aug-23	Roy Ivor Hall	Pod A	Hot Water Tank #1	n/a	ND - Open - No action required
9-Aug-23	Roy Ivor Hall	Pod A	Hot Water Tank #2	n/a	ND - Open - No action required
18-Sep-23	Central Utilities Plant		Hot Water faucet (HW)	n/a	60 - Open - Normal operations with preventative maintenance
28-Sep-23	Central Utilities Plant	Kitchen	Hot Water faucet (HW)	0.62 GU/ml	Open - No action required
18-Sep-23	Central Utilities Plant	Basement	Hot Water Tank	n/a	40 - Open - Normal operations with preventative maintenance
28-Sep-23	Central Utilities Plant		Hot Water Tank	ND - Open - No action required	
18-Sep-23	William G. Davis Building, JKL Block	Room 2115J	Hot Water faucet (HW)	n/a	ND - Open - No action required
19-Sep-23	William G. Davis Building, ABCD	Room 4034	Hot Water faucet (HW)	n/a	ND - Open - No action required
19-Sep-23	RAWC	Pool Room	Hot Water faucet (HW)	n/a	ND - Open - No action required
20-Sep-23	RAWC		Hot Water Tank #1	n/a	ND - Open - No action required
20-Sep-23	RAWC		Hot Water Tank #2	n/a	ND - Open - No action required
12-Oct-23	McLuhan Court	Unit 55	Potable Hot Water	n/a	ND - Open - No action required
12-Oct-23	Schreiberwood	Unit 25	Potable Hot Water	n/a	ND - Open - No action required
12-Oct-23	MaGrath Valley	Unit 156	Potable Hot Water	n/a	ND - Open - No action required
12-Oct-23	Leacock Lane	Unit 117	Potable Hot Water	n/a	ND - Open - No action required
12-Oct-23	Putnam Place	Unit 92	Potable Hot Water	n/a	ND - Open - No action required
24-Jan-24	Early Learning Centre	Laundry Room	Potable Hot Water	n/a	ND - Open - No action required
24-Jan-24	Early Learning Centre	Laundry Room	Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	Student Centre	Room 124	Potable Hot Water	n/a	ND - Open - No action required
24-Jan-24	Student Centre		Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	Student Centre		Hot Water Tank #2	n/a	ND - Open - No action required
24-Jan-24	Academic Annex	Room MC	Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	Alumni House	Mechanical Room	Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	Alumni House	Room 104	Potable Hot Water	n/a	ND - Open - No action required
24-Jan-24	Innovation Complex	Room 1247	Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	Innovation Complex	Room 1247	Hot Water Tank #2	n/a	ND - Open - No action required
24-Jan-24	Lislehurst Building	Boiler Room	Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	Lislehurst Building	Boiler Room	Hot Water Tank #2	n/a	1 - Open - No action required
24-Jan-24	Lislehurst Building	Room 1020	Potable Hot Water	n/a	1 - Open - No action required
24-Jan-24	HMALC Building	Mechanical Penthouse	Hot Water Tank #1	n/a	ND - Open - No action required
24-Jan-24	HMALC Building	Room 253	Potable Hot Water	n/a	ND - Open - No action required
13-Feb-24	William G. Davis Building	Tunnel HX - Basement, Block A	Hot Water Tank	n/a	1 - Open - No action required
13-Feb-24	CCT	Penthouse	Hot Water Tank #2	n/a	ND - Open - No action required
13-Feb-24	Roy Ivor Hall	Laundry Room	Hot Water Tank	n/a	ND - Open - No action required
13-Feb-24	Roy Ivor Hall	Block C	Hot Water Tank	n/a	ND - Open - No action required
13-Feb-24	Roy Ivor Hall	Block D	Hot Water Tank	n/a	ND - Open - No action required
13-Feb-24	Instructional Centre (IB)	Kitchen	Hot Water Tank	n/a	ND - Open - No action required
13-Feb-24	Greenhouse	Ground	Hot Water Tank	n/a	ND - Open - No action required
13-Feb-24	Greenhouse		Potable Hot Water	n/a	ND - Open - No action required
13-Feb-24	HSC		Potable Hot Water	n/a	ND - Open - No action required
13-Feb-24	RAWC	Men's Washroom	Shower Hot Water	n/a	ND - Open - No action required
13-Feb-24	RAWC	Women's Washroom	Shower Hot Water	n/a	ND - Open - No action required
12-Jun-24	Instructional Centre (IB)	Penthouse	Hot Water Tank	n/a	ND - Open - No action required
12-Jun-24	RAWC		Hot Tub	n/a	ND - Open - No action required
7-Aug-24	CUP		Cooling Tower	n/a	ND - Open - No action required
7-Aug-24	Library		Cooling Tower	n/a	0 - Open - No action required
7-Aug-24	CCT		Cooling Tower	n/a	ND - Open - No action required
7-Aug-24	New Science Building (NSB)		Cooling Tower	n/a	ND - Open - No action required
22-Jan-25	CCT		Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Maanjwew nendamowinan		Potable Hot Water	n/a	ND - Open - No action required
22-Jan-25	Deerfield Hall		Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Erindale Hall		Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Maanjwew nendamowinan		Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Maanjwew nendamowinan		Hot Water Tank #2	n/a	ND - Open - No action required
22-Jan-25	William G. Davis Building		BC Tower	n/a	1 - Open - No action required
22-Jan-25	Roy Ivor Hall	Pod A	Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Erindale Hall		Hot Water Tank #2	n/a	ND - Open - No action required
22-Jan-25	Roy Ivor Hall	Pod B	Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Roy Ivor Hall	Pod B	Hot Water Tank #2	n/a	ND - Open - No action required
22-Jan-25	Oscar Peterson Hall		Hot Water Tank #1	n/a	ND - Open - No action required
22-Jan-25	Roy Ivor Hall	Pod A	Hot Water Tank #2	n/a	ND - Open - No action required
22-Jan-25	Deerfield Hall		Hot Water Tank #2	n/a	ND - Open - No action required
22-Jan-25	Deerfield Hall		Hot Water Tank #3	n/a	ND - Open - No action required
22-Jan-25	Deerfield Hall	Room 1082	Potable Hot Water	n/a	1 - Open - No action required
22-Jan-25	HMALC Building	Room 253	Potable Hot Water	n/a	ND - Open - No action required
21-Mar-25	New Science Building (NSB)	Penthouse	Potable Hot Water	n/a	ND - Open - No action required
21-Mar-25	Instructional Centre (IB)	Kitchen	Hot Water Tank	n/a	ND - Open - No action required
21-Mar-25	Instructional Centre (IB)		Potable Hot Water	n/a	ND - Open - No action required
21-Mar-25	New Science Building (NSB)	Penthouse	Hot Water Tank	n/a	ND - Open - No action required
21-Mar-25	Kaneff Centre/Innovation Complex	Room 103	Potable Hot Water	n/a	ND - Open - No action required
21-Mar-25	CCT	Room 4199	Potable Hot Water	n/a	ND - Open - No action required
21-Mar-25	William G. Davis Building (DV)	JKL DV1111	Potable Hot Water	n/a	ND - Open - No action required
21-Mar-25	William G. Davis Building (DV)	Room 4002	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Student Centre		Hot Water Tank #2	n/a	ND - Open - No action required
3-Apr-25	Student Centre		Hot Water Tank #2	n/a	ND - Open - No action required
3-Apr-25	Kaneff Centre		Hot Water Tank #2	n/a	ND - Open - No action required
3-Apr-25	Erindale Hall	Room 106	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Innovation Complex		Hot Water Tank #2	n/a	ND - Open - No action required
3-Apr-25	Oscar Peterson Hall	Lobby Washroom	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Roy Ivor Hall	Pod B	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Roy Ivor Hall	Pod C	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Roy Ivor Hall	Pod D	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Roy Ivor Hall	Pod A	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Innovation Complex		Hot Water Tank #1	n/a	ND - Open - No action required
3-Apr-25	CCT	Penthouse	Hot Water Tank #2	n/a	ND - Open - No action required
3-Apr-25	Health Sciences Complex	Basement	Potable Hot Water	n/a	ND - Open - No action required
3-Apr-25	Kaneff Centre	Room 269	Hot Water Tank #1	n/a	ND - Open - No action required