

Table 5 - Water Testing - UTM E. Coli and Total Coliform Results - September 17, 2025				E.COLI LIMITS
				Potable Cold-Water = 0 CFU/100-ml
				Potable Cold-Water ≥ 1 CFU/100-ml
				TOTAL COLIFORMS LIMITS
				Potable Cold-Water = 0 CFU/100-ml
				Potable Cold-Water ≥ 1 CFU/100-ml
Test Date	Building	Room Tested	Room Description	Room Status
21/Apr/21	WG Davis Building, ABCD Block	DV5004	5th floor washroom	0 - Open - No action required
21/Apr/21	HMALC Building	Rm 253	Caretaker Closet on Level 2	0 - Open - No action required
21/Apr/21	Erindale Hall	Suite 207		0 - Open - No action required
21/Apr/21	Oscar Peterson Hall	Rm 600C	6th floor - Caretaker Closet	0 - Open - No action required
21/Apr/21	Roy Ivor Hall, BLOCK A	Rm 606		0 - Open - No action required
21/Apr/21	Roy Ivor Hall, BLOCK B	Rm 621		0 - Open - No action required
21/Apr/21	Roy Ivor Hall, BLOCK C		Main floor caretaker closet	0 - Open - No action required
21/Apr/21	Roy Ivor Hall, BLOCK D	Rm 645		0 - Open - No action required
10/Aug/21	RAWC	Men's locker rm 115	Cold Water faucet	0 - Open - No action required
10/Aug/21	DV JKL	Caretaking closet sink rm 1111	Cold Water faucet	0 - Open - No action required
10/Aug/21	HSC	Penthouse Mech Rm	Cold Water faucet	0 - Open - No action required
24/Aug/21	CCT	4199 – sink in caretaking closet	Cold Water faucet	0 - Open - No action required
24/Aug/21	IB	465 – sink in mechanical penthouse	Cold Water faucet	0 - Open - No action required
1-Dec-21	Student Centre	209	kitchen tap	0 - Open - No Action required
1-Dec-21	Lislehurst Building	kitchen	kitchen tap	0 - Open - No Action required
1-Dec-21	Early Learning Centre	113	laundry sink tap	0 - Open - No Action required
1-Dec-21	Alumni House	3	kitchen tap	0 - Open - No Action required
1-Dec-21	Kaneff Building	131	CC slop sink tap	0 - Open - No Action required
14-Jul-22	Central Utilities Plant	Lunch room	Cold Water faucet	0 - Open - No Action required
14-Jul-22	WG Davis Building, ABCD Block	Room 3029	Caretaking Closet cold water faucet	0 - Open - No Action required
14-Jul-22	WG Davis Building, JKL Block	Room 1111	Cold Water faucet	0 - Open - No Action required
14-Jul-22	RAWC Building	Family Change Room	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Erindale Hall	Suite 207	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Oscar Peterson Hall	Room 128, closet	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Roy Ivor Hall, Block A	Room 601	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Roy Ivor Hall, BLOCK B	Room 616	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Roy Ivor Hall, BLOCK C	Room 631	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Roy Ivor Hall, BLOCK D	Room 641	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Schreiberwood	Room 27	Cold water faucet	0 - Open - No Action required
6-Oct-22	McLuhan Court	Room 90	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Putnam Place	Room 115	Cold Water faucet	0 - Open - No Action required
6-Oct-22	Leacock Lane	Room 145	Cold water faucet	0 - Open - No Action required
6-Oct-22	MaGrath Valley	Room 154	Cold Water faucet	0 - Open - No Action required
17-Nov-22	CCT Building		Cold Water faucet	0 - Open - No Action required
17-Nov-22	HMALC Building	CC253	cold water faucet	0 - Open - No Action required
17-Nov-22	Research Greenhouse		Cold Water faucet	0 - Open - No Action required
17-Nov-22	Instructional Centre		cold water faucet	0 - Open - No Action required
17-Nov-22	Deerfield Hall	Room 1020	Cold Water faucet	0 - Open - No Action required
17-Nov-22	Maanjiwe nendamowinan		Cold Water faucet	0 - Open - No Action required
1-Dec-22	HSC		Cold water faucet	0 - Open - No Action required
1-Dec-22	Student Centre		Cold Water faucet	0 - Open - No Action required
1-Dec-22	Alumni House		Cold Water faucet	0 - Open - No Action required
14-Dec-22	Kaneff Building	Room 131A	Cold Water faucet	0 - Open - No Action required
14-Dec-22	Early Learning Centre	Room 113	Cold Water faucet	0 - Open - No Action required
31-Mar-23	Lislehurst Building		Cold Water faucet	0 - Open - No Action required
17-Jul-23	CCT Building	Room 4166	Cold Water faucet	0 - Open - No Action required
17-Jul-23	Instuctional Centre	Room 29	Cold Water faucet	0 - Open - No Action required
17-Jul-23	Deerfield Hall	Room 1740	Cold Water faucet	0 - Open - No Action required
17-Jul-23	Maanjiwe nendamowinan	Room 7250	Cold Water faucet	0 - Open - No Action required
17-Jul-23	Kaneff Building	Room 131	Cold Water faucet	0 - Open - No Action required
8-Aug-23	Roy Ivor Hall, BLOCK A	Room 603	Cold Water faucet	0 - Open - No action required
8-Aug-23	Roy Ivor Hall, BLOCK B	Room 618	Cold Water faucet	0 - Open - No action required
8-Aug-23	Roy Ivor Hall, BLOCK C	Room 632	Cold Water faucet	0 - Open - No action required
8-Aug-23	Roy Ivor Hall, BLOCK D	Laundry	Cold Water faucet	0 - Open - No action required
8-Aug-23	Erindale Hall	Room 106	Cold Water faucet	0 - Open - No action required
8-Aug-23	Oscar Peterson Hall	Lobby Washroom	Cold Water faucet	0 - Open - No action required
18-Sep-23	Central Utilities Plant	Room 402	Cold Water faucet	0 - Open - No action required
19-Sep-23	RAWC	Room P001	Cold Water faucet	0 - Open - No action required
19-Sep-23	WG Davis Building, ABCD Block	Room 4034	Cold Water faucet	0 - Open - No action required
19-Sep-23	WG Davis Building, JKL Block	Room 2115J	Cold Water faucet	0 - Open - No action required
12-Oct-23	McLuhan Court	Unit 55	Cold Water faucet	0 - Open - No action required
12-Oct-23	Schreiberwood	Unit 25	Cold Water faucet	0 - Open - No action required
12-Oct-23	MaGrath Valley	Unit 156	Cold Water faucet	0 - Open - No action required
12-Oct-23	Leacock Lane	Unit 117	Cold Water faucet	0 - Open - No action required
12-Oct-23	Putnam Place	Unit 92	Cold Water faucet	0 - Open - No action required
23-Jan-24	Alumni House	Room 104	Cold Water faucet	0 - Open - No action required
23-Jan-24	Student Centre	Room 124	Cold Water faucet	0 - Open - No action required
24-Jan-24	Lislehurst Building	Room 102	Cold Water faucet	0 - Open - No action required
24-Jan-24	HMALC Building	Room 253	Cold Water faucet	0 - Open - No action required
24-Jan-24	Early Learning Centre	Laundry room	Cold Water faucet	0 - Open - No action required
13-Feb-24	Greenhouse		Cold Water faucet	0 - Open - No action required
13-Feb-24	HSC		Cold Water faucet	0 - Open - No action required
17-Sep-25	Roy Ivor Hall	Room 631	Cold Water faucet	0 - Open - No action required
17-Sep-25	McLuhan Court	Unit 54	Cold Water faucet	0- Open - No action required

17-Sep-25	Erindale Hall	Room 108	Cold Water faucet	0 - Open - No action required
17-Sep-25	Roy Ivor Hall	Room 605	Cold Water faucet	0 - Open - No action required
17-Sep-25	Putnam Place	Unit 91	Cold Water faucet	0 - Open - No action required
17-Sep-25	Oscar Peterson Hall	Room 126	Cold Water faucet	0 - Open - No action required
17-Sep-25	Roy Ivor Hall	Room 616	Cold Water faucet	0 - Open - No action required
17-Sep-25	Schreiberwood	Unit 39	Cold Water faucet	0 - Open - No action required
17-Sep-25	MaGrath Valley	Unit 174	Cold Water faucet	0 - Open - No action required
17-Sep-25	Leacock Lane	Unit 117	Cold Water faucet	0 - Open - No action required
17-Sep-25	Roy Ivor Hall	Room 641	Cold Water faucet	0 - Open - No action required
17-Sep-25	Student Centre	Washroom	Cold Water faucet	0 - Open - No action required