

May 23, 2017

University of Toronto  
255 McCaul Street, Level 4  
Toronto, Ontario M5T 1W7

**Attn: Mr. Irfan Miraj, P.Eng., MHSc.**  
**Manager, Hazardous Construction Materials Group**

**Re: Results of PCM and TEM Air Monitoring Program**  
**May 15- 19, 2017**  
**University of Toronto – Medical Sciences Building**  
**1 King’s College Circle, Toronto, Ontario**

---

## **1.0 INTRODUCTION**

Safetech Environmental Limited (SEL) has been retained from May 15 to May 19, 2017 to provide air monitoring services for the University of Toronto’s Medical Sciences Building located at 1 King’s College Circle, Toronto, Ontario M5S 1A8. Air sampling has been performed at the request of Mr. Irfan Miraj, Manager, Hazardous Construction Materials Group, to determine if airborne asbestos fibre concentrations are within acceptable and applicable limits. This report provides detail of air sampling conducted from May 15-19, 2017.

From May 15 to May 19, SEL has collected a total of 70 representative samples, 2 location specific samples and 10 outdoor samples:

- Representative samples refer to locations that were uniformly selected and also upon occupant request. These “building-wide” air samples provide an overview of air quality with regard to airborne fibres.
- Location samples refer to samples taken pre- and post-asbestos clean-up in locations where asbestos-containing dust (>0.5%) were present.
- Outdoor reference samples were collected because asbestos fibres are naturally occurring.

## **2.0 SUMMARY OF CONCLUSIONS**

The Medical Sciences Building air quality is not being negatively impacted by the presence of asbestos-containing building materials existing within the building. The building is deemed to be safe for general occupancy. In addition, although construction related work is being conducted at various locations within the Medical Sciences Building it does not appear that airborne fibres are being drawn into the heating, ventilation and air conditioning systems and negatively impacting the quality of air.

SEL has based above conclusions on the facts briefly described below:

- Of the 70 representative samples; all 70 samples indicate that at the time of sampling the airborne fiber concentrations were well below the TWA (time weighted average) of 0.1 fibers per cubic centimeter (f/cc), in accordance with Ontario Regulation 490/09, Designated Substances and also below 50% TWA; an action level followed by SEL.
- Of the 2 location specific samples; all 2 samples indicate that at the time of sampling the airborne fiber concentrations were well below the TWA (time weighted average) of 0.1 fibers per cubic centimeter (f/cc), in accordance with Ontario Regulation 490/09, Designated Substances and also below 50% TWA; an action level followed by SEL.
- All 10 outdoor samples also indicated that at the time of sampling the airborne fiber concentrations were well below 0.1f/cc.

Please refer to Appendix A detailed spread sheets and technical reports of aforementioned samples. As explained in next section (3.1), other non-asbestos fibres and particles may interfere and result in higher fibre counts. Therefore the results shown in Appendix A do not reflect airborne concentrations of asbestos alone but for the purpose of this assessment, it is compared to the TWA for asbestos. Actual airborne asbestos fibre concentration may be lower than the values in Appendix A.

### **3.0 METHODOLOGY**

#### **3.1 Air Monitoring for Airborne Fibres**

Phase contrast microscopy (PCM) air samples were retrieved within designated locations. The air samples were collected using a 25-mm three-piece filter cassettes containing a 0.8  $\mu\text{m}$  cellulose ester membrane filter and equipped with a 50-mm electrically conductive extension cowl. The filter cassettes were attached to a high volume air sampling pump calibrated with a filter cassette in line to a known flow rate.

The air sampling pumps were calibrated to a flow rate of approximately 15 litres per minute. The air samples were collected using 25 mm three piece cassette with 50 mm electrically conductive extension cowl and mixed cellulose ester filter, 0.8  $\mu\text{m}$  (recommended 0.45 to 1.2 in method) effective pore size, and back-up pad. The air samples were analyzed in accordance with U.S. National Institute of Occupational Safety and Health (NIOSH) Manual of Analytical Methods, Method 7400, Issue 2: Asbestos and other Fibres by PCM (August 15, 1994), using the asbestos fibre counting rules.

The quantitative working range of this method is 0.04 to 0.5 fibre/cc for a 1000 L air sample. The Limit of Detection (LOD) depends on sample volume and quantity of interfering dust, and is < 0.01 fibre/cc for atmospheres free of interferences. The method gives an index of airborne fibres. Fibres less than approximately 0.25 µm in diameter will not be detected by this method. In addition, other airborne fibres and particles that fall within the counting range criteria may act as possible interferences. Demolition and construction related work areas where high levels of dust are present might overload the membrane and/or interfere with the analysis. As required by NIOSH Method 7400, blank filters were submitted for analysis to ensure that no contamination of the filters occurred during sampling or analytical procedures. Analytical results, as reported in the result table of this report have been field blank corrected.

### **3.2 Transmission Electron Microscopy**

Where PCM results indicate airborne fibres to be greater than 50% of the TWA, a secondary analysis of air samples was conducted using NIOSH Method 7402, Issue 2: Asbestos by TEM (August 15, 1994). This method is used to determine asbestos fibres in the optically visible range and has the ability to distinguish asbestos fibres from other types of fibres (e.g. clothing fibres). It is intended to complement the results obtained by phase contrast microscopy (NIOSH Method 7400).

In accordance with this method, a sample is analyzed at a magnification of 10,000 times. Only fibres with an aspect ratio of >3:1 and only those fibres greater than 5 µm in length are counted. The quantitative working range of this method is 0.04 to 0.5 fibres per cubic centimetre (f/cc) for a 1000 litre (L) air sample. The Limit of Detection (LOD) depends on sample volume and quantity of interfering dust, and is < 0.01 fibres per cubic centimetre (f/cc) for atmospheres free of interferences. Other amphibole particles that have asbestos ratios greater than 3:1 and elemental compositions similar to the asbestos minerals may interfere in the TEM analysis. Some non-amphibole minerals may give electron diffraction patterns similar to amphiboles. High concentrations of background dust may also interfere with fibre identification.

## **4.0 LIMITATIONS**

The investigation, assessments and recommendations detailed in this report were carried out in a manner consistent with the level of care and skill normally exercised by reasonable members of the environmental and industrial hygiene consulting profession currently practicing under similar conditions in the area. Furthermore, the investigation, assessments and recommendations in this report have been made based on conditions observed at the time of the assessment and are limited to the areas investigated.


In preparing this report, Safetech Environmental Limited (SEL) relied on information supplied by others. Except as expressly set-out in this report, SEL has not made any independent verification of such information.

The analytical method used meets the requirements of O.Reg. 278/05. However, it is important to note that this method is not specific to the identification of asbestos fibres. All particles with a length greater than 5 micrometres, less than 3 micrometres in diameter and a length to diameter ratio of 3 to 1 or greater are included in the count. Fibres with diameters less than about 0.3 micrometres cannot be detected using this method regardless of length.

This report has been prepared for the sole use of the person or entity to who it is addressed. No other person or entity is entitled to use or rely upon this report without the express written consent of Safetech Environmental Limited and the person or entity to who it is addressed. Any use that a third party makes of this report, or any reliance based on conclusions and recommendations made, are the responsibility of such third parties. SEL accepts no responsibility for damages suffered by third parties as a result of actions based on this report.

Should you have any questions regarding this project, please contact our office.  
Sincerely,

SAFETECH ENVIRONMENTAL LIMITED



Josh Hamilton  
OH&S Technician



D. Glenn Smith, BA, CRSP, AMRT  
Senior Project Manager

**Appendices:**

- Appendix A – PCM Air Sample Spreadsheets – SEL
- Appendix B – PCM Location Specific Report
- Appendix C – Pump Calibration Sheets
- Appendix D – PCM Analysis Example Calculation Sheet

# Appendix A

## PCM AIR SAMPLE SPREADSHEET-SEL

---

**Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 3, University of Toronto, May 19, 2017**

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
3	3287K	Hallway	Central	2017-05-1061	6	15.08	10:12	12:19	127	1915	5.5	0.001	SC/GS	Yes	Occupied.
3	3388K	Hallway	Central	2017-05-1062	5	15.04	10:16	12:21	125	1880	4.5	0.001	SC/GS	Yes	Occupied.
3	3249K	Hallway	Central	2017-05-1063	9	15.04	10:20	12:24	124	1865	6	0.001	SC/GS	Yes	Occupied.
3	3374K	Hallway	Central	2017-05-1064	7	15.01	10:26	12:26	120	1801	5.5	0.001	SC/GS	Yes	Occupied.
3	3369K	Hallway	Central	2017-05-1065	8	14.96	10:30	12:29	119	1780	4	0.001	SC/GS	Yes	Occupied.
3	3348K	Hallway	Central	2017-05-1066	10	15.03	10:34	12:21	107	1608	5	0.001	SC/GS	Yes	Occupied.
3	3279	Janitorial Room	Central	2017-05-1067	2	14.98	10:41	12:36	115	1723	1.5	0.001	SC/GS	Yes	Not Occupied.
3	3327	Dark Room	Central	2017-05-1068	1	15.05	10:47	12:40	113	1701	3	0.001	SC/GS	Yes	Not Occupied.
3	3322K	Hallway	Central	2017-05-1069	6	15.08	12:45	14:21	96	1448	3	0.001	SC/GS	Yes	Occupied.
3	3234K	Hallway	Central	2017-05-1070	5	15.04	12:49	14:18	89	1339	4.5	0.001	SC/GS	Yes	Occupied.
3	3234	Elevator Lobby	Central	2017-05-1071	7	15.01	12:52	14:24	92	1381	7.5	0.002	SC/GS	Yes	Occupied.
3	3320K	Hallway	Central	2017-05-1072	9	15.04	12:57	14:27	90	1354	4	0.001	SC/GS	Yes	Occupied.
3	3239K	Hallway	Central	2017-05-1073	10	15.03	13:01	14:29	88	1323	8	0.003	SC/GS	Yes	Occupied.
3	3201K	Hallway	Central	2017-05-1074	8	14.96	13:04	14:30	86	1287	3	0.001	SC/GS	Yes	Occupied.

## Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 3, University of Toronto, May 19, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
	Exterior Control	NA	South of Medical Sciences Building	2017-05-1075	2	14.98	13:08	14:35	87	1303	1	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-1076	1	15.05	13:11	14:41	90	1355	2.5	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-1077	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1078	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1079	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1080	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7

Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.

2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.



**Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 5, University of Toronto, May 18, 2017**

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
5	5369K	Hallway	Adjacent to 5364	2017-05-1042	5	15.02	11:20	14:36	76	1142	4.5	0.002	SC/GS	Yes	Gasket Installation.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-1055	1	15.05	14:04	15:14	70	1054	2	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-1056	2	15.01	14:08	15:19	71	1066	3	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-1057	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1058	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1059	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1060	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7

Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

- 1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.
- 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.





**Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 4, University of Toronto, May 18, 2017**

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
4	4280	Lab	Central	2017-05-1043	1	15.05	11:40	13:10	90	1355	3	0.001	SC/GS	Yes	Not Occupied.
4	4243	Janitorial Room	Central	2017-05-1044	2	15.01	11:45	13:14	89	1336	3.5	0.001	SC/GS	Yes	Not Occupied.
4	4185K	Hallway	Central	2017-05-1045	6	15.09	11:50	13:19	89	1343	4.5	0.001	SC/GS	Yes	Occupied.
4	4374K	Hallway	Central	2017-05-1046	9	14.96	11:56	13:22	86	1287	8	0.003	SC/GS	Yes	Occupied.
4	4384K	Hallway	Central	2017-05-1047	7	14.97	12:00	13:24	84	1257	5	0.002	SC/GS	Yes	Occupied.
4	4369K	Hallway	Central	2017-05-1048	8	15	12:05	13:30	85	1275	2	0.001	SC/GS	Yes	Occupied.
4	4350K	Hallway	Central	2017-05-1049	10	14.99	12:08	13:32	84	1259	4	0.001	SC/GS	Yes	Occupied.
4	4349K	Hallway	Central	2017-05-1050	6	15.09	13:37	14:46	69	1041	4	0.002	SC/GS	Yes	Occupied.
4	4234	Elevator Lobby	Central	2017-05-1051	8	15	13:42	14:52	70	1050	6	0.002	SC/GS	Yes	Occupied.
4	4342A	Office	Central	2017-05-1052	9	14.96	13:47	15:01	74	1107	4	0.002	SC/GS	Yes	Occupied. Door Open.
4	4322K	Hallway	Central	2017-05-1053	7	14.97	13:52	14:01	69	1033	3	0.001	SC/GS	Yes	Occupied.
4	4222K	Hallway	Central	2017-05-1054	10	14.99	13:58	15:08	70	1049	2	0.001	SC/GS	Yes	Occupied.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-1055	1	15.05	14:04	15:14	70	1054	2	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-1056	2	15.01	14:08	15:19	71	1066	3	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-1057	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1058	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1059	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1060	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7  
 Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.  
 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.



## Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 5, University of Toronto, May 17, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
5	5272	Janitorial Room	Central	2017-05-1022	1	15.03	10:20	12:07	107	1608	2.5	0.001	JC	Yes	Not Occupied.
5	5272K	Hallway	Central	2017-05-1023	5	15.05	10:23	12:09	106	1595	5.5	0.002	JC	Yes	Occupied.
5	5369K	Hallway	Central	2017-05-1024	8	15.02	10:26	12:12	106	1592	3	0.001	JC	Yes	Occupied.
5	5350K	Hallway	Central	2017-05-1025	10	14.98	10:29	12:16	107	1603	8	0.002	JC	Yes	Occupied.
5	5348K	Hallway	Central	2017-05-1026	7	15.01	10:34	12:20	106	1591	3.5	0.001	JC	Yes	Occupied.
5	5324K	Hallway	Central	2017-05-1027	9	14.96	10:38	12:24	106	1586	7	0.002	JC	Yes	Occupied.
5	5234	Elevator Lobby	Central	2017-05-1028	6	15.11	10:44	12:29	105	1587	5.5	0.002	JC	Yes	Occupied.
5	5323	Janitorial Room	Central	2017-05-1029	2	15.04	10:48	12:26	98	1474	6	0.002	JC	Yes	Not Occupied.
5	5322K	Hallway	Central	2017-05-1030	6	15.11	12:35	13:51	76	1148	4.5	0.002	JC	Yes	Occupied.
5	5201K	Hallway	Central	2017-05-1031	5	15.05	12:39	13:53	74	1114	8	0.003	JC	Yes	Occupied.
5	5222K	Hallway	Central	2017-05-1032	9	14.96	12:43	13:56	73	1092	13	0.006	JC	Yes	Occupied.
5	5322K	Hallway	Central	2017-05-1033	7	15.01	12:47	13:59	72	1081	4.5	0.002	JC	Yes	Occupied.
5	5228	Equipment Room	Central	2017-05-1034	10	14.98	12:51	14:02	71	1064	4.5	0.002	JC	Yes	Not Occupied.
5	5334	Lab	Central	2017-05-1035	8	15.02	12:53	14:05	72	1081	5	0.002	JC	Yes	Occupied.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-1036	2	15.04	12:59	14:11	72	1083	2	0.001	JC	Yes	Exterior sample for comparison.

## Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 5, University of Toronto, May 17, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
	Exterior Control	NA	North of Medical Sciences Building	2017-05-1037	1	15.03	13:03	14:14	71	1067	2	0.001	JC	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-1018	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1019	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1020	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1021	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7

Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.

2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.



**Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 6, University of Toronto, May 16, 2017**

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
6	6276	Janitorial Closet	Central	2017-05-1002	8	14.98	9:40	11:57	137	2052	7	0.001	SC/GS	Yes	Not Occupied.
6	6369K	Hallway	Central	2017-05-1003	5	15.07	9:44	12:17	153	2306	5	0.001	SC/GS	Yes	Occupied.
6	6342	Lab	Central	2017-05-1004	2	15.05	9:48	12:58	190	2860	3	0.001	SC/GS	Yes	Occupied.
6	6254K	Hallway	Central	2017-05-1005	1	15.02	9:52	12:20	148	2223	9	0.002	SC/GS	Yes	Occupied.
6	6250K	Hallway	Central	2017-05-1006	10	14.95	9:55	12:23	148	2213	7	0.001	SC/GS	Yes	Occupied.
6	6348K	Hallway	Central	2017-05-1007	9	15.01	9:58	12:26	148	2222	11	0.002	SC/GS	Yes	Occupied.
6	6234	Elevator Lobby	Central	2017-05-1008	7	15.02	10:01	12:30	149	2238	3	0.001	SC/GS	Yes	Occupied.
6	6303	Conference Room	Central	2017-05-1010	7	15.02	12:39	14:10	91	1367	6	0.001	SC/GS	Yes	Occupied.
6	6302	Lab	Central	2017-05-1011	9	15.01	12:42	14:14	92	1381	11	0.003	SC/GS	Yes	Occupied.
6	6324K	Hallway	Central	2017-05-1012	10	14.95	12:53	14:17	84	1256	6.5	0.002	SC/GS	Yes	Occupied.
6	6221K	Hallway	Central	2017-05-1013	8	14.98	12:57	14:19	82	1228	3	0.001	SC/GS	Yes	Occupied.
6	6226	Janitorial Room	Central	2017-05-1014	2	15.05	13:01	14:22	81	1219	4	0.001	SC/GS	Yes	Not Occupied.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-1016	1	15.02	13:24	14:56	92	1382	3	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-1017	5	15.07	13:30	15:01	91	1371	2	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-1018	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1019	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1020	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1021	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7  
 Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.  
 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.



## Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 5, University of Toronto, May 16, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
5	5324K	Hallway	Adjacent to 5323	2017-05-1001	6	15.09	9:23	10:35	72	1086	4	0.002	SC/GS	Yes	Gasket Installation.
5	5348K	Hallway	Adjacent to 5340	2017-05-1009	6	15.09	11:15	13:12	117	1766	8	0.002	SC/GS	Yes	Gasket Installation.
5	5348K	Hallway	Adjacent to 5348	2017-05-1015	6	15.09	13:17	14:34	77	1162	4	0.002	SC/GS	Yes	Gasket Installation.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-1016	1	15.02	13:24	14:56	92	1382	3	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-1017	5	15.07	13:30	15:01	91	1371	2	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-1018	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1019	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1020	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1021	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7

Tel: 905 624-2722  
 www.safetechenv.com



Interpretation of Results

- 1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.
- 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.

**Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 7, University of Toronto, May 15, 2017**

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
7	7271K	Hallway	Central	2017-05-983	9	15.03	10:18	11:43	85	1278	4.5	0.002	SC/GS	Yes	Occupied.
7	7239K	Hallway	Central	2017-05-984	7	14.99	10:21	11:46	85	1274	3	0.001	SC/GS	Yes	Occupied.
7	7369K	Hallway	Central	2017-05-985	10	14.96	10:25	11:49	84	1257	6	0.002	SC/GS	Yes	Occupied.
7	7347K	Hallway	Central	2017-05-986	6	15.05	10:31	11:52	81	1219	5.5	0.002	SC/GS	Yes	Occupied.
7	7223	Janitorial Closet	Central	2017-05-987	1	15.02	10:39	11:55	76	1142	3	0.001	SC/GS	Yes	Not Occupied.
7	7328K	Hallway	Central	2017-05-988	8	14.98	10:43	12:01	78	1168	3	0.001	SC/GS	Yes	Occupied.
7	7302K	Hallway	Central	2017-05-989	7	14.99	12:31	14:27	76	1139	4	0.002	SC/GS	Yes	Occupied.
7	7202K	Hallway	Central	2017-05-990	9	15.03	12:39	14:31	112	1683	6	0.002	SC/GS	Yes	Occupied.
7	7335	Glasswashing	Central	2017-05-993	8	14.98	12:56	14:39	103	1543	4	0.001	SC/GS	Yes	Occupied.
7	7234	Elevator Lobby	Central	2017-05-994	10	14.96	12:59	14:35	96	1436	8	0.002	SC/GS	Yes	Occupied.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-995	6	15.05	13:22	14:53	91	1370	3	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-996	1	15.02	13:27	14:57	90	1352	2	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-997	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-998	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-999	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1000	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7  
 Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

- 1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.
- 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.



## Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 6, University of Toronto, May 15, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
6	6324K	Hallway	Adjacent to 6323	2017-05-981	5	15.06	9:03	11:27	84	1265	20	0.007	SC/GS	Yes	Gasket Installation.
6	6334	Lab	Central	2017-05-982	2	15.09	10:01	12:48	168	2535	6	0.001	SC/GS	Yes	Not Occupied.
6	6334	Lab	Central	2017-05-992	2	15.09	12:49	14:44	115	1735	3	0.001	SC/GS	Yes	Not Occupied.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-995	6	15.05	13:22	14:53	91	1370	3	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-996	1	15.02	13:27	14:57	90	1352	2	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-997	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-998	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-999	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1000	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7

Tel: 905 624-2722  
 www.safetechenv.com



Interpretation of Results

1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.

2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.

**Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 4, University of Toronto, May 15, 2017**

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
4	4324K	Hallway	Adjacent to 4323	2017-05-981	5	15.06	12:45	14:21	96	1446	10	0.003	SC/GS	Yes	Gasket Installation.
	Exterior Control	NA	South of Medical Sciences Building	2017-05-995	6	15.05	13:22	14:53	91	1370	3	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	North of Medical Sciences Building	2017-05-996	1	15.02	13:27	14:57	90	1352	2	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-05-997	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-998	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-999	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-05-1000	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limited  
 3045 Southcreek Road, #14  
 Mississauga, Ontario  
 L4X 2X7

Tel: 905 624-2722  
 www.safetechenv.com

Interpretation of Results

1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.

2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.





# Appendix B

## LOCATION SPECIFIC REPORT

---



**TABLE I**  
**Results of Air Testing Associated with Asbestos Abatement**  
**Gasket Installations**  
**University of Toronto, Medical Sciences Building**  
**May 15, 2017**

<b>Sample No.</b>	<b>Sample Location</b>	<b>Start Time</b>	<b>Stop Time</b>	<b>Sample Volume (L)</b>	<b>Airborne Fibre Conc. (f/cc)</b>
2017-05-981	6324K Adjacent to 6323	9:03	11:27	1265	0.007
2017-05-991	4324K Adjacent to 4323	12:45	14:21	1446	0.003

# Appendix C

## PUMP CALIBRATION SHEET

---



